

FINAL REPORT

HVAC System Engineering Feasibility Study Old Main

Commonwealth of Pennsylvania
State System of Higher Education
Shippensburg University
1871 Old Main Drive
Shippensburg, Pennsylvania 17257



Prepared by



Century Engineering, Inc.
200 Airport Road
New Cumberland, PA 17070
(717) 901-7055



December 30, 2011

103073.01

TABLE OF CONTENTS

	<u>Page</u>
EXECUTIVE SUMMARY	1
INTRODUCTION/BACKGROUND	3
EXISTING CONDITIONS/LOAD STUDY	6
DISCUSSION/BUILDING SYSTEM REQUIREMENTS	9
ANALYSIS AND RECOMMENDATIONS	10
FEASIBILITY/IMPLEMENTATION	12
BUDGET/COST IMPLICATIONS	14
CONCLUSION	21

APPENDICES

A	Option 2 VAV Zoning Plans
B	Block Load Data
	B-1 Building Envelope Input Data
	B-2 Space Input Data
	B-3 Air System Input Data
	B-4 Air System Output Data
C	Sample Equipment Submittals
	C-1 McQuay
	C-2 Johnson Controls

EXECUTIVE SUMMARY

Century Engineering has been issued a work order (#2011-1, under Contract #5000000031) by Shippensburg University of the State System of Higher Education of the Commonwealth of Pennsylvania to provide a feasibility study for upgrading the HVAC system serving Old Main located at 1871 Old Main Drive.

Old Main is the signature building on campus. The overall goal of this study is to determine what HVAC system upgrades and specific options are available to bring the entire building up to code compliant conditions, including efficient energy management, providing each space with reasonable temperature control and a comfortable working atmosphere. This study presents an engineering opinion on how best to utilize small annual funding sources to make progress on the overall goal and to achieve maximum results for any portion of HVAC upgrades that would benefit the building along the way. In order to limit the complexity of this analysis, a few assumptions have been made to help narrow the focus onto specific options which present a more realistic approach to renovating this particular building.

Old Main is partially conditioned by an existing mechanical HVAC system consisting of two central station, four-pipe air handling units (approximately 60 Tons each), that have been in service since the last major renovation effort in 1984-85. It has been reported that maintenance staff have at times had to manually isolate floors individually to control airflow in order to bring adequate HVAC system capacity to all areas of the building. It is clear that the existing system has surpassed its expected service life, having been in operation for over twenty-five years. Because of the present condition and limited operability of the HVAC system, the University requested this study in order to suggest recommended upgrades to rectify the problems in the best way possible with the goal in mind to increase overall building energy efficiency.

As part of this study a peak block cooling load calculation was performed on all floors of Old Main. The building load was divided into zoned groups of spaces based on exposure orientation and then grouped by floor and also by building quadrant. Old Main requires approximately 150 Tons of peak load cooling and approximately 4,600 CFM of outdoor ventilation air.

After careful examination of all assumptions and limiting factors involved, the following have been chosen for analysis and consideration:

- Option 1: Replace two (2) existing air handling units with two (2) new 75-Ton four-pipe variable air volume (VAV) air handlers and retrofit the existing zones with single duct VAV terminals with heating water coil; the heating water finned tube radiation system at the perimeter shall be retained as it is currently used.
- Option 2: Replace two (2) existing air handling units with four (4) new 38-Ton four-pipe variable air volume (VAV) air handlers isolating the four building quadrants into separate air systems; retrofit the existing zones with single duct VAV terminals with heating water coil; the heating water finned tube radiation system at the perimeter shall be retained as it is currently used.
- Option 3: Remove two (2) existing air handling units, the pneumatic zone dampers, and the heating water finned tube radiation system at the perimeter; provide four-pipe console fan coil units along the perimeter and concealed units where required for interior spaces; provide two (2) new 2,500 CFM dedicated outdoor air energy recovery units to provide tempered ventilation air to the conditioned zone spaces.

Each of the three design options listed above have their inherent advantages in terms of the overall benefits that each option provides and all three options will have a significant effect on improving overall building energy consumption. However, the feasibility of implementation can present a number of pitfalls and hurdles that must be considered and overcome along the way, which may affect the decision on which suggestion makes the most sense. A challenge is presented of determining what the best and most logical recommendation is for spending the annual funding allotments in order to achieve the end goal of a completely renovated Old Main building HVAC system.

It appears that the option that presents the most practical choice, offering more flexibility and ease of implementation, is the second featured alternative which suggests dividing Old Main into four separate variable air volume systems each with a four-pipe air handling unit and VAV air terminals. Any option that is chosen will require significant coordination of the multiple phases of implementation, but it appears as though splitting the building into quadrant systems allows the easiest to control for the use of incremental annual funding sources.

INTRODUCTION/BACKGROUND

Old Main is the signature building on campus, and houses administrative functions including the President's and Vice President's offices, as well as other administrative services, human resources, admissions, financial aid, registrar, and student accounts offices. Constructed in 1871, its reported last renovation occurred in 1984-85 when most of the HVAC systems were either upgraded or replaced.

The overall goal of this study is to determine what HVAC system upgrades and specific options are available to bring the entire building up to code compliant conditions, including efficient energy management, providing each space with reasonable temperature control and a comfortable working atmosphere. This includes providing systems analysis and "order-of-magnitude" opinions of probable construction cost to determine the approximate funding level required to achieve this overall goal. It is evident that the level of funding to achieve this goal in its entirety may not be available for some time; however, a lower level of project funding in annual increments should be available in the near future. Therefore, this study presents an engineering opinion on how best to utilize these smaller funding sources to make progress on the overall goal and to achieve maximum results for any portion of HVAC upgrades that would benefit the building along the way.

When evaluating existing buildings for recommendations for renovating mechanical systems, the analysis must consider a wide range of choices with regard to the types of systems that are available. In order to limit the complexity of this analysis, a few assumptions have been made to help narrow the focus onto specific options which present a more realistic approach to renovating this particular building.

- One assumption is obviously the limitation on project funding, as already mentioned. The entire building HVAC system will not be able to be demolished for full replacement all under one effort. Any upgrades to the HVAC system will be assumed to be implemented as partial upgrades with changes made on an incremental basis according to availability of funding and building logistics such as time schedule and occupancy. It is understood that there will be a limitation of available funding in annual increments, which is to be appropriated as an annual maintenance budget for Old Main.
- Another assumption heavily considers the historical nature of this building and the limitations that the existing architecture presents on the notion of renovation activity. Mechanical construction must be able to be accomplished without altering or destroying the historical significance of the building's appearance. Mechanical system recommendations have assumed that little to no major architectural alterations to any parts of Old Main are desired by the University or any governing historical society or group.

- It is assumed that during and throughout any renovation construction activity, the remainder of the building is to remain fully functional and occupied continuously. While minor inconveniences are unavoidable during this type of work, the recommendations presented have taken into consideration what level of impact the suggested renovation activity could have on the facility and its occupants.
- The existing building envelope including the wall, window, and roof constructions will remain in their current state and any plans for upgrading or renovating any one or all of these architectural systems have not been considered here. It should be noted that the existing wall, window, and roof constructions appear to be marginally insulated, if at all, and are most likely not conducive to enhancing the energy efficiency of proposed mechanical systems nor contributory to the reduction of the heating and cooling capacity required to condition the spaces for optimal human comfort. Consideration of optimizing the building envelope will surely help a great deal, but are beyond the scope of this analysis.
- The mechanical HVAC systems currently serving Old Main use a central plant that produces chilled water, hydronic heating water, and hydronic heating glycol as the heat transfer media used in the HVAC systems equipment. It is reported that these central plant utilities are intended to remain in place for the short-term future while a campus-wide central plant is in the planning stages to serve this building in the long-term. Therefore, the system recommendations presented have only considered those that use chilled and heating water equipment and other systems such as DX refrigerant based, gas-fired packaged or water source heat loop have been eliminated from consideration. Should this assumption be determined to be too narrow, then consideration of these other types of systems may be expanded upon.
- The system of automatic temperature control (ATC) that is currently installed in Old Main consists of a web-based BACnet compatible direct digital control (DDC) network backbone (by Automated Logic Corporation) that controls the existing hydronic heating and cooling equipment and distribution pumps as well as the control of the existing air handling units. It is assumed that any future HVAC renovations will utilize or expand this existing ATC system network as required to sequence and control any additional new equipment.

As part of this feasibility study effort, Century Engineering has performed the following tasks under the scope of this work:

- A cursory overall review of the existing building documentation available which includes the original mechanical renovation drawings (c. 12/29/1982), Century Room upgrades (c. 12/15/1998), and the relocation of the existing chiller condensing units (7/28/1997). Other documents reviewed were the "Feasibility Study for the Old Main Chapel," (RPA,

1/14/2008), "Central Chilled Water System Evaluation," (EEI, 6/10/2010), and the Old Main ATC As-Builts, (Intercon Automation, 7/7/2005).

- A preliminary site visit to Old Main for the purpose of observing the extent of the existing mechanical HVAC systems and equipment in order to gain visual knowledge of the age, condition, and overall functioning state of the system as it currently operates. This site visit was also to determine evidence of any major deviations from the existing documents as they were reviewed and to visually assess the general architectural layout and construction of the building.
- General discussions during initial and subsequent site visits with Shippensburg University maintenance personnel regarding the overall condition, history, and operation of the existing HVAC systems and equipment.
- Completion of overall estimated building block heating and cooling load calculations using basic assumptions for the purpose of determining general overall expected systems capacity requirements for both heating and cooling capacity and necessary volumes of outdoor air for use in meeting the current ventilation requirements. These calculations do not provide sufficient data for use with any detailed design preparation and it is recommended that a more extensive detailed analysis be performed in the future to meet any actual design purpose.
- Analyzed, selected, and evaluated potential options, alternatives, and cost implications of mechanical HVAC system renovations that could be offered for consideration to be implemented into Old Main taking into account the confines of the realm of assumptions made.
- Presented a Preliminary Draft Report documenting initial progress of the essential tasks pertinent to realizing the achievement of the overall goal of this study.
- Participated in a review discussion of the Preliminary Draft Report with Shippensburg University facilities managers.
- A follow-up site visit to Old Main for the purpose of observing in closer detail some of the pneumatic bladder dampers and their associated controls and completing a detailed survey of the existing zone control thermostats while documenting current space usage.
- Presented this Final Draft Report documenting the completion of the full HVAC System Feasibility Study of Old Main, including the compilation of supporting analysis data, floor plans showing proposed zoning diagrams, and revisions to previously submitted order-of-magnitude project costs.

EXISTING CONDITIONS/LOAD STUDY

Old Main is partially conditioned by an existing mechanical HVAC system consisting of two central station four-pipe air handling units (approximately 60 Tons each), that have been in service since the last major renovation effort in 1984-85. These units were originally variable volume by way of variable guide vanes at the inlets to the supply fans. With the retrofit of new variable frequency drives, the air handling units have since been converted for variable air volume (VAV) operation with full air-side economizer mode. These two AHUs are situated on the top (4th) floor of the building in mechanical equipment rooms located on the back (North) side of the building at opposite ends of the main central corridor. Each unit is tasked with serving half of the building including spaces on the first, second, and third floors and are practically identical in size, capacity, and configuration. Two inline return/relief fans are located in the upper attic space above the fourth floor main corridor and are each assigned to one of the main air handling units. Four-pipe hydronic service is distributed from the basement central plant consisting of two 70-Ton (nominal) capacity split system chillers and a 1700 MBH steam-glycol hot water convertor. Two additional 812 MBH steam-hot water convertors in the basement also produce heating water that serves all of the perimeter finned tube radiation heating throughout the building.

The fourth floor is presently unoccupied and contains small rooms that have been abandoned and were not renovated in the 1984-85 major improvement to the building. Subsequently, this floor is not mechanically conditioned or ventilated by the central HVAC system with the exception of a limited number of heating water unit heaters installed in the corridors. The HVAC system as described above distributes conditioned mixed supply air to the third, second, and first floors via vertical supply air ducts in each quadrant of the building. The supply air mains branch outward from duct shafts in each of the four quadrants on each floor where they separate into multiple sub-branches. Each sub-branch contains a duct-mounted pneumatically operated bladder-type damper which serves as a variable air volume (VAV) type zone control device. These air systems use the central air handlers to produce low pressure variable amounts of air via the bladder-type zone dampers to provide a temperature responsive system for the end users. Each pneumatically operated zone damper is controlled by a single differential pressure sensor downstream of the damper to maintain airflow to the conditioned spaces within the zone. Temperature in each space is controlled by dedicated room thermostats, which operate individual duct-mounted pneumatically operated bladder dampers or variable air volume ceiling supply air diffusers, which in turn control static pressure downstream of their respective zone dampers. The existing zone dampers are presently in poor operating condition and are failing due to age. This is making it extremely difficult to maintain overall building control with respect to adequate air distribution and control of temperature and humidity. It has been reported that maintenance staff have at times had to manually isolate floors individually to control airflow in order to bring adequate HVAC system capacity to all areas of the building. The need for this has occurred primarily during a building start-up after an unoccupied shutdown period such as over a weekend or extended holiday.

It is clear that the existing system has surpassed its expected service life having been in operation for over twenty-five years and the current state of its operation is having a significant negative impact on overall building energy consumption. There have been attempts to upgrade and maintain the system as best as can be expected with items such as upgrades to the automatic temperature control (ATC) system and routine periodic maintenance to the air handling units including motor shafts and bearings. However, the main area of concern appears to be the inability of the pneumatic dampers to be able to operate properly. Most of these devices are located above hard ceilings or in otherwise difficult to access locations and cannot be repaired or maintained. Because of the present condition and limited operability of the HVAC system, the University requested this study in order to suggest recommended upgrades to rectify the problems in the best way possible with the goal in mind to increase overall building energy efficiency.

As part of this study a peak block cooling load calculation was performed on all floors of Old Main. The Chapel and the Institutional Research Wing were calculated separately. The Century Room café area was excluded since this area was recently renovated and adequate data is available regarding this system. As a result, Old Main requires a block cooling load capacity of approximately 150 Tons including the load due to incoming outdoor ventilation air. The following assumptions were made with regard to cooling load input factors. More detailed information is included in the Appendices of this document.

- Weather Data: Harrisburg, PA, Summer Design-92°Fdb/74°Fwb, Winter Design-9°F
- Exterior Wall Construction: 4" face brick, 8" HW concrete block (stone) masonry, uninsulated cavity, gypsum wallboard, u-value = 0.248
- Roof/Attic Construction: Slate, wood deck, 6" batt insulation, u-value = 0.044
- Window Construction: Wood framed, single pane, 1/8" clear glass, u-value = 0.98
- Spaces: Typical office criteria, 5 People/1000 sq.ft. (per ASHRAE 62.1-2007), Lighting = 1.0 W./sq.ft., Equipment = 1.5 W./sq.ft., Infiltration = 0.5 ACH (cooling)/1.25 ACH (heating)
- Ventilation Rate: 5.0 CFM/P. + 0.06 CFM/sq.ft. (typical office space per ASHRAE 62.1-2007)
- Thermostat Set Points: Occupied-75°F(cooling)/70°F(heating)
- Hydronic Service Temperatures: 12°F(dT, chilled water), 20°F(dT, heating water)

The building load was divided into zoned groups of spaces based on exposure orientation and then grouped by floor and also by building quadrant. The following tables summarize the calculated building loads. Due to the different grouping of spaces and zones from the Floor Grouping to the Quadrant Grouping, there is some diversity in the peak cooling and ventilation loads which is evident by the slightly differing total results as shown in the tabular data. It is important to note that these values, while differing slightly, are well within the same orders of magnitude and the differences are negligible for this analysis. Detailed breakdowns of the resultant block loads are included in the Appendices.

Zones Grouped By Floor

SYSTEM	Cooling Capacity (Tons)	Heating Capacity (MBH)	Ventilation Air (CFM)	Building Area (sq.ft.)
1 st Floor	40.2	531.6	1235	16,250
2 nd Floor	40.4	538.4	1080	14,205
3 rd Floor	33.6	456.1	1080	14,210
4 th Floor	37.1	498.7	1200	16,000
TOTAL	151.3	2024.8	4595	60,665

Zones Grouped By Quadrant

SYSTEM	Cooling Capacity (Tons)	Heating Capacity (MBH)	Ventilation Air (CFM)	Building Area (sq.ft.)
NW Core	31.1	383.2	875	10,690
SW Core	31.2	377.6	875	10,710
NE Core	26.5	334.7	715	8,840
SE Core	35.2	427.3	985	12,060
N4 Core/Main	29.1	502.2	1155	18,365
TOTAL	153.1	2025.0	4605	60,665

Note: N4 Core/Main includes the 4th Floor North Central Wing and all main corridors, stairs, and toilet rooms on all floors

SYSTEM	Cooling Capacity (Tons)	Heating Capacity (MBH)	Ventilation Air (CFM)	Building Area (sq.ft.)
Chapel	41.0	534.3	1920	5,555
Institutional Research Wing	5.9	77.0	175	2,045

BLDG. TOTAL	Cooling Capacity (Tons)	Heating Capacity (MBH)	Ventilation Air (CFM)	Building Area (sq.ft.)
Old Main Bldg.	200	2636	6700	68,265

DISCUSSION/BUILDING SYSTEM REQUIREMENTS

As outlined above, Old Main requires approximately 150 Tons of peak load cooling and approximately 4,600 CFM of outdoor ventilation air. The Chapel and the Institutional Research Wing add another approximately 47 Tons of cooling. An examination of the zoning method as depicted on the existing drawings indicates that the building load has been divided equally in half from East to West with a single air handling unit serving each half. The two building halves are then divided again with each air handling unit serving a specific quadrant of the building (AHU-1, NE/SE and AHU-2, NW/SW). Nominally, each half of the building can be approximated to require about 75 Tons where each of the four quadrants requires about 38 Tons of cooling and about 15,000 CFM of supply air.

- Each air handling unit serves half of the building and there are no provisions in place to provide any redundancy or flexibility should one of the air handling units be rendered inoperable due to failure or other shutdown of the unit. Therefore, one half of the building is affected if there is a shutdown of one of the air handlers for any reason. New HVAC upgrades should consider reducing the breadth of reliability on one air system by possibly further dividing the building zones into smaller HVAC systems.
- The existing systems are reportedly designed to include future capacity which is assumed to be the possible fit out of the fourth floor. To date there has been no fit out requiring extension of the HVAC system to the fourth floor. Any future HVAC upgrades should consider including all or at least a portion of the fourth floor load into the system capacity.
- Operations and activity within Old Main will be expected to continue while HVAC upgrades are occurring. Any future HVAC upgrades should take into account the effects that shutting down any portion of the building has allowing the least amount of disruption to the occupants and the functions that occur in those areas of the building.
- Old Main has several different exposure orientations and considerably different space usage diversity. For this reason, as much system flexibility as possible should be considered in order to properly satisfy the varying load conditions that may occur throughout the building at any given time. Several zones of control should be provided in any future HVAC systems upgrade.
- There is an existing direct digital control (DDC) network backbone already in place to provide a limited degree of building automation of the existing HVAC systems. It is assumed that any future HVAC upgrades will be incorporated into this existing system in order to expand the building automation capabilities. Any incremental system upgrades will have to be able to tie into the existing ATC system and be fully operational while the remaining systems continue to operate alongside them as they presently do.

ANALYSIS AND RECOMMENDATIONS

After careful examination of all assumptions and limiting factors involved, the following have been chosen for analysis and consideration:

- Option 1: Replace two (2) existing air handling units with two (2) new 75-Ton four-pipe variable air volume (VAV) air handlers and retrofit the existing zones with single duct VAV terminals with heating water coil; the heating water finned tube radiation system at the perimeter shall be retained as it is currently used.
- Option 2: Replace two (2) existing air handling units with four (4) new 38-Ton four-pipe variable air volume (VAV) air handlers isolating the four building quadrants into separate air systems; retrofit the existing zones with single duct VAV terminals with heating water coil; the heating water finned tube radiation system at the perimeter shall be retained as it is currently used.
- Option 3: Remove two (2) existing air handling units, the pneumatic zone dampers, and the heating water finned tube radiation system at the perimeter; provide four-pipe console fan coil units along the perimeter and concealed units where required for interior spaces; provide two (2) new 2,500 CFM dedicated outdoor air energy recovery units to provide tempered ventilation air to the conditioned zone spaces.

Option 1

It has already been mentioned that the existing HVAC systems equipment is well beyond its expected service life, so it goes without saying that the existing air handling units are in need of immediate replacement in order to satisfy their intended use and be considered reliable into the foreseeable future. A direct replacement of the existing air handling units is a straight-forward initial recommendation as it presents the option of replacing the aged equipment without changing any of the original functional intent of the system. Each unit would be located in the existing locations and sized for the intended load capacity, including the appropriate amount of outdoor ventilation air to meet the latest building code requirements. The failing pneumatically operated zone dampers would be replaced with single duct VAV terminals with zone controllers to produce a more reliable air distribution system with better zone comfort control. Control of these units can be incorporated into the existing building ATC system. It is possible that some or all of the system ductwork can be reused with little or no reconfiguration. The heating water finned tube radiation system at the perimeter serves the purpose of providing an offset to the building envelope heat losses and would continue to serve this purpose with little to no modifications needed.

Option 2

Much like the system described above in Option 1, this system alternative allows for the replacement of the aged existing AHUs with four new units while providing the flexibility and specialized zone coverage of a smaller capacity air system dedicated to a select building zone. Two of these new air handling units would be located in new mechanical equipment rooms on the fourth floor, constructed directly across from the existing rooms, while two additional new units would be located in the existing mechanical rooms. The vertical duct risers serving the two southern quadrants would be decoupled from the existing duct mains and isolated from the northern quadrants, each to be served by their own new air handling unit. The units would be sized for the capacity of a single quadrant load capacity and ventilation air requirement. Likewise, this option would provide replacement of the existing pneumatic dampers with VAV terminals while the perimeter heating system remains.

Option 3

This system alternative suggests the most radical change away from the existing design by essentially eliminating the notion of a central air system satisfying all of the building conditioning needs. Each space within the building conditioning zones would be provided with one or more four-pipe fan coil units providing all of the sensible cooling and heating requirements within a localized controlled zone. Console fan coil units fitted with chilled and heating water coils would be installed on the perimeter of the spaces along the exterior wall. A single-zone thermostat would control each unit individually to meet the immediate needs of the spaces. The perimeter finned tube heating system would be removed in this scenario. New chilled and heating water piping risers and lateral runs would be provided to serve each zone of fan coil units installed in each quadrant. The two existing air handling units would be removed and two new dedicated outdoor air energy recovery units would be provided in their place to deliver tempered ventilation air to the conditioned zone spaces. The existing duct shafts would be used for distribution of ventilation supply air and exhaust air removal.

FEASIBILITY/IMPLEMENTATION

A key part of the decision making process when considering upgrades and modifications to existing buildings is the impact that the renovation concept has on the ability to get the work done. Each of the three design options listed above have their inherent advantages in terms of the overall benefits that each option provides and all three options will have a significant effect on improving overall building energy consumption. However, the feasibility of implementation can present a number of pitfalls and hurdles that must be considered and overcome along the way which may affect the decision on which suggestion makes the most sense.

Option 1

While this option seems like the simplest and most logical decision whereby the existing air handling units are replaced in kind, the impact on the total building is larger. As mentioned before, each of the two existing air handlers serves one half of the building. In order to replace even one of them there would have to be a total shutdown of that half of the building to get the old unit out and install the new unit in its place and get it up and running. This could take several weeks to accomplish. Careful planning would have to be arranged ahead of time in order to coordinate this type of shutdown. However, once completed there would not be any further need to disrupt this amount of building occupancy and the remainder of the recommended upgrades can take place fairly easily. Each quadrant zone can be isolated from the central system and retrofitted one floor at a time. Once the retrofit is completed, it can be tied into the air system main and brought online. The overall impact would only be to the functionality of the spaces being renovated at that particular time period. This could more than likely be coordinated rather easily with some prior planning and availability of swing space. The existing pneumatic dampers, controls, and a majority of the ductwork will have to be removed. With the retrofitting of the existing zone dampers with VAV terminals, there will be the requirement for some minor architectural modifications as existing ceiling spaces will have to be accessed and bulkheads and ceiling heights may have to be altered in order to accommodate the installation of new equipment. This presents some unique challenges in different parts of Old Main as each floor is not typical with respect to the others. Ceiling space is limited in most areas, but there are varying ceiling heights on the different floors and accessibility to existing ductwork and zone dampers can be especially challenging in some cases. Vertical duct risers could possibly remain intact without the need to access or remove them at all. This would definitely be a benefit to the feasibility of this option.

Option 2

In contrast to Option 1 as described above, this option seems to alleviate some of the problem of the impact presented by a half building shutdown. It is conceivable that the first steps to implementing this option would be to construct the new mechanical equipment rooms on the fourth floor across from the existing air handler rooms in preparation for serving the two southern building quadrants. Since the fourth floor is abandoned and unconditioned, there would be practically no impact on the existing building functions whatsoever while these units are placed in the ready position to be

integrated into the building HVAC system. Once they are ready to go, a brief coordinated shutdown of the existing air handler would allow the existing duct main to be decoupled, isolating the two respective building quadrants while the new air handler is placed online to serve the zones in its associated southern building quadrant. The existing air handler can be reconnected and placed back online to continue serving the remaining northern building quadrant until it is replaced. But much like the problem presented by Option 1, the northern quadrants will have to endure a prolonged shutdown while the existing air handlers are replaced. However, the overall building impact will be minimized since only one fourth of the building will be inconvenienced as it will only be serving that one northern quadrant by that time. One important hurdle whose significance should not be overlooked when considering this option is locating provisions for outdoor air intake to and relief air exhaust from the new air handling units. The existing units have convenient access to the northern (back) side of the building for this crucial function. The new units will need to find similar access for new louvered air plenums as the front side of the building will not be a desirable location to provide this. Implementing the remainder of the concept scheme follows very similarly to the installation of VAV zones on the individual floors, except each will be integrated into a single quadrant air system independent of the other quadrant. In the end, there will be closer control of a smaller air system with this concept with more flexibility between the four air systems serving all four quadrants of the building.

Option 3

As mentioned above, this option presents the most radical change of all when compared to the central air systems outlined in the other two options. However, in order to implement this option successfully a significant portion of the system needs to be installed ahead of time before bringing it online. Before any existing zones can be retrofitted with four-pipe fan coil units, the chilled and heating water risers will have to be put in place to distribute the hydronic services. While this presents a new set of piping networks including risers and lateral runs, it does not impact the functionality of the existing air systems in the mean time. Pipe risers can be located in convenient existing chase spaces emanating from the basement central plant and continuing up through the building with valved zone connections included for future connection to lateral branches when the zones are to be retrofitted. Each individual space within a particular zone can be planned for the installation of the console fan coil units needed to serve it and these can be installed at a time when this is most feasible. It is important to note that while disruption within the zone may be isolated to only one or two spaces at a time, there may be a wider impact to areas directly below in order to install lateral branch piping in the ceiling space of the floor below with rough-in connections up to the fan coil units on the floor above. This system can be implemented on a floor-by-floor basis within a particular quadrant and then that quadrant can be isolated from the air system serving that portion of the building. A significant hurdle associated with this option is how to provide ventilation air to the retrofitted zones before the entire half of the building is completed and the existing air handling units have not yet been replaced with new dedicated outdoor air energy recovery ventilators. A notable drawback to this system type is the introduction of several new individual equipment units that require periodic maintenance or are subject to require various repairs or replacement parts.

BUDGET/COST IMPLICATIONS

The limiting factor that carries the most significant impact on the implementation of any major HVAC upgrades that are to be carried out in the near future in Old Main is the availability of sufficient funding to cover the costs associated with completing the project. As it has been stated, it is understood that there will be a limitation of available funding in annual increments. Therefore, a challenge is presented of determining what the best and most logical recommendation is for spending the annual funding allotments in order to achieve the end goal of a completely renovated Old Main building HVAC system. The following breakdown presents a budget cost assumption for each of the options suggested in this study. It should be noted that due to the analytical nature of this study, which does not include detailed design efforts, there cannot be any strict reliance on these costs for anything other than an overall assumption of reasonable expectations of order-of-magnitude project costs.

Option 1 (Unit Prices)

HVAC Demolition, Existing Central Station AHU	\$5,000 (each)
HVAC Demolition, ductwork, dampers, air devices	\$22,500 (per quadrant)
(1) New 75-Ton/30,000 CFM Central Station Air Handling Unit, installed	\$105,000 (each)
(1) Single Duct VAV Terminal w/ HW Reheat, ductwork, diffusers installed	\$6,750 (each)
ATC tie-in to existing Automated Logic DDC backbone, per VAV terminal	\$1,200 (each)
Sheet Metal Ductwork (main), insulated, installed	\$50,000 (per quadrant)
Hydronic Piping (main), insulated, installed	\$37,500 (per quadrant)
Misc. Archit. Modifications (walls, ceilings, bulkheads, floors)	\$200,000 (allowance)

Option 2 (Unit Prices)

HVAC Demolition, Existing Central Station AHU	\$5,000 (each)
HVAC Demolition, ductwork, dampers, air devices	\$22,500 (per quadrant)
(1) New 38-Ton/15,000 CFM Central Station Air Handling Unit, installed	\$54,000 (each)
(1) Single Duct VAV Terminal w/ HW Reheat, ductwork, diffusers installed	\$6,750 (each)
ATC tie-in to existing Automated Logic DDC backbone, per VAV terminal	\$1,200 (each)
(1) Intake Air Plenum/(1) Exhaust Air Plenum	\$8,000 (pair)
Sheet Metal Ductwork (main), insulated, installed	\$50,000 (per quadrant)
Hydronic Piping (main), insulated, installed	\$37,500 (per quadrant)
Misc. Archit. Modifications (walls, ceilings, bulkheads, floors)	\$200,000 (allowance)

Option 3 (Unit Prices)

HVAC Demolition, Existing Central Station AHU	\$5,000 (each)
HVAC Demolition, ductwork, dampers, air devices	\$22,500 (per quadrant)
HVAC Demolition, HW piping and perimeter heat	\$7,600 (per quadrant)
(1) New 2,500 CFM Energy Recovery Ventilator w/ Total Wheel, Installed	\$38,600 (each)
(1) Fan Coil Unit, Console Type, 4-Pipe, installed	\$5,000 (each)
ATC tie-in to existing Automated Logic DDC backbone, per FCU	\$1,500 (each)
Hydronic Piping (main and branch), insulated, installed	\$103,000 (per quadrant)
Sheet Metal Ductwork (main, supply/exhaust), insulated, installed	\$39,600 (per quadrant)
Misc. Archit. Modifications (walls, ceilings, bulkheads, floors)	\$200,000 (allowance)

Option 1 (Convert NE quadrant including a new central AHU for East side)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$27,500
75-Ton AHU, East Wings	1	\$105,000
Single Duct VAV Terminals, NE Wing, 1 st – 4th Floors	43	\$290,250
ATC tie-in, VAV Terminals, NE Wing, 1 st – 4th Floors	43	\$51,600
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$761,850

Option 1 (Convert SE quadrant and tie into a new central AHU on East side)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$22,500
Single Duct VAV Terminals, SE Wing, 1 st – 4th Floors	42	\$283,500
ATC tie-in, VAV Terminals, SE Wing, 1 st – 4th Floors	42	\$50,400
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$643,900

Option 1 (Convert entire East side of building including both NE and SE Wings and a new central AHU)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$50,000
75-Ton AHU, East Wings	1	\$105,000
Single Duct VAV Terminals, NE/SE Wings, 1 st – 4th Floors	85	\$573,750
ATC tie-in, VAV Terminals, NE/SE Wings, 1 st – 4th Floors	85	\$102,000
Sheet Metal Ductwork	2	\$100,000
Hydronic Piping	2	\$75,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,405,750

Option 1 (Convert NW quadrant including a new central AHU for West side)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$27,500
75-Ton AHU, East Wings	1	\$105,000
Single Duct VAV Terminals, NW Wing, 1 st – 4th Floors	42	\$283,500
ATC tie-in, VAV Terminals, NW Wing, 1 st – 4th Floors	42	\$50,400
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$753,900

Option 1 (Convert SW quadrant and tie into a new central AHU on West side)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$22,500
Single Duct VAV Terminals, SW Wing, 1 st – 4th Floors	43	\$290,250
ATC tie-in, VAV Terminals, SW Wing, 1 st – 4th Floors	43	\$51,600
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$651,850

Option 1 (Convert entire West side of building including both NW and SW Wings & a new central AHU)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$50,000
75-Ton AHU, East Wings	1	\$105,000
Single Duct VAV Terminals, NW/SW Wings, 1 st – 4th Flrs	85	\$573,750
ATC tie-in, VAV Terminals, NW/SW Wings, 1 st – 4th Flrs	85	\$102,000
Sheet Metal Ductwork	2	\$100,000
Hydronic Piping	2	\$75,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,405,750

Option 2 (Convert NW quadrant including a new central AHU for NW quadrant)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$27,500
38-Ton AHU, NW Quadrant	1	\$54,000
Single Duct VAV Terminals, NW Wing, 1 st – 4th Floors	42	\$283,500
ATC tie-in, VAV Terminals, NW Wing, 1 st – 4th Floors	42	\$50,400
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$702,900

Option 2 (Convert NE quadrant including a new central AHU for NE quadrant)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$27,500
38-Ton AHU, NE Quadrant	1	\$54,000
Single Duct VAV Terminals, NE Wing, 1 st – 4th Floors	43	\$290,250
ATC tie-in, VAV Terminals, NE Wing, 1 st – 4th Floors	43	\$51,600
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$710,850

Option 2 (Convert entire North side of building including both NW and NE Wings & two new central AHUs)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$55,000
38-Ton AHU, East Wings	2	\$108,000
Single Duct VAV Terminals, NE/SE Wings, 1 st – 4th Floors	85	\$573,750
ATC tie-in, VAV Terminals, NE/SE Wings, 1 st – 4th Floors	85	\$102,000
Intake/Exhaust Plenums	1	\$8,000
Sheet Metal Ductwork	2	\$100,000
Hydronic Piping	2	\$75,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,421,750

Option 2 (Convert SW quadrant including a new central AHU for SW quadrant)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$22,500
38-Ton AHU, SW Quadrant	1	\$54,000
Single Duct VAV Terminals, SW Wing, 1 st – 4th Floors	43	\$290,250
ATC tie-in, VAV Terminals, SW Wing, 1 st – 4th Floors	43	\$51,600
Intake/Exhaust Plenums	1	\$8,000
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$682,050

Option 2 (Convert SE quadrant including a new central AHU for SE quadrant)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$22,500
38-Ton AHU, SE Quadrant	1	\$54,000
Single Duct VAV Terminals, SE Wing, 1 st – 4th Floors	42	\$283,500
ATC tie-in, VAV Terminals, SE Wing, 1 st – 4th Floors	42	\$50,400
Intake/Exhaust Plenums	1	\$8,000
Sheet Metal Ductwork	1	\$50,000
Hydronic Piping	1	\$37,500
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$705,900

Option 2 (Convert entire South side of bldg including both SW & SE Wings & two new central AHUs)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$45,000
38-Ton AHU, East Wings	2	\$108,000
Single Duct VAV Terminals, NW/SW Wings, 1 st – 4th Flrs	85	\$573,750
ATC tie-in, VAV Terminals, NW/SW Wings, 1 st – 4th Flrs	85	\$102,000
Intake/Exhaust Plenums	1	\$8,000
Sheet Metal Ductwork	2	\$100,000
Hydronic Piping	2	\$75,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,411,750

Option 3 (Convert NE Quadrant to FCUs NOT including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$30,100
4-Pipe FCU's, NE Wing, 1 st – 4th Floors	41	\$205,000
ATC tie-in, FCU's, NE Wing, 1 st – 4th Floors	41	\$61,500
Sheet Metal Ductwork	1	\$39,600
Hydronic Piping	1	\$103,000
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$639,200

Option 3 (Convert SE Quadrant to FCUs NOT including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$30,100
4-Pipe FCU's, SE Wing, 1 st – 4th Floors	52	\$260,000
ATC tie-in, FCU's, SE Wing, 1 st – 4th Floors	52	\$78,000
Sheet Metal Ductwork	1	\$39,600
Hydronic Piping	1	\$103,000
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$710,700

Option 3 (Convert NW Quadrant to FCUs NOT including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$30,100
4-Pipe FCU's, NW Wing, 1 st – 4th Floors	50	\$250,000
ATC tie-in, FCU's, NW Wing, 1 st – 4th Floors	50	\$75,000
Sheet Metal Ductwork	1	\$39,600
Hydronic Piping	1	\$103,000
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$697,700

Option 3 (Convert SW Quadrant to FCUs NOT including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$30,100
4-Pipe FCU's, SW Wing, 1 st – 4th Floors	48	\$240,000
ATC tie-in, FCU's, SW Wing, 1 st – 4th Floors	48	\$72,000
Sheet Metal Ductwork	1	\$39,600
Hydronic Piping	1	\$103,000
Misc. Archit. Mods.	1	\$200,000
TOTAL	-----	\$684,700

Option 3 (Convert entire East side of building to FCUs including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$35,100
2,500 CFM ERV, East Wings	1	\$38,600
4-Pipe FCU's, NE/SE Wings, 1 st – 4th Floors	93	\$465,000
ATC tie-in, FCU's, NE/SE Wings, 1 st – 4th Floors	93	\$139,500
Sheet Metal Ductwork	2	\$79,200
Hydronic Piping	2	\$206,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,363,400

Option 3 (Convert entire West side of building to FCUs including a new Energy Recovery Ventilator)

ITEM	QUANTITY	TOTAL ASSUMED COST
HVAC Demolition		\$35,100
2,500 CFM ERV, West Wings	1	\$38,600
4-Pipe FCU's, NW/SW Wings, 1 st – 4th Floors	98	\$490,000
ATC tie-in, FCU's, NW/SW Wings, 1 st – 4th Floors	98	\$147,000
Sheet Metal Ductwork	2	\$79,200
Hydronic Piping	2	\$206,000
Misc. Archit. Mods.	2	\$400,000
TOTAL	-----	\$1,395,900

CONCLUSION

Three options for upgrading the existing HVAC systems serving Old Main have been offered here all of which include the use of a combined chilled and heating water hydronic system in keeping with the University's master plan for a campus utility plant. The first option suggests merely a replacement of the two existing four-pipe air handlers, while converting the conditioned spaces to a variable volume air system retrofitting the existing pneumatically operated dampers with single duct terminal units with hydronic heating coils. While providing an upgrade to the existing system components, this option limits the flexibility and diversity of system operation and does not optimize energy efficiency performance. Another option suggests the most radical change away from the existing design by eliminating the notion of a central air system with each space within the building conditioning zones being provided with four-pipe fan coil units. Providing a larger degree of individual control increases the flexibility of the system, but an increase in the number of equipment units will result in an increase maintenance burden in order to keep all of these units operating properly. However, it appears that the option that presents the most practical choice, offering more flexibility and ease of implementation, is the second featured alternative which suggests dividing Old Main into four separate variable air volume systems each with a four-pipe air handling unit and VAV air terminals. Any option that is chosen will require significant coordination of the multiple phases of implementation, but it appears as though splitting the building into quadrant systems allows the easiest to control for the use of incremental annual funding sources.

APPENDICES



Appendix A

Option 2 VAV Zoning Plans

↑ CARD READER LOCATION
 K\$ KEYED SWITCH ENTRY
 ADA ENTRANCE
 1208 = ROOM NUMBER
 488 = AREA / ROOM SQFT
 FLOOR PLAN UPDATED LAST:
 3/5/07
 TOTAL GROSS SQFT =
 113,853 SQFT




	CARD READER LOCATION
	K\$ KEYED SWITCH ENTRY
	ADA ENTRANCE
120B	= ROOM NUMBER
488	= AREA / ROOM SQFT
FLOOR PLAN UPDATED LAST:	3/5/07
TOTAL GROSS SQFT =	113,653 SQFT



OPTION 2: VAV ZONING (31 zones)

NW Quadrant: 6 zones
NE Quadrant: 5 zones
SW Quadrant: 8 zones
SE Quadrant: 6 zones
N/Central: 6 zones

= THERMOSTAT




↑ CARD READER LOCATION
 K\$ KEYED SWITCH ENTRY
 ADA ENTRANCE
 120B = ROOM NUMBER
 488 = AREA / ROOM SQFT
 FLOOR PLAN UPDATED LAST:
 3/5/07
 TOTAL GROSS SQFT =
 113,653 SQFT



OPTION 2: VAV ZONING (35 zones)

NW Quadrant: 7 zones
NE Quadrant: 6 zones
SW Quadrant: 8 zones
SE Quadrant: 8 zones
N/Central: 6 zones

T = THERMOSTAT



OLD MAIN
THIRD FLOOR PLAN
NO SCALE B-1-2-3-4
6' 8" 10' 12' 20' 25'

	CARD READER LOCATION
	KEYED SWITCH ENTRY
	ADA ENTRANCE
120B	ROOM NUMBER

488 = AREA / ROOM SOFT

FLOOR PLAN UPDATED LAST:
3/5/07

TOTAL GROSS SOFT =
113,453 SOFT



N/CENTRAL

OPTION 2: VAV ZONING (35 zones)

NW Quadrant: 5 zones

NE Quadrant: 5 zones


SW Quadrant: 6 zones

SE Quadrant: 6 zones

N/Central: 13 zones

[T] = THERMOSTAT

NW QUADRANT



**OLD MAIN
FOURTH FLOOR PLAN**

NO SCALE B-1-2-3-4
6' 8' 10' 12' 20' 25'

Appendix B

Block Load Data

Appendix B-1

Building Envelope Input Data

Design Weather Parameters & MSHGs

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:14PM

Design Parameters:

City Name	Harrisburg
Location	Pennsylvania
Latitude	40.2 Deg.
Longitude	76.8 Deg.
Elevation	308.0 ft
Summer Design Dry-Bulb	92.0 °F
Summer Coincident Wet-Bulb	74.0 °F
Summer Daily Range	18.8 °F
Winter Design Dry-Bulb	9.0 °F
Winter Design Wet-Bulb	6.7 °F
Atmospheric Clearness Number	1.00
Average Ground Reflectance	0.20
Soil Conductivity	0.800 BTU/(hr-ft-°F)
Local Time Zone (GMT +/- N hours)	5.0 hours
Consider Daylight Savings Time	No
Simulation Weather Data	Harrisburg (TM2)
Current Data is	2001 ASHRAE Handbook
Design Cooling Months	January to December

Design Day Maximum Solar Heat Gains

(The MSHG values are expressed in BTU/(hr-ft²))

Month	N	NNE	NE	ENE	E	ESE	SE	SSE	S
January	19.4	19.4	19.4	78.7	151.1	207.4	239.5	250.5	253.8
February	23.9	23.9	46.3	129.3	187.0	232.8	247.3	245.1	241.0
March	28.7	28.7	100.5	164.6	218.0	237.7	237.0	218.0	206.3
April	33.5	67.6	140.8	193.8	219.0	225.4	202.2	171.5	153.5
May	36.9	102.9	162.3	206.1	219.0	207.9	172.4	133.1	112.0
June	46.1	113.6	170.0	207.9	214.8	198.8	159.3	116.6	95.5
July	37.9	99.1	162.1	201.9	212.2	203.8	169.6	129.9	109.6
August	35.3	64.8	137.4	185.6	213.2	217.2	195.9	165.9	148.8
September	29.7	29.7	94.9	154.1	204.9	228.6	226.8	210.7	198.5
October	24.6	24.6	51.3	116.9	184.0	221.6	241.2	238.7	232.8
November	19.6	19.6	19.6	81.2	145.5	202.8	234.9	248.7	248.6
December	17.4	17.4	17.4	61.4	132.3	192.5	229.6	246.2	251.2
Month	SSW	SW	WSW	W	WNW	NW	NNW	HOR	Mult
January	253.0	240.9	202.9	152.6	79.0	19.4	19.4	131.4	1.00
February	245.3	248.3	233.6	188.9	125.5	52.4	23.9	178.7	1.00
March	216.5	233.4	240.2	212.6	169.5	98.0	28.7	221.3	1.00
April	170.5	200.6	224.5	221.3	194.5	137.9	71.6	249.7	1.00
May	132.4	173.3	207.0	220.3	205.6	160.2	103.9	263.3	1.00
June	114.9	160.7	196.4	216.9	206.2	168.7	115.4	266.3	1.00
July	128.2	170.0	200.8	216.4	200.7	159.1	103.7	261.0	1.00
August	164.5	193.9	216.4	213.6	187.8	133.9	70.8	245.6	1.00
September	210.7	227.0	228.4	205.2	153.4	95.0	29.7	212.3	1.00
October	238.5	240.4	221.8	182.6	122.8	44.6	24.6	174.7	1.00
November	247.4	232.8	204.1	144.5	81.1	19.6	19.6	129.7	1.00
December	248.3	227.0	192.9	127.6	64.2	17.4	17.4	110.1	1.00

Mult. = User-defined solar multiplier factor.

Wall Constructions

Exterior Wall Assembly

Wall Details

Outside Surface Color Medium
Absorptivity 0.675
Overall U-Value 0.248 BTU/(hr-ft²-°F)

Wall Layers Details (Inside to Outside)

Layers	Thickness in	Density lb/ft ³	Specific Ht. BTU / (lb - °F)	R-Value (hr-ft ² -°F)/BTU	Weight lb/ft ²
Inside surface resistance	0.000	0.0	0.00	0.68500	0.0
Gypsum board	0.625	50.0	0.26	0.56000	2.6
Air space	0.000	0.0	0.00	0.91000	0.0
8-in HW concrete block	8.000	61.0	0.20	1.11111	40.7
Face brick	4.000	125.0	0.22	0.43300	41.7
Outside surface resistance	0.000	0.0	0.00	0.33300	0.0
Totals	12.625	-		4.03211	84.9

Window Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W1

Window Details:

Detailed Input Yes
Height 5.75 ft
Width 3.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W10

Window Details:

Detailed Input Yes
Height 9.75 ft
Width 1.33 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W11

Window Details:

Detailed Input Yes
Height 7.75 ft
Width 2.67 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W12

Window Details:

Detailed Input Yes
 Height 10.00 ft
 Width 2.33 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W13

Window Details:

Detailed Input Yes
 Height 9.00 ft
 Width 12.00 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W14

Window Details:

Detailed Input Yes
 Height 8.00 ft
 Width 4.67 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

W15

Window Details:

Detailed Input Yes
 Height 8.25 ft
 Width 4.67 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W16

Window Details:

Detailed Input Yes
 Height 16.28 ft
 Width 5.33 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W17

Window Details:

Detailed Input Yes
 Height 18.00 ft
 Width 5.33 ft
 Frame Type Wood
 Internal Shade Type None
 Overall U-Value 0.982 BTU/(hr-ft²-°F)
 Overall Shade Coefficient 0.688

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" gray tint	0.631	0.065	0.304
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W18

Window Details:

Detailed Input Yes
Height 27.00 ft
Width 5.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.688

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" gray tint	0.631	0.065	0.304
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W19

Window Details:

Detailed Input Yes
Height 8.00 ft
Width 4.67 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W2

Window Details:

Detailed Input Yes
Height 10.75 ft
Width 4.75 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W20

Window Details:

Detailed Input Yes
Height 5.00 ft
Width 2.33 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W21

Window Details:

Detailed Input Yes
Height 10.75 ft
Width 4.33 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W22

Window Details:

Detailed Input Yes
Height 6.75 ft
Width 3.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W23

Window Details:

Detailed Input Yes
Height 34.50 ft
Width 5.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W3

Window Details:

Detailed Input Yes
Height 8.10 ft
Width 6.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W4

Window Details:

Detailed Input Yes
Height 9.75 ft
Width 4.25 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

W5

Window Details:

Detailed Input Yes
Height 7.25 ft
Width 4.25 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W6

Window Details:

Detailed Input Yes
Height 7.50 ft
Width 4.75 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W7

Window Details:

Detailed Input Yes
Height 7.50 ft
Width 6.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Window Constructions

W8

Window Details:

Detailed Input Yes
Height 6.25 ft
Width 4.00 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

W9

Window Details:

Detailed Input Yes
Height 6.25 ft
Width 1.33 ft
Frame Type Wood
Internal Shade Type None
Overall U-Value 0.982 BTU/(hr-ft²-°F)
Overall Shade Coefficient 0.831

Glass Details:

Gap Type 1/4" Air Space

Glazing	Glass Type	Transmissivity	Reflectivity	Absorptivity
Outer Glazing	1/8" clear	0.841	0.078	0.081
Glazing #2	not used	1.000	0.000	0.000
Glazing #3	not used	1.000	0.000	0.000

Door Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:32PM

Wood Door

Door Details:

Gross Area 21.0 ft²
Door U-Value 0.300 BTU/(hr-ft²-°F)

Glass Details:

Glass Area 0.0 ft²
Glass U-Value 0.580 BTU/(hr-ft²-°F)
Glass Shade Coefficient 0.880
Glass Shaded All Day? No

External Shade Geometries

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

South Balcony

Reveal Depth 0.0 in

Overhang:

Projection from surface	96.0 in
Height above window	12.0 in
Ext. past RH side of window	0.0 in
Ext. past LH side of window	0.0 in

Left Fin:

Projection from surface	0.0 in
Height above window	0.0 in
Dist. from edge of window	0.0 in

Right Fin:

Projection from surface	0.0 in
Height above window	0.0 in
Dist. from edge of window	0.0 in

Roof Constructions

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:31PM

Slate + Wood Deck

Roof Details

Outside Surface Color Dark
Absorptivity 0.900
Overall U-Value 0.044 BTU/(hr-ft²-°F)

Roof Layers Details (Inside to Outside)

Layers	Thickness In	Density lb/ft ³	Specific Ht. BTU / (lb - °F)	R-Value (hr-ft ² -°F)/BTU	Weight lb/ft ²
Inside surface resistance	0.000	0.0	0.00	0.68500	0.0
1/2-in gypsum board	0.500	50.0	0.26	0.44803	2.1
R-19 batt insulation	6.000	0.5	0.20	19.23077	0.3
Air space	0.000	0.0	0.00	0.91000	0.0
3/4-in wood board	0.750	34.0	0.29	0.93284	2.1
Slate	0.500	270.0	0.30	0.05002	11.3
Outside surface resistance	0.000	0.0	0.00	0.33300	0.0
Totals	7.750	-		22.58965	15.7

Appendix B-2

Space Input Data

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-E. Toilet/Stair 3

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	247.0	2	0	2

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W5
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-Lounge/Corridor

1. General Details:

Floor Area 905.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults **ASHRAE Std 62.1-2007**

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	431.0	5	0	0

3.1. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**
1st Window Type **W5**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-Main Corr/Lobby

1. General Details:

Floor Area 2255.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

(No Wall, Window, Door data).

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NE Corridor

1. General Details:

Floor Area 335.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	78.0	0	0	2

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NE Wing 1

1. General Details:

Floor Area 630.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft³

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W5

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NE Wing 2

1. General Details:

Floor Area 865.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	320.0	3	1	0
N	150.0	2	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5
2nd Window Type W13

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NE Wing

1. General Details:

Floor Area 610.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NW Corridor

1. General Details:

Floor Area 335.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	78.0	0	0	1

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
Door Type **Wood Door**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipJ. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NW Wing 1

1. General Details:

Floor Area 730.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	430.0	6	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NW Wing 2

1. General Details:

Floor Area 715.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	320.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W5

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NW Wing 3

1. General Details:

Floor Area 665.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-NW Wing 4

1. General Details:

Floor Area 1230.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	290.0	3	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SE Corridor

1. General Details:

Floor Area 350.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	78.0	2	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W14

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SE Wing 1

1. General Details:

Floor Area 850.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	520.0	6	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W5

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SE Wing 2

1. General Details:

Floor Area 850.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	2	1	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5
2nd Window Type W13

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SE Wing 3

1. General Details:

Floor Area 835.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	6	0	1

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W5
1st Window Shade Type South Balcony
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-Stair 2

1. General Details:

Floor Area 270.0 ft²
Avg. Ceiling Height 13.6 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	152.0	0	0	0
S	162.0	0	0	2
E	152.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
Door Type Wood Door

3.3. Construction Types for Exposure E

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SW Corridor

1. General Details:

Floor Area 310.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	78.0	2	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W9

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SW Wing 1

1. General Details:

Floor Area 630.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	5	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SW Wing 2

1. General Details:

Floor Area 850.0 ft²
 Avg. Ceiling Height 10.0 ft
 Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
 OA Requirement 1 5.0 CFM/person
 OA Requirement 2 0.06 CFM/ft²
 Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
 Wattage 1.00 W/ft²
 Ballast Multiplier 1.00
 Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
 Activity Level Office Work
 Sensible 245.0 BTU/hr/person
 Latent 205.0 BTU/hr/person
 Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
 Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
 Schedule None
 Latent 0 BTU/hr
 Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
 Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	3	0	1
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
 1st Window Type W5
 Door Type Wood Door

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
 1st Window Type W5

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
 Design Heating 1.25 ACH
 Energy Analysis 0.00 CFM
 Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
 (No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-SW Wing 3

1. General Details:

Floor Area 850.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	5	0	1

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W5
1st Window Shade Type South Balcony
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

1-W. Toilet/Vest/Stair1

1. General Details:

Floor Area 680.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	247.0	2	1	2

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W5
2nd Window Type W6
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-Chap. Platform/Storage

1. General Details:

Floor Area 2385.0 ft²
Avg. Ceiling Height 30.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage PUBLIC ASSEMBLY: Auditorium
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	720.0	1	1	0
E	1560.0	3	0	0
N	720.0	2	2	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W18
2nd Window Type W17

3.2. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W17

3.3. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W17
2nd Window Type W20

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	1192.5	45	0
W	1192.5	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

4.2. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-Chapel Assembly

1. General Details:

Floor Area 3170.0 ft²
Avg. Ceiling Height 30.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage PUBLIC ASSEMBLY: Auditorium
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	1590.0	6	0	0
E	1590.0	6	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W18

3.2. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W18

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 10.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-E. Toilet/Stair 3

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 13.6 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	247.0	2	1	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W4
2nd Window Type W2

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-Main Corr/Lobby

1. General Details:

Floor Area 2360.0 ft²
Avg. Ceiling Height 13.6 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

(No Wall, Window, Door data).

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NE Corridor

1. General Details:

Floor Area 335.0 ft²
Avg. Ceiling Height 13.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	110.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
1st Window Type W16

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NE Wing 1

1. General Details:

Floor Area 645.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00	ft ² /person
Activity Level Office Work	
Sensible 245.0	BTU/hr/person
Latent 205.0	BTU/hr/person
Schedule 100% Load 24-7	

2.5. Miscellaneous Loads:

Sensible 0	BTU/hr
Schedule None	
Latent 0	BTU/hr
Schedule None	

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NE Wing 2

1. General Details:

Floor Area 730.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	350.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NE Wing 3

1. General Details:

Floor Area 685.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NW Corridor

1. General Details:

Floor Area 350.0 ft²
Avg. Ceiling Height 13.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	110.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
1st Window Type W16

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NW Wing 1

1. General Details:

Floor Area 685.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	430.0	6	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NW Wing 2

1. General Details:

Floor Area 900.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	320.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-NW Wing 3

1. General Details:

Floor Area 645.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SE Corridor

1. General Details:

Floor Area 430.0 ft²
Avg. Ceiling Height 13.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	110.0	2	0	0

3.1. Construction Types for Exposure S

Wall Type **Exterior Wall Assembly**
1st Window Type W10

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SE Wing 1

1. General Details:

Floor Area 900.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	520.0	6	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SE Wing 2

1. General Details:

Floor Area 800.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	4	0	1
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W4
Door Type Wood Door

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SE Wing 3

1. General Details:

Floor Area 850.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	5	0	1

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4
1st Window Shade Type South Balcony
Door Type Wood Door

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-Stair 2

1. General Details:

Floor Area 270.0 ft²
Avg. Ceiling Height 13.6 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	152.0	0	0	0
S	162.0	1	0	0
E	152.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W3

3.3. Construction Types for Exposure E

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SW Corridor

1. General Details:

Floor Area 335.0 ft²
Avg. Ceiling Height 13.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	110.0	2	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W10

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SW Wing 1

1. General Details:

Floor Area 575.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	5	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W4

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SW Wing 2

1. General Details:

Floor Area 845.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	3	0	1
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W4
Door Type Wood Door

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-SW Wing 3

1. General Details:

Floor Area 865.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	6	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W4
1st Window Shade Type South Balcony

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

2-W. Toilet/Stair 1

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 13.6 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	247.0	2	1	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W4
2nd Window Type W2

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-Balcony

1. General Details:

Floor Area 700.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage PUBLIC ASSEMBLY: Auditorium
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

(No Wall, Window, Door data).

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 50.0 People
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-E. Toilet/Stair 3

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule **None**

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule **None**

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule **None**
Latent 0 BTU/hr
Schedule **None**

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule **None**

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	247.0	2	1	0

3.1. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**
1st Window Type W8
2nd Window Type W2

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-Main Corr/Lobby

1. General Details:

Floor Area 2435.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	88.5	1	0	0

3.1. Construction Types for Exposure W

Wall Type **Exterior Wall Assembly**
1st Window Type W7

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NE Corridor

1. General Details:

Floor Area 305.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule **None**

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule **None**

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule **None**
Latent 0 BTU/hr
Schedule **None**

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule **None**

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	78.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
1st Window Type **W9**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NE Wing 1

1. General Details:

Floor Area 610.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NE Wing 2

1. General Details:

Floor Area 730.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NE Wing 3

1. General Details:

Floor Area 645.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NW Corridor

1. General Details:

Floor Area 345.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	78.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W15

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NW Wing 1

1. General Details:

Floor Area 750.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	430.0	6	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NW Wing 2

1. General Details:

Floor Area 750.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	330.0	5	0	0
N	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-NW Wing 3

1. General Details:

Floor Area 650.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	360.0	5	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SE Corridor

1. General Details:

Floor Area 375.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	78.0	1	0	0

3.1. Construction Types for Exposure S

Wall Type **Exterior Wall Assembly**
1st Window Type **W9**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SE Wing 1

1. General Details:

Floor Area 920.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	520.0	6	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SE Wing 2

1. General Details:

Floor Area 920.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SE Wing 3

1. General Details:

Floor Area 850.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	6	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-Stair 2

1. General Details:

Floor Area 270.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	152.0	0	0	0
S	162.0	2	0	0
E	152.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type **Exterior Wall Assembly**

3.2. Construction Types for Exposure S

Wall Type **Exterior Wall Assembly**
1st Window Type W11

3.3. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SW Corridor

1. General Details:

Floor Area 345.0 ft²
Avg. Ceiling Height 9.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	78.0	1	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W9

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SW Wing 1

1. General Details:

Floor Area 595.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	360.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SW Wing 2

1. General Details:

Floor Area 595.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	360.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W8

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-SW Wing 3

1. General Details:

Floor Area 1120.0 ft²
Avg. Ceiling Height 10.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	490.0	6	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W8

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU, Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

3-W. Toilet/Stair 1

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	247.0	2	1	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W8
2nd Window Type W2

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-E. Toilet/Stair 3

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	247.0	2	1	0

3.1. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**
1st Window Type W1
2nd Window Type W2

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	500.0	45	0

4.1. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-Main Corr/Lobby

1. General Details:

Floor Area 2070.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	85.5	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W3

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
N	1035.0	45	0
S	1035.0	45	0

4.1. Construction Types for Exposure N

Roof Type Slate + Wood Deck

4.2. Construction Types for Exposure S

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-N Corridor

1. General Details:

Floor Area 970.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	66.5	0	0	1
E	66.5	1	0	0

3.1. Construction Types for Exposure W

Wall Type **Exterior Wall Assembly**
Door Type Wood Door

3.2. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	485.0	45	0
W	485.0	45	0

4.1. Construction Types for Exposure E

Roof Type **Slate + Wood Deck**

4.2. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

7.1. 1st Partition Details:

Partition Type **Wall Partition**
Area 418.0 ft²

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

U-Value 0.500 BTU/(hr-ft²-°F)
Uncondit. Space Max Temp 95.0 °F
Ambient at Space Max Temp 115.0 °F

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

Uncondit. Space Min Temp 10.0 °F
Ambient at Space Min Temp 35.0 °F

7.2. 2nd Partition Details:
(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-N Wing 1

1. General Details:

Floor Area 1055.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	484.0	5	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	1055.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-N Wing 2

1. General Details:

Floor Area 1055.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	484.0	5	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	1055.0	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NE Corridor

1. General Details:

Floor Area 440.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	76.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
1st Window Type W3

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	220.0	45	0
W	220.0	45	0

4.1. Construction Types for Exposure E

Roof Type **Slate + Wood Deck**

4.2. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NE Wing 1

1. General Details:

Floor Area 630.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	325.0	4	0	0
N	150.0	0	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	630.0	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NE Wing 2

1. General Details:

Floor Area 645.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	334.0	4	0	0
N	150.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	645.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NW Corridor

1. General Details:

Floor Area 440.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	76.0	1	0	0

3.1. Construction Types for Exposure N

Wall Type **Exterior Wall Assembly**
1st Window Type W3

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	220.0	45	0
W	220.0	45	0

4.1. Construction Types for Exposure E

Roof Type **Slate + Wood Deck**

4.2. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NW Wing 1

1. General Details:

Floor Area 750.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	380.0	5	0	0
N	150.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	750.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-NW Wing 2

1. General Details:

Floor Area 750.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	300.0	4	0	0
N	150.0	0	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure N

Wall Type Exterior Wall Assembly

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	750.0	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SE Corridor

1. General Details:

Floor Area 440.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	76.0	1	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W3

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	220.0	45	0
W	220.0	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

4.2. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SE Wing 1

1. General Details:

Floor Area 920.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
E	475.0	6	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	920.0	45	0

4.1. Construction Types for Exposure E

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SE Wing 2

1. General Details:

Floor Area 665.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	308.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	665.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SE Wing 3

1. General Details:

Floor Area 1105.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	449.0	6	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
S	1105.0	45	0

4.1. Construction Types for Exposure S

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-Stair 2

1. General Details:

Floor Area 270.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type **Free Hanging**
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	152.0	0	0	0
S	162.0	2	0	0
E	152.0	0	0	0

3.1. Construction Types for Exposure W

Wall Type **Exterior Wall Assembly**

3.2. Construction Types for Exposure S

Wall Type **Exterior Wall Assembly**
1st Window Type W12

3.3. Construction Types for Exposure E

Wall Type **Exterior Wall Assembly**

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

2.4. People:

Occupancy 0.0 Person
Activity Level **Office Work**
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SW Corridor

1. General Details:

Floor Area 440.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage **GENERAL: Corridor**
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	76.0	1	0	0

3.1. Construction Types for Exposure S

Wall Type **Exterior Wall Assembly**
1st Window Type W3

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
E	220.0	45	0
W	220.0	45	0

4.1. Construction Types for Exposure E

Roof Type **Slate + Wood Deck**

4.2. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SW Wing 1

1. General Details:

Floor Area 595.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	308.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	595.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SW Wing 2

1. General Details:

Floor Area 695.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	308.0	4	0	0
S	150.0	1	0	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	695.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-SW Wing 3

1. General Details:

Floor Area 1065.0 ft²
Avg. Ceiling Height 8.8 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 200.00 ft²/person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
S	431.0	6	0	0

3.1. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W1

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
S	1065.0	45	0

4.1. Construction Types for Exposure S

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4-W. Toilet/Stair 1

1. General Details:

Floor Area 500.0 ft²
Avg. Ceiling Height 9.5 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage GENERAL: Corridor
OA Requirement 1 0.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
Wattage 0.75 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.4. People:

Occupancy 0.0 Person
Activity Level Office Work
Sensible 245.0 BTU/hr/person
Latent 205.0 BTU/hr/person
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 BTU/hr
Schedule None
Latent 0 BTU/hr
Schedule None

2.3. Electrical Equipment:

Wattage 0.00 W/ft²
Schedule None

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
W	247.0	2	1	0

3.1. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W1
2nd Window Type W2

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
W	500.0	45	0

4.1. Construction Types for Exposure W

Roof Type Slate + Wood Deck

5. Infiltration:

Design Cooling 0.50 ACH
Design Heating 1.25 ACH
Energy Analysis 0.00 CFM
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

Inst. Research Bldg.

1. General Details:

Floor Area 2045.0 ft²
Avg. Ceiling Height 9.0 ft
Building Weight 100.0 lb/ft²

1.1. OA Ventilation Requirements:

Space Usage OFFICE: Office space
OA Requirement 1 5.0 CFM/person
OA Requirement 2 0.06 CFM/ft²
Space Usage Defaults ASHRAE Std 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Recessed (Unvented)
Wattage 1.00 W/ft²
Ballast Multiplier 1.00
Schedule 100% Load 24-7

2.2. Task Lighting:

Wattage 0.00 W/ft²
Schedule None

2.3. Electrical Equipment:

Wattage 1.50 W/ft²
Schedule 100% Load 24-7

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (ft ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	300.0	2	0	2
S	300.0	2	1	0
E	570.0	3	0	2
W	340.0	2	0	0

3.1. Construction Types for Exposure N

Wall Type Exterior Wall Assembly
1st Window Type W6
Door Type Wood Door

3.2. Construction Types for Exposure S

Wall Type Exterior Wall Assembly
1st Window Type W14
2nd Window Type W1

3.3. Construction Types for Exposure E

Wall Type Exterior Wall Assembly
1st Window Type W14
Door Type Wood Door

3.4. Construction Types for Exposure W

Wall Type Exterior Wall Assembly
1st Window Type W14

4. Roofs, Skylights:

Exp.	Roof Gross Area (ft ²)	Roof Slope (deg.)	Skylight Qty.
N	510.0	20	0
S	510.0	20	0
E	510.0	20	0
W	510.0	20	0

4.1. Construction Types for Exposure N

Roof Type Slate + Wood Deck

Space Input Data

ShipU. Old Main HVAC Study
Century Engineering

12/06/2011
01:16PM

4.2. Construction Types for Exposure S

Roof Type **Slate + Wood Deck**

4.3. Construction Types for Exposure E

Roof Type **Slate + Wood Deck**

4.4. Construction Types for Exposure W

Roof Type **Slate + Wood Deck**

5. Infiltration:

Design Cooling **0.50 ACH**

Design Heating **1.25 ACH**

Energy Analysis **0.00 CFM**

Infiltration occurs at all hours.

6. Floors:

Type **Floor Above Conditioned Space**

(No additional input required for this floor type).

7. Partitions:

(No partition data).

Appendix B-3

Air System Input Data

1st Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name 1st Floor
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 5

2. System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
 Ventilation Sizing Method Sum of Space OA Airflows
 Unocc. Damper Position Closed
 Damper Leak Rate 0 %
 Outdoor Air CO2 Level 400 ppm

Economizer Data:

Control Non-integrated dry-bulb control
 Upper Cutoff 55.0 °F
 Lower Cutoff 50.0 °F

Preheat Coil Data:

Setpoint 60.0 °F
 Heating Source Hot Water
 Schedule JFMAMJJASOND
 Coil position Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature 55.0 °F
 Coil Bypass Factor 0.100
 Cooling Source Chilled Water
 Schedule JFMAMJJASOND
 Capacity Control Constant Temperature - Fan On

Supply Fan Data:

Fan Type BI/AF with Variable Frequency Drive
 Configuration Draw-thru
 Fan Performance 3.00 in wg
 Overall Efficiency 43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain 0 %
 Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

Return Fan Data:

Fan Type Forward Curved with Variable Frequency Drive
 Fan Performance 2.00 in wg
 Overall Efficiency 48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
----------------	--

1st Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1-Main Corr/Lobby	x1
1-Lounge/Corridor	x1
1-Stair 2	x1
1-W. Toilet/Vest/Stair1	x1
1-E. Toilet/Stair 3	x1
Zone 2: Zone 2	
1-NW Corridor	x1
1-NW Wing 1	x1
1-NW Wing 2	x1
1-NW Wing 3	x1
1-NW Wing 4	x1
Zone 3: Zone 3	
1-SW Corridor	x1
1-SW Wing 1	x1
1-SW Wing 2	x1
1-SW Wing 3	x1
Zone 4: Zone 4	
1-NE Corridor	x1
1-NE Wing 1	x1
1-NE Wing 2	x1
1-NE Wing 3	x1
Zone 5: Zone 5	
1-SE Corridor	x1
1-SE Wing 1	x1
1-SE Wing 2	x1
1-SE Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occupied	75.0 °F
Cooling T-stat: Unoccupied	85.0 °F
Heating T-stat: Occupied	70.0 °F
Heating T-stat: Unoccupied	60.0 °F
T-stat Throttling Range	0.10 %
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule	100% Occupied 24-7
Unoccupied Cooling is	Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	15504.7 CFM
Ventilation Airflow	1232.8 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

1st Floor Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Cooling Sensible 0 %
Cooling Latent 0 %
Heating 0 %

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-
1	2136.8	-	111.9	-
2	3900.5	-	130.7	-
3	2997.8	-	100.6	-
4	2935.0	-	100.3	-
5	3735.9	-	119.8	-

5. Equipment Data

No Equipment Data required for this system.

2nd Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name 2nd Floor
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 5

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
2-Main Corr/Lobby	x1

2nd Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

2-Stair 2	x1
2-W. Toilet/Stair 1	x1
2-E. Toilet/Stair 3	x1
Zone 2: Zone 2	
2-NW Corridor	x1
2-NW Wing 1	x1
2-NW Wing 2	x1
2-NW Wing 3	x1
Zone 3: Zone 3	
2-SW Corridor	x1
2-SW Wing 1	x1
2-SW Wing 2	x1
2-SW Wing 3	x1
Zone 4: Zone 4	
2-NE Corridor	x1
2-NE Wing 1	x1
2-NE Wing 2	x1
2-NE Wing 3	x1
Zone 5: Zone 5	
2-SE Corridor	x1
2-SE Wing 1	x1
2-SE Wing 2	x1
2-SE Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occupied	75.0 °F
Cooling T-stat: Unoccupied	85.0 °F
Heating T-stat: Occupied	70.0 °F
Heating T-stat: Unoccupied	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule	100% Occupied 24-7
Unoccupied Cooling is	Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air

Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None

Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	16144.5 CFM
Ventilation Airflow	1080.4 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

2nd Floor Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-	-
1	2002.6	-	108.5	-	-
2	3549.0	-	119.8	-	-
3	3657.7	-	116.2	-	-
4	3301.7	-	113.2	-	-
5	3903.3	-	127.4	-	-

5. Equipment Data

No Equipment Data required for this system.

3rd Floor Input Data

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name 3rd Floor
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 5

2. System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
 Ventilation Sizing Method Sum of Space OA Airflows
 Unocc. Damper Position Closed
 Damper Leak Rate 0 %
 Outdoor Air CO2 Level 400 ppm

Economizer Data:

Control Non-integrated dry-bulb control
 Upper Cutoff 55.0 °F
 Lower Cutoff 50.0 °F

Preheat Coil Data:

Setpoint 60.0 °F
 Heating Source Hot Water
 Schedule JFMAMJJASOND
 Coil position Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature 55.0 °F
 Coil Bypass Factor 0.100
 Cooling Source Chilled Water
 Schedule JFMAMJJASOND
 Capacity Control Constant Temperature - Fan On

Supply Fan Data:

Fan Type BI/AF with Variable Frequency Drive
 Configuration Draw-thru
 Fan Performance 3.00 in wg
 Overall Efficiency 43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain 0 %
 Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

Return Fan Data:

Fan Type Forward Curved with Variable Frequency Drive
 Fan Performance 2.00 in wg
 Overall Efficiency 48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
3-Main Corr/Lobby	x1

3rd Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

3-Stair 2	x1
3-W. Toilet/Stair 1	x1
3-E. Toilet/Stair 3	x1
Zone 2: Zone 2	
3-NW Corridor	x1
3-NW Wing 1	x1
3-NW Wing 2	x1
3-NW Wing 3	x1
Zone 3: Zone 3	
3-SW Corridor	x1
3-SW Wing 1	x1
3-SW Wing 2	x1
3-SW Wing 3	x1
Zone 4: Zone 4	
3-NE Corridor	x1
3-NE Wing 1	x1
3-NE Wing 2	x1
3-NE Wing 3	x1
Zone 5: Zone 5	
3-SE Corridor	x1
3-SE Wing 1	x1
3-SE Wing 2	x1
3-SE Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occupied	75.0 °F
Cooling T-stat: Unoccupied	85.0 °F
Heating T-stat: Occupied	70.0 °F
Heating T-stat: Unoccupied	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	12839.3 CFM
Ventilation Airflow	1081.0 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

3rd Floor Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-	-
1	1859.2	-	89.6	-	-
2	2655.2	-	95.3	-	-
3	2883.7	-	96.7	-	-
4	2416.3	-	87.9	-	-
5	3262.2	-	109.4	-	-

5. Equipment Data

No Equipment Data required for this system.

4th Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name 4th Floor
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 6

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-Main Corr/Lobby	x1

4th Floor Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-Stair 2	x1
4-W. Toilet/Stair 1	x1
4-E. Toilet/Stair 3	x1
Zone 2: Zone 2	
4-NW Corridor	x1
4-NW Wing 1	x1
4-NW Wing 2	x1
Zone 3: Zone 3	
4-N Corridor	x1
4-N Wing 1	x1
4-N Wing 2	x1
Zone 4: Zone 4	
4-NE Corridor	x1
4-NE Wing 1	x1
4-NE Wing 2	x1
Zone 5: Zone 5	
4-SW Corridor	x1
4-SW Wing 1	x1
4-SW Wing 2	x1
4-SW Wing 3	x1
Zone 6: Zone 6	
4-SE Corridor	x1
4-SE Wing 1	x1
4-SE Wing 2	x1
4-SE Wing 3	x1

Thermostats and Zone Data:

Zone All
 Cooling T-stat: Occupied 75.0 °F
 Cooling T-stat: Unoccupied 85.0 °F
 Heating T-stat: Occupied 70.0 °F
 Heating T-stat: Unoccupied 60.0 °F
 T-stat Throttling Range 0.10 °F
 Diversity Factor 100 %
 Direct Exhaust Airflow 0.0 CFM
 Direct Exhaust Fan kW 0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone All
 Terminal Type VAV box with RH
 Minimum Airflow 40 % of supply air

Reheat Coil Source Hot Water
 Reheat Coil Schedule JFMAMJJASOND

Zone Heating Units:

Zone All
 Zone Heating Unit Type None

Zone Unit Heat Source Hot Water
 Zone Heating Unit Schedule JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature 55.0 °F
 Supply Fan Airflow 14323.8 CFM
 Ventilation Airflow 1208.3 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T 12.0 °F
 Hot Water Delta-T 20.0 °F

Safety Factors:

Cooling Sensible 0 %

4th Floor Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Cooling Latent 0 %
Heating 0 %

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-	-
1	2087.9	-	92.5	-	-
2	1897.0	-	66.1	-	-
3	2450.0	-	99.5	-	-
4	1681.2	-	60.3	-	-
5	3081.8	-	97.2	-	-
6	3342.0	-	108.1	-	-

5. Equipment Data

No Equipment Data required for this system.

Chapel Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

1. General Details:

Air System Name Chapel
Equipment Type Chilled Water AHU
Air System Type Single Zone CAV
Number of zones 1

2. System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
Ventilation Sizing Method Sum of Space OA Airflows
Unocc. Damper Position Closed
Damper Leak Rate 0 %
Outdoor Air CO2 Level 400 ppm

Economizer Data:

Control Non-integrated dry-bulb control
Upper Cutoff 55.0 °F
Lower Cutoff 50.0 °F

Central Cooling Data:

Supply Air Temperature 55.0 °F
Coil Bypass Factor 0.100
Cooling Source Chilled Water
Schedule JFMAMJJASOND
Capacity Control Cycled or Staged Capacity - Fan On

Central Heating Data:

Supply Temperature 95.0 °F
Heating Source Hot Water
Schedule JFMAMJJASOND
Capacity Control Cycled or Staged Capacity - Fan On

Supply Fan Data:

Fan Type Backward Inclined or Airfoil (BI/AF)
Configuration Draw-thru
Fan Performance 2.00 in wg
Overall Efficiency 54 %

Duct System Data:

Supply Duct Data:

Duct Heat Gain 0 %
Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
2-Chapel Assembly	x1
2-Chap. Platform/Storage	x1

Thermostats and Zone Data:

Zone All
Cooling T-stat: Occupied 75.0 °F
Cooling T-stat: Unoccupied 85.0 °F
Heating T-stat: Occupied 70.0 °F
Heating T-stat: Unoccupied 60.0 °F
T-stat Throttling Range 0.10 °F
Diversity Factor 100 %
Direct Exhaust Airflow 0.0 CFM
Direct Exhaust Fan kW 0.0 kW

Thermostat Schedule 100% Occupied 24-7
Unoccupied Cooling is Available

Supply Terminals Data:

Zone All
Terminal Type Diffuser
Minimum Airflow 0.00 CFM/person

Chapel Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone Heating Units:

Zone All
Zone Heating Unit Type None

Zone Unit Heat Source Hot Water
Zone Heating Unit Schedule JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature 55.0 °F
Supply Fan Airflow 16979.1 CFM
Ventilation Airflow 1918.3 CFM
Heating Supply Temperature 95.0 °F

Hydronic Sizing Specifications:

Chilled Water Delta-T 12.0 °F
Hot Water Delta-T 20.0 °F

Safety Factors:

Cooling Sensible 0 %
Cooling Latent 0 %
Heating 0 %

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coll (MBH)	(CFM)
1	16979.1	-	-	

5. Equipment Data

No Equipment Data required for this system.

N4 Core/Main Corr. Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name N4 Core/Main Corr.
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 4

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-Main Corr/Lobby	x1

N4 Core/Main Corr. Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-N Corridor	x1
4-N Wing 1	x1
4-N Wing 2	x1
4-E. Toilet/Stair 3	x1
4-Stair 2	x1
4-W. Toilet/Stair 1	x1
Zone 2: Zone 2	
3-Main Corr/Lobby	x1
3-E. Toilet/Stair 3	x1
3-Stair 2	x1
3-W. Toilet/Stair 1	x1
Zone 3: Zone 3	
2-Main Corr/Lobby	x1
2-E. Toilet/Stair 3	x1
2-Stair 2	x1
2-W. Toilet/Stair 1	x1
Zone 4: Zone 4	
1-Main Corr/Lobby	x1
1-Lounge/Corridor	x1
1-E. Toilet/Stair 3	x1
1-Stair 2	x1
1-W. Toilet/Vest/Stair1	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occupied	75.0 °F
Cooling T-stat: Unoccupied	85.0 °F
Heating T-stat: Occupied	70.0 °F
Heating T-stat: Unoccupied	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	10536.5 CFM
Ventilation Airflow	1154.7 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

Zone Sizing Data:

N4 Core/Main Corr. Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone Airflow Sizing Method **Sum of space airflow rates**
Space Airflow Sizing Method **Individual peak space loads**

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-
1	4537.9	-	192.0	-
2	1859.2	-	89.6	-
3	2002.6	-	108.5	
4	2136.8	-	111.9	

5. Equipment Data

No Equipment Data required for this system.

NE Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name NE Core
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 4

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-NE Corridor	x1

NE Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-NE Wing 1	x1
4-NE Wing 2	x1
Zone 2: Zone 2	
3-NE Corridor	x1
3-NE Wing 1	x1
3-NE Wing 2	x1
3-NE Wing 3	x1
Zone 3: Zone 3	
2-NE Corridor	x1
2-NE Wing 1	x1
2-NE Wing 2	x1
2-NE Wing 3	x1
Zone 4: Zone 4	
1-NE Corridor	x1
1-NE Wing 1	x1
1-NE Wing 2	x1
1-NE Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occ.	75.0 °F
Cooling T-stat: Unocc.	85.0 °F
Heating T-stat: Occ.	70.0 °F
Heating T-stat: Unocc.	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	10334.2 CFM
Ventilation Airflow	716.0 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

Zone Sizing Data:

Zone Airflow Sizing Method	Sum of space airflow rates
Space Airflow Sizing Method	Individual peak space loads

Zone	Supply Airflow	Zone Htg Unit	Reheat Coil	-

NE Core Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

	(CFM)	(MBH)	(MBH)	-
1	1681.2	-	60.3	-
2	2416.3	-	87.9	-
3	3301.7	-	113.2	
4	2935.0	-	100.3	

5. Equipment Data

No Equipment Data required for this system.

NW Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name NW Core
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 4

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-NW Corridor	x1

NW Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-NW Wing 1	x1
4-NW Wing 2	x1
Zone 2: Zone 2	
3-NW Corridor	x1
3-NW Wing 1	x1
3-NW Wing 2	x1
3-NW Wing 3	x1
Zone 3: Zone 3	
2-NW Corridor	x1
2-NW Wing 1	x1
2-NW Wing 2	x1
2-NW Wing 3	x1
Zone 4: Zone 4	
1-NW Corridor	x1
1-NW Wing 1	x1
1-NW Wing 2	x1
1-NW Wing 3	x1
1-NW Wing 4	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occ.	75.0 °F
Cooling T-stat: Unocc.	85.0 °F
Heating T-stat: Occ.	70.0 °F
Heating T-stat: Unocc.	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW
Thermostat Schedule	100% Occupied 24-7
Unoccupied Cooling is	Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	12001.7 CFM
Ventilation Airflow	871.9 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

Zone Sizing Data:

Zone Airflow Sizing Method	Sum of space airflow rates
Space Airflow Sizing Method	Individual peak space loads

NW Core Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-	-
1	1897.0	-	66.1	-	-
2	2655.2	-	95.3	-	-
3	3549.0	-	119.8		
4	3900.5	-	130.7		

5. Equipment Data

No Equipment Data required for this system.

SE Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name SE Core
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 4

2. System Components:

Ventilation Air Data:

Airflow Control	Constant Ventilation Airflow
Ventilation Sizing Method	Sum of Space OA Airflows
Unocc. Damper Position	Closed
Damper Leak Rate	0 %
Outdoor Air CO ₂ Level	400 ppm

Economizer Data:

Control	Non-integrated dry-bulb control
Upper Cutoff	55.0 °F
Lower Cutoff	50.0 °F

Preheat Coil Data:

Setpoint	60.0 °F
Heating Source	Hot Water
Schedule	JFMAMJJASOND
Coil position	Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature	55.0 °F
Coil Bypass Factor	0.100
Cooling Source	Chilled Water
Schedule	JFMAMJJASOND
Capacity Control	Constant Temperature - Fan On

Supply Fan Data:

Fan Type	BL/AF with Variable Frequency Drive
Configuration	Draw-thru
Fan Performance	3.00 in wg
Overall Efficiency	43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain	0 %
Duct Leakage	0 %

Return Duct or Plenum Data:

Return Air Via	Ducted Return
----------------------	---------------

Return Fan Data:

Fan Type	Forward Curved with Variable Frequency Drive
Fan Performance	2.00 in wg
Overall Efficiency	48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-SE Corridor	x1

SE Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-SE Wing 1	x1
4-SE Wing 2	x1
4-SE Wing 3	x1
Zone 2: Zone 2	
3-SE Corridor	x1
3-SE Wing 1	x1
3-SE Wing 2	x1
3-SE Wing 3	x1
Zone 3: Zone 3	
2-SE Corridor	x1
2-SE Wing 1	x1
2-SE Wing 2	x1
2-SE Wing 3	x1
Zone 4: Zone 4	
1-SE Corridor	x1
1-SE Wing 1	x1
1-SE Wing 2	x1
1-SE Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occ.	75.0 °F
Cooling T-stat: Unocc.	85.0 °F
Heating T-stat: Occ.	70.0 °F
Heating T-stat: Unocc.	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	14243.3 CFM
Ventilation Airflow	985.2 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

Zone Sizing Data:

Zone Airflow Sizing Method	Sum of space airflow rates
Space Airflow Sizing Method	Individual peak space loads

SE Core Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coll (MBH)	-
1	3342.0	-	108.1	-
2	3262.2	-	109.4	-
3	3903.3	-	127.4	
4	3735.9	-	119.8	

5. Equipment Data

No Equipment Data required for this system.

Staff Office Bldg. Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name Staff Office Bldg.
 Equipment Type Chilled Water AHU
 Air System Type Single Zone CAV
 Number of zones 1

2. System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
 Ventilation Sizing Method Sum of Space OA Airflows
 Unocc. Damper Position Closed
 Damper Leak Rate 0 %
 Outdoor Air CO₂ Level 400 ppm

Economizer Data:

Control Non-integrated dry-bulb control
 Upper Cutoff 55.0 °F
 Lower Cutoff 50.0 °F

Central Cooling Data:

Supply Air Temperature 55.0 °F
 Coil Bypass Factor 0.100
 Cooling Source Chilled Water
 Schedule JFMAMJJASOND
 Capacity Control Cycled or Staged Capacity - Fan On

Central Heating Data:

Supply Temperature 95.0 °F
 Heating Source Hot Water
 Schedule JFMAMJJASOND
 Capacity Control Cycled or Staged Capacity - Fan On

Supply Fan Data:

Fan Type Backward Inclined or Airfoil (BI/AF)
 Configuration Draw-thru
 Fan Performance 2.00 in wg
 Overall Efficiency 54 %

Duct System Data:

Supply Duct Data:
 Duct Heat Gain 0 %
 Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
Inst. Research Bldg.	x1

Thermostats and Zone Data:

Zone All
 Cooling T-stat: Occupied 75.0 °F
 Cooling T-stat: Unoccupied 85.0 °F
 Heating T-stat: Occupied 70.0 °F
 Heating T-stat: Unoccupied 60.0 °F
 T-stat Throttling Range 0.10 °F
 Diversity Factor 100 %
 Direct Exhaust Airflow 0.0 CFM
 Direct Exhaust Fan kW 0.0 kW

Thermostat Schedule 100% Occupied 24-7
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone All
 Terminal Type Diffuser
 Minimum Airflow 0.00 CFM/person

Staff Office Bldg. Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone Heating Units:

Zone All
Zone Heating Unit Type None

Zone Unit Heat Source Hot Water
Zone Heating Unit Schedule JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature 55.0 °F
Supply Fan Airflow 2594.4 CFM
Ventilation Airflow 173.8 CFM
Heating Supply Temperature 95.0 °F

Hydronic Sizing Specifications:

Chilled Water Delta-T 12.0 °F
Hot Water Delta-T 20.0 °F

Safety Factors:

Cooling Sensible 0 %
Cooling Latent 0 %
Heating 0 %

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coll (MBH)	(CFM)
1	2594.4	-	-	-

5. Equipment Data

No Equipment Data required for this system.

SW Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

1. General Details:

Air System Name SW Core
 Equipment Type Chilled Water AHU
 Air System Type VAV
 Number of zones 4

2. System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
 Ventilation Sizing Method Sum of Space OA Airflows
 Unocc. Damper Position Closed
 Damper Leak Rate 0 %
 Outdoor Air CO2 Level 400 ppm

Economizer Data:

Control Non-integrated dry-bulb control
 Upper Cutoff 55.0 °F
 Lower Cutoff 50.0 °F

Preheat Coil Data:

Setpoint 60.0 °F
 Heating Source Hot Water
 Schedule JFMAMJJASOND
 Coil position Downstream of Mixing Point

Central Cooling Data:

Supply Air Temperature 55.0 °F
 Coil Bypass Factor 0.100
 Cooling Source Chilled Water
 Schedule JFMAMJJASOND
 Capacity Control Constant Temperature - Fan On

Supply Fan Data:

Fan Type BI/AF with Variable Frequency Drive
 Configuration Draw-thru
 Fan Performance 3.00 in wg
 Overall Efficiency 43 %

% Airflow	100	90	80	70	60	50
% kW	100	77	57	42	30	21

% Airflow	40	30	20	10	0
% kW	15	13	10	7	5

Duct System Data:

Supply Duct Data:

Duct Heat Gain 0 %
 Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

Return Fan Data:

Fan Type Forward Curved with Variable Frequency Drive
 Fan Performance 2.00 in wg
 Overall Efficiency 48 %

% Airflow	100	90	80	70	60	50
% kW	100	77	60	44	35	25

% Airflow	40	30	20	10	0
% kW	19	13	9	7	6

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
4-SW Corridor	x1

SW Core Input Data

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/08/2011
 10:16AM

4-SW Wing 1	x1
4-SW Wing 2	x1
4-SW Wing 3	x1
Zone 2: Zone 2	
3-SW Corridor	x1
3-SW Wing 1	x1
3-SW Wing 2	x1
3-SW Wing 3	x1
Zone 3: Zone 3	
2-SW Corridor	x1
2-SW Wing 1	x1
2-SW Wing 2	x1
2-SW Wing 3	x1
Zone 4: Zone 4	
1-SW Corridor	x1
1-SW Wing 1	x1
1-SW Wing 2	x1
1-SW Wing 3	x1

Thermostats and Zone Data:

Zone	All
Cooling T-stat: Occ.	75.0 °F
Cooling T-stat: Unocc.	85.0 °F
Heating T-stat: Occ.	70.0 °F
Heating T-stat: Unocc.	60.0 °F
T-stat Throttling Range	0.10 °F
Diversity Factor	100 %
Direct Exhaust Airflow	0.0 CFM
Direct Exhaust Fan kW	0.0 kW
Thermostat Schedule	100% Occupied 24-7
Unoccupied Cooling is	Available

Supply Terminals Data:

Zone	All
Terminal Type	VAV box with RH
Minimum Airflow	40 % of supply air
Reheat Coil Source	Hot Water
Reheat Coil Schedule	JFMAMJJASOND

Zone Heating Units:

Zone	All
Zone Heating Unit Type	None
Zone Unit Heat Source	Hot Water
Zone Heating Unit Schedule	JFMAMJJASOND

4. Sizing Data (Computer-Generated):

System Sizing Data:

Cooling Supply Temperature	55.0 °F
Supply Fan Airflow	12603.0 CFM
Ventilation Airflow	874.6 CFM

Hydronic Sizing Specifications:

Chilled Water Delta-T	12.0 °F
Hot Water Delta-T	20.0 °F

Safety Factors:

Cooling Sensible	0 %
Cooling Latent	0 %
Heating	0 %

Zone Sizing Data:

Zone Airflow Sizing Method	Sum of space airflow rates
Space Airflow Sizing Method	Individual peak space loads

SW Core Input Data

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/08/2011
10:16AM

Zone	Supply Airflow (CFM)	Zone Htg Unit (MBH)	Reheat Coil (MBH)	-
1	3081.8	-	97.2	-
2	2883.7	-	96.7	-
3	3657.7	-	116.2	
4	2997.8	-	100.6	

5. Equipment Data

No Equipment Data required for this system.

Appendix B-4

Air System Output Data

Air System Sizing Summary for 1st Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 1st Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 5
 Floor Area 16250.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 40.2 Tons
 Total coil load 482.6 MBH
 Sensible coil load 403.1 MBH
 Coil CFM at Jul 1600 14926 CFM
 Max block CFM at Jul 1600 15505 CFM
 Sum of peak zone CFM 15706 CFM
 Sensible heat ratio 0.835
 ft³/Ton 404.1
 BTU/(hr-ft²) 29.7
 Water flow @ 12.0 °F rise 80.48 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.8 / 62.8 °F
 Leaving DB / WB 52.5 / 51.2 °F
 Coil ADP 49.7 °F
 Bypass Factor 0.100
 Resulting RH 45 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 5 of 5 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 40.2 MBH
 Coil CFM at Nov 0000 6282 CFM
 Max coil CFM 15505 CFM
 Water flow @ 20.0 °F drop 4.02 gpm

Load occurs at Nov 0000
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 15505 CFM
 Standard CFM 15333 CFM
 Actual max CFM/ft² 0.95 CFM/ft²

Fan motor BHP 17.02 BHP
 Fan motor kW 12.69 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 15505 CFM
 Standard CFM 15333 CFM
 Actual max CFM/ft² 0.95 CFM/ft²

Fan motor BHP 10.16 BHP
 Fan motor kW 7.58 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 1233 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 23.91 CFM/person

Zone Sizing Summary for 1st Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name	1st Floor	Number of zones	5
Equipment Class	CW AHU	Floor Area	16250.0 ft ²
Air System Type	VAV	Location	Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM	Sum of space airflow rates	Calculation Months	Jan to Dec
Space CFM	Individual peak space loads	Sizing Data	Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	44.6	2137	855	Jul 1600	98.2	4610.0	0.46
Zone 2	82.5	3901	1560	Jul 1600	105.7	3675.0	1.06
Zone 3	61.6	2998	1199	Aug 1500	81.3	2640.0	1.14
Zone 4	61.9	2935	1174	Jul 1600	81.5	2440.0	1.20
Zone 5	75.2	3736	1494	Aug 1500	95.8	2885.0	1.29

Zone Terminal Sizing Data

Zone Name	Reheat Coll Load (MBH)	Reheat Coll Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	111.9	11.19	0.0	0.00	0
Zone 2	130.7	13.08	0.0	0.00	0
Zone 3	100.6	10.06	0.0	0.00	0
Zone 4	100.3	10.04	0.0	0.00	0
Zone 5	119.8	11.98	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
1-Main Corr/Lobby	1	9.1	Jul 1500	427	30.0	2255.0	0.19
1-Lounge/Corridor	1	14.6	Jul 0900	681	25.5	905.0	0.75
1-Stair 2	1	3.7	Aug 1900	172	12.2	270.0	0.64
1-W. Toilet/Vest/Stair1	1	11.6	Jul 1700	545	17.3	680.0	0.80
1-E. Toilet/Stair 3	1	6.7	Jul 1400	312	13.3	500.0	0.62
Zone 2							
1-NW Corridor	1	1.6	Jul 1500	75	5.7	335.0	0.22
1-NW Wing 1	1	26.5	Jul 1700	1239	28.3	730.0	1.70
1-NW Wing 2	1	19.7	Jul 0900	920	25.1	715.0	1.29
1-NW Wing 3	1	13.1	Jul 1500	614	21.4	665.0	0.92
1-NW Wing 4	1	22.5	Jul 1700	1053	25.2	1230.0	0.86
Zone 3							
1-SW Corridor	1	2.7	Sep 1400	126	6.0	310.0	0.41
1-SW Wing 1	1	23.0	Jul 1700	1076	24.5	630.0	1.71
1-SW Wing 2	1	18.6	Aug 1400	871	24.8	850.0	1.03
1-SW Wing 3	1	19.7	Sep 1400	924	25.9	850.0	1.09
Zone 4							
1-NE Corridor	1	1.6	Jul 1500	76	5.8	335.0	0.23
1-NE Wing 1	1	18.9	Jul 0900	887	24.5	630.0	1.41
1-NE Wing 2	1	29.6	Jul 1700	1388	30.6	865.0	1.60
1-NE Wing 3	1	12.5	Jul 1500	585	20.6	610.0	0.96

B-136

Zone Sizing Summary for 1st Floor

Project Name: ShipU. Old Main HVAC Study

Prepared by: Century Engineering

12/06/2011

01:29PM

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 5							
1-SE Corridor	1	7.3	Sep 1300	343	9.2	350.0	0.98
1-SE Wing 1	1	24.5	Jul 1400	1146	31.3	850.0	1.35
1-SE Wing 2	1	26.7	Jul 1700	1250	28.2	850.0	1.47
1-SE Wing 3	1	21.3	Sep 1400	997	27.1	835.0	1.19

Ventilation Sizing Summary for 1st Floor

12/06/2011
01:29PM

1. Summary

Ventilation Sizing Method Design Ventilation Airflow Rate 1233 CFM

2. Space Ventilation Analysis Table

Sum of Space OA Airflows 1233 CFM

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
1-Main Corridor/Lobby	1	2255.0	0.0	426.7	0.00	0.06	0.0	0.0	135.3
1-Lounge/Corridor	1	905.0	0.0	681.2	0.00	0.06	0.0	0.0	54.3
1-Stair 2	1	270.0	0.0	172.0	0.00	0.06	0.0	0.0	16.2
1-W. Toilet/Vest/Stair1	1	680.0	0.0	544.5	0.00	0.06	0.0	0.0	40.8
1-E. Toilet/Stair 3	1	500.0	0.0	312.5	0.00	0.06	0.0	0.0	30.0
Zone 2									
1-NW Corridor	1	335.0	0.0	74.5	0.00	0.06	0.0	0.0	20.1
1-NW Wing 1	1	730.0	3.7	1239.1	5.00	0.06	0.0	0.0	62.1
1-NW Wing 2	1	715.0	3.6	920.4	5.00	0.06	0.0	0.0	60.8
1-NW Wing 3	1	685.0	3.3	613.7	5.00	0.06	0.0	0.0	56.5
1-NW Wing 4	1	1230.0	6.2	1052.8	5.00	0.06	0.0	0.0	104.6
Zone 3									
1-SW Corridor	1	310.0	0.0	126.2	0.00	0.06	0.0	0.0	18.6
1-SW Wing 1	1	630.0	3.2	1076.3	5.00	0.06	0.0	0.0	53.6
1-SW Wing 2	1	850.0	4.3	871.5	5.00	0.06	0.0	0.0	72.3
1-SW Wing 3	1	850.0	4.3	923.9	5.00	0.06	0.0	0.0	72.3
Zone 4									
1-NE Corridor	1	335.0	0.0	75.9	0.00	0.06	0.0	0.0	20.1
1-NE Wing 1	1	630.0	3.2	886.8	5.00	0.06	0.0	0.0	53.6
1-NE Wing 2	1	865.0	4.3	1387.6	5.00	0.06	0.0	0.0	73.5
1-NE Wing 3	1	610.0	3.1	584.7	5.00	0.06	0.0	0.0	51.9
Zone 5									
1-SE Corridor	1	350.0	0.0	342.6	0.00	0.06	0.0	0.0	21.0
1-SE Wing 1	1	850.0	4.3	1146.3	5.00	0.06	0.0	0.0	72.3
1-SE Wing 2	1	850.0	4.3	1249.8	5.00	0.06	0.0	0.0	72.3
1-SE Wing 3	1	835.0	4.2	997.3	5.00	0.06	0.0	0.0	71.0
Totals (incl. Space Multipliers)				15706.1					1232.8

Air System Design Load Summary for 1st Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600		HEATING DATA AT DES HTG		HEATING DATA AT DES HTG	
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2716 ft ²	123334	-	2716 ft ²	-	-
Wall Transmission	4955 ft ²	22245	-	4955 ft ²	74965	-
Roof Transmission	0 ft ²	0	-	0 ft ²	0	-
Window Transmission	2716 ft ²	35606	-	2716 ft ²	162675	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	252 ft ²	1009	-	252 ft ²	4612	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	14765 W	50373	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	15465 W	52765	-	0	0	-
People	52	12629	10568	0	0	0
Infiltration	-	23748	36063	-	220340	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	321709	46630	-	462592	0
Zone Conditioning	-	320302	46630	-	462035	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	14926 CFM	23643	-	6282 CFM	-4994	-
Ventilation Load	1233 CFM	19566	32862	1233 CFM	81162	0
Supply Fan Load	14926 CFM	39588	-	6282 CFM	-6630	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	403099	79492	-	531572	0
Central Cooling Coil	-	403099	79501	-	-40180	0
Preheat Coil	-	0	-	-	9739	-
Terminal Reheat Coils	-	0	-	-	562013	-
>> Total Conditioning	-	403099	79501	-	531572	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for 2nd Floor

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 2nd Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 5
 Floor Area 14205.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 40.4 Tons
 Total coil load 484.5 MBH
 Sensible coil load 410.3 MBH
 Coil CFM at Jul 1600 15347 CFM
 Max block CFM at Jul 1600 16145 CFM
 Sum of peak zone CFM 16414 CFM
 Sensible heat ratio 0.847
 ft²/Ton 351.8
 BTU/(hr-ft²) 34.1
 Water flow @ 12.0 °F rise 80.79 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.6 / 62.6 °F
 Leaving DB / WB 52.6 / 51.2 °F
 Coil ADP 49.8 °F
 Bypass Factor 0.100
 Resulting RH 45 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 5 of 5 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 42.0 MBH
 Coil CFM at Jan 1300 6566 CFM
 Max coil CFM 16145 CFM
 Water flow @ 20.0 °F drop 4.20 gpm

Load occurs at Jan 1300
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 16145 CFM
 Standard CFM 15966 CFM
 Actual max CFM/ft² 1.14 CFM/ft²

Fan motor BHP 17.72 BHP
 Fan motor kW 13.21 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 16145 CFM
 Standard CFM 15966 CFM
 Actual max CFM/ft² 1.14 CFM/ft²

Fan motor BHP 10.58 BHP
 Fan motor kW 7.89 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 1080 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 23.68 CFM/person

Zone Sizing Summary for 2nd Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 2nd Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 5
 Floor Area 14205.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	40.8	2003	801	Jul 1600	95.7	3630.0	0.55
Zone 2	74.3	3549	1420	Jul 1600	97.1	2580.0	1.38
Zone 3	73.3	3658	1463	Sep 1500	92.7	2620.0	1.40
Zone 4	68.9	3302	1321	Jul 1600	92.1	2395.0	1.38
Zone 5	78.8	3903	1561	Aug 1500	102.4	2980.0	1.31

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	108.5	10.86	0.0	0.00	0
Zone 2	119.8	11.99	0.0	0.00	0
Zone 3	116.2	11.62	0.0	0.00	0
Zone 4	113.2	11.33	0.0	0.00	0
Zone 5	127.4	12.75	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
2-Main Corr/Lobby	1	10.9	Jul 1500	510	43.6	2360.0	0.22
2-Stair 2	1	6.2	Sep 1400	292	14.2	270.0	1.08
2-W. Toilet/Stair 1	1	14.2	Jul 1700	665	19.0	500.0	1.33
2-E. Toilet/Stair 3	1	11.4	Jul 0900	536	19.0	500.0	1.07
Zone 2							
2-NW Corridor	1	4.5	Jul 1500	213	12.1	350.0	0.61
2-NW Wing 1	1	31.5	Jul 1700	1473	31.1	685.0	2.15
2-NW Wing 2	1	25.3	Jul 0900	1185	30.5	900.0	1.32
2-NW Wing 3	1	14.5	Jul 1500	678	23.5	645.0	1.05
Zone 3							
2-SW Corridor	1	3.8	Sep 1400	176	9.1	335.0	0.53
2-SW Wing 1	1	27.1	Jul 1700	1268	26.7	575.0	2.20
2-SW Wing 2	1	20.8	Aug 1400	975	26.7	845.0	1.15
2-SW Wing 3	1	26.5	Sep 1400	1239	30.3	865.0	1.43
Zone 4							
2-NE Corridor	1	4.5	Jul 1500	209	11.8	335.0	0.62
2-NE Wing 1	1	22.9	Jul 0900	1072	27.6	645.0	1.66
2-NE Wing 2	1	28.2	Jul 1700	1321	28.6	730.0	1.81
2-NE Wing 3	1	14.9	Jul 1500	699	24.0	685.0	1.02
Zone 5							
2-SE Corridor	1	4.1	Sep 1400	194	10.9	430.0	0.45

Zone Sizing Summary for 2nd Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
2-SE Wing 1	1	29.2	Jul 0900	1367	35.3	900.0	1.52
2-SE Wing 2	1	26.3	Aug 1600	1231	27.9	800.0	1.54
2-SE Wing 3	1	23.7	Sep 1400	1111	28.3	850.0	1.31

Ventilation Sizing Summary for 2nd Floor

12/06/2011
01:29PM

1. Summary

Ventilation Sizing Method	Sum of Space OA Airflows
Design Ventilation Airflow Rate	1080 CFM

.....

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
2-Main Corr/Lobby	1	2360.0	0.0	510.0	0.00	0.06	0.0	0.0	141.6
2-Stair 2	1	270.0	0.0	292.1	0.00	0.06	0.0	0.0	16.2
2-W. Toilet/Stair 1	1	500.0	0.0	664.8	0.00	0.06	0.0	0.0	30.0
2-E. Toilet/Stair 3	1	500.0	0.0	535.7	0.00	0.06	0.0	0.0	30.0
Zone 2									
2-NW Corridor	1	350.0	0.0	212.6	0.00	0.06	0.0	0.0	21.0
2-NW Wing 1	1	685.0	3.4	1472.7	5.00	0.06	0.0	0.0	58.2
2-NW Wing 2	1	900.0	4.5	1185.4	5.00	0.06	0.0	0.0	76.5
2-NW Wing 3	1	645.0	3.2	678.2	5.00	0.06	0.0	0.0	54.8
Zone 3									
2-SW Corridor	1	335.0	0.0	176.4	0.00	0.06	0.0	0.0	20.1
2-SW Wing 1	1	575.0	2.9	1267.8	5.00	0.06	0.0	0.0	48.9
2-SW Wing 2	1	845.0	4.2	974.9	5.00	0.06	0.0	0.0	71.8
2-SW Wing 3	1	865.0	4.3	1238.7	5.00	0.06	0.0	0.0	73.5
Zone 4									
2-NE Corridor	1	335.0	0.0	209.3	0.00	0.06	0.0	0.0	20.1
2-NE Wing 1	1	645.0	3.2	1071.6	5.00	0.06	0.0	0.0	54.8
2-NE Wing 2	1	730.0	3.7	1321.5	5.00	0.06	0.0	0.0	62.1
2-NE Wing 3	1	685.0	3.4	699.3	5.00	0.06	0.0	0.0	58.2
Zone 5									
2-SE Corridor	1	430.0	0.0	194.2	0.00	0.06	0.0	0.0	25.8
2-SE Wing 1	1	900.0	4.5	1367.3	5.00	0.06	0.0	0.0	76.5
2-SE Wing 2	1	800.0	4.0	1230.5	5.00	0.06	0.0	0.0	68.0
2-SE Wing 3	1	850.0	4.3	1111.2	5.00	0.06	0.0	0.0	72.3
Totals (Incl. Space Multipliers)				16414.3					1080.4

Air System Design Load Summary for 2nd Floor

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600 COOLING OA DB / WB 91.4 °F / 73.8 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	3360 ft ²	143517	-	3360 ft ²	-	-
Wall Transmission	3937 ft ²	17323	-	3937 ft ²	59563	-
Roof Transmission	0 ft ²	0	-	0 ft ²	0	-
Window Transmission	3360 ft ²	44052	-	3360 ft ²	201261	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	63 ft ²	252	-	63 ft ²	1153	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	12935 W	44130	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	13688 W	46701	-	0	0	-
People	46	11177	9353	0	0	0
Infiltration	-	23497	35862	-	218019	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	330649	45216	-	479996	0
Zone Conditioning	-	329285	45216	-	479411	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	15347 CFM	23869	-	6566 CFM	-5224	-
Ventilation Load	1080 CFM	17183	28946	1080 CFM	71134	0
Supply Fan Load	15347 CFM	39966	-	6566 CFM	-6944	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	410302	74162	-	538376	0
Central Cooling Coil	-	410302	74168	-	-45521	0
Preheat Coil	-	0	-	-	0	-
Terminal Reheat Coils	-	0	-	-	583897	-
>> Total Conditioning	-	410302	74168	-	538376	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for 3rd Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 3rd Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 5
 Floor Area 14210.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 33.6 Tons
 Total coil load 402.9 MBH
 Sensible coil load 333.8 MBH
 Coil CFM at Jul 1600 12331 CFM
 Max block CFM at Jul 1600 12839 CFM
 Sum of peak zone CFM 13077 CFM
 Sensible heat ratio 0.829
 ft²/Ton 423.3
 BTU/(hr-ft²) 28.4
 Water flow @ 12.0 °F rise 67.18 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.9 / 62.9 °F
 Leaving DB / WB 52.5 / 51.2 °F
 Coil ADP 49.7 °F
 Bypass Factor 0.100
 Resulting RH 45 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 5 of 5 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 33.5 MBH
 Coil CFM at Jan 1300 5231 CFM
 Max coil CFM 12839 CFM
 Water flow @ 20.0 °F drop 3.35 gpm

Load occurs at Jan 1300
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 12839 CFM
 Standard CFM 12697 CFM
 Actual max CFM/ft² 0.90 CFM/ft²

Fan motor BHP 14.09 BHP
 Fan motor kW 10.51 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 12839 CFM
 Standard CFM 12697 CFM
 Actual max CFM/ft² 0.90 CFM/ft²

Fan motor BHP 8.42 BHP
 Fan motor kW 6.28 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 1081 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 23.67 CFM/person

Zone Sizing Summary for 3rd Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 3rd Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 5
 Floor Area 14210.0
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft²)	Zone CFM/ft²
Zone 1	38.4	1859	744	Jul 1600	77.7	3705.0	0.50
Zone 2	56.1	2655	1062	Jul 1600	78.3	2495.0	1.06
Zone 3	58.6	2884	1153	Aug 1500	78.2	2655.0	1.09
Zone 4	51.1	2416	967	Jul 1600	72.5	2290.0	1.06
Zone 5	66.3	3262	1305	Aug 1500	88.5	3065.0	1.06

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coll Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	89.6	8.96	0.0	0.00	0
Zone 2	95.3	9.54	0.0	0.00	0
Zone 3	96.7	9.68	0.0	0.00	0
Zone 4	87.9	8.80	0.0	0.00	0
Zone 5	109.4	10.94	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft²)	Space CFM/ft²
Zone 1							
3-Main Corr/Lobby	1	13.7	Jul 1600	643	35.7	2435.0	0.26
3-Stair 2	1	5.6	Sep 1400	261	12.5	270.0	0.97
3-W. Toilet/Stair 1	1	11.3	Jul 1700	527	14.7	500.0	1.05
3-E. Toilet/Stair 3	1	9.1	Jul 0900	428	14.7	500.0	0.86
Zone 2							
3-NW Corridor	1	2.8	Jul 1500	130	7.5	345.0	0.38
3-NW Wing 1	1	23.7	Jul 1700	1109	26.8	750.0	1.48
3-NW Wing 2	1	18.2	Jul 1400	852	24.2	750.0	1.14
3-NW Wing 3	1	12.1	Jul 1500	565	19.9	650.0	0.87
Zone 3							
3-SW Corridor	1	2.2	Aug 1500	104	6.1	345.0	0.30
3-SW Wing 1	1	18.0	Jul 1700	843	21.4	595.0	1.42
3-SW Wing 2	1	15.8	Jul 1400	741	21.4	595.0	1.25
3-SW Wing 3	1	25.5	Sep 1400	1196	29.3	1120.0	1.07
Zone 4							
3-NE Corridor	1	1.7	Jul 1500	79	5.6	305.0	0.26
3-NE Wing 1	1	16.8	Jul 1400	787	22.7	610.0	1.29
3-NE Wing 2	1	21.1	Jul 1700	988	24.3	730.0	1.35
3-NE Wing 3	1	12.0	Jul 1500	562	19.8	645.0	0.87
Zone 5							
3-SE Corridor	1	2.3	Aug 1500	109	6.5	375.0	0.29

Zone Sizing Summary for 3rd Floor

Project Name: ShipU. Old Main HVAC Study

Prepared by: Century Engineering

12/06/2011

01:29PM

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
3-SE Wing 1	1	23.1	Jul 1400	1082	30.5	920.0	1.18
3-SE Wing 2	1	21.6	Aug 1600	1012	25.8	920.0	1.10
3-SE Wing 3	1	22.6	Sep 1400	1059	25.7	850.0	1.25

Ventilation Sizing Summary for 3rd Floor

12/06/2011
01:29PM

1. Summary

Ventilation Sizing Method	Sum of Space OA Airflows
Design Ventilation Airflow Rate	1081 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
3-Main Corr/Lobby	1	2435.0	0.0	643.0	0.00	0.06	0.0	0.0	146.1
3-Stair 2	1	270.0	0.0	261.1	0.00	0.06	0.0	0.0	16.2
3-W. Toilet/Stair 1	1	500.0	0.0	527.0	0.00	0.06	0.0	0.0	30.0
3-E. Toilet/Stair 3	1	500.0	0.0	428.2	0.00	0.06	0.0	0.0	30.0
Zone 2									
3-NW Corridor	1	345.0	0.0	129.5	0.00	0.06	0.0	0.0	20.7
3-NW Wing 1	1	750.0	3.8	1108.9	5.00	0.06	0.0	0.0	63.8
3-NW Wing 2	1	750.0	3.8	852.1	5.00	0.06	0.0	0.0	63.8
3-NW Wing 3	1	650.0	3.3	564.7	5.00	0.06	0.0	0.0	55.3
Zone 3									
3-SW Corridor	1	345.0	0.0	103.8	0.00	0.06	0.0	0.0	20.7
3-SW Wing 1	1	595.0	3.0	842.7	5.00	0.06	0.0	0.0	50.6
3-SW Wing 2	1	595.0	3.0	741.3	5.00	0.06	0.0	0.0	50.6
3-SW Wing 3	1	1120.0	5.6	1195.9	5.00	0.06	0.0	0.0	95.2
Zone 4									
3-NE Corridor	1	305.0	0.0	79.3	0.00	0.06	0.0	0.0	18.3
3-NE Wing 1	1	610.0	3.1	786.6	5.00	0.06	0.0	0.0	51.9
3-NE Wing 2	1	730.0	3.7	988.4	5.00	0.06	0.0	0.0	62.1
3-NE Wing 3	1	645.0	3.2	562.1	5.00	0.06	0.0	0.0	54.8
Zone 5									
3-SE Corridor	1	375.0	0.0	109.4	0.00	0.06	0.0	0.0	22.5
3-SE Wing 1	1	920.0	4.6	1081.8	5.00	0.06	0.0	0.0	78.2
3-SE Wing 2	1	920.0	4.6	1011.6	5.00	0.06	0.0	0.0	78.2
3-SE Wing 3	1	850.0	4.3	1059.3	5.00	0.06	0.0	0.0	72.3
Totals (incl. Space Multipliers)								1081.0	
13076.6									

Air System Design Load Summary for 3rd Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600		HEATING DATA AT DES HTG		HEATING DATA AT DES HTG	
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2077 ft ²	92768	-	2077 ft ²	-	-
Wall Transmission	5264 ft ²	23080	-	5264 ft ²	79625	-
Roof Transmission	0 ft ²	0	-	0 ft ²	0	-
Window Transmission	2077 ft ²	27233	-	2077 ft ²	124422	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	0 ft ²	0	-	0 ft ²	0	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	12941 W	44151	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	13703 W	46752	-	0	0	-
People	46	11190	9363	0	0	0
Infiltration	-	20595	31057	-	191086	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	265769	40420	-	395133	0
Zone Conditioning	-	264598	40420	-	394660	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	12331 CFM	19466	-	5231 CFM	-4164	-
Ventilation Load	1081 CFM	17165	28615	1081 CFM	71171	0
Supply Fan Load	12331 CFM	32595	-	5231 CFM	-5538	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	333824	69035	-	456129	0
Central Cooling Coil	-	333824	69041	-	-33470	0
Preheat Coil	-	0	-	-	11699	-
Terminal Reheat Coils	-	0	-	-	477900	-
>> Total Conditioning	-	333824	69041	-	456129	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for 4th Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 4th Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 6
 Floor Area 16000.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 37.1 Tons
 Total coil load 444.8 MBH
 Sensible coil load 370.3 MBH
 Coil CFM at Jul 1600 13687 CFM
 Max block CFM at Jul 1600 14324 CFM
 Sum of peak zone CFM 14540 CFM
 Sensible heat ratio 0.832
 ft²/Ton 431.6
 BTU/(hr-ft²) 27.8
 Water flow @ 12.0 °F rise 74.18 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.9 / 62.9 °F
 Leaving DB / WB 52.5 / 51.2 °F
 Coil ADP 49.7 °F
 Bypass Factor 0.100
 Resulting RH 45 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 6 of 6 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 37.2 MBH
 Coil CFM at Jan 1300 5816 CFM
 Max coil CFM 14324 CFM
 Water flow @ 20.0 °F drop 3.72 gpm

Load occurs at Jan 1300
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 14324 CFM
 Standard CFM 14165 CFM
 Actual max CFM/ft² 0.90 CFM/ft²

Fan motor BHP 15.72 BHP
 Fan motor kW 11.72 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 14324 CFM
 Standard CFM 14165 CFM
 Actual max CFM/ft² 0.90 CFM/ft²

Fan motor BHP 9.39 BHP
 Fan motor kW 7.00 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 1208 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 24.34 CFM/person

Zone Sizing Summary for 4th Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name 4th Floor
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 6
 Floor Area 16000.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	43.6	2088	835	Jul 1600	79.1	3340.0	0.63
Zone 2	39.5	1897	759	Jul 1600	53.9	1940.0	0.98
Zone 3	50.9	2450	980	Jul 1600	83.8	3080.0	0.80
Zone 4	35.0	1681	672	Jul 1600	49.5	1715.0	0.98
Zone 5	62.5	3082	1233	Aug 1600	77.4	2795.0	1.10
Zone 6	68.0	3342	1337	Aug 1500	86.7	3130.0	1.07

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	92.5	9.25	0.0	0.00	0
Zone 2	66.1	6.61	0.0	0.00	0
Zone 3	99.5	9.95	0.0	0.00	0
Zone 4	60.3	6.04	0.0	0.00	0
Zone 5	97.2	9.72	0.0	0.00	0
Zone 6	108.1	10.81	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-Main Corr/Lobby	1	17.5	Jul 1600	821	35.8	2070.0	0.40
4-Stair 2	1	6.0	Sep 1400	279	12.6	270.0	1.03
4-W. Toilet/Stair 1	1	11.6	Jul 1700	545	15.4	500.0	1.09
4-E. Toilet/Stair 3	1	9.5	Jul 1500	442	15.4	500.0	0.88
Zone 2							
4-NW Corridor	1	4.6	Jul 1500	214	10.2	440.0	0.49
4-NW Wing 1	1	19.9	Jul 1700	931	22.9	750.0	1.24
4-NW Wing 2	1	16.1	Jul 1300	752	20.9	750.0	1.00
Zone 3							
4-N Corridor	1	6.2	Jul 1500	292	30.5	970.0	0.30
4-N Wing 1	1	24.2	Jul 1700	1135	26.6	1055.0	1.08
4-N Wing 2	1	21.9	Jul 1300	1023	26.6	1055.0	0.97
Zone 4							
4-NE Corridor	1	4.6	Jul 1500	214	10.2	440.0	0.49
4-NE Wing 1	1	14.6	Jul 1400	682	19.5	630.0	1.08
4-NE Wing 2	1	16.8	Jul 1700	786	19.9	645.0	1.22
Zone 5							
4-SW Corridor	1	6.4	Sep 1400	300	10.2	440.0	0.68
4-SW Wing 1	1	16.8	Jul 1700	788	19.5	595.0	1.32

Zone Sizing Summary for 4th Floor

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
4-SW Wing 2	1	18.3	Jul 1700	854	21.0	695.0	1.23
4-SW Wing 3	1	24.3	Sep 1400	1140	26.8	1065.0	1.07
Zone 6							
4-SE Corridor	1	6.4	Sep 1400	300	10.2	440.0	0.68
4-SE Wing 1	1	22.2	Jul 1400	1039	28.3	920.0	1.13
4-SE Wing 2	1	17.8	Jul 1700	834	20.5	665.0	1.25
4-SE Wing 3	1	25.0	Sep 1400	1169	27.6	1105.0	1.06

Ventilation Sizing Summary for 4th Floor

12/06/2011
01:29PM

1. Summary

Ventilation Sizing Method Design Ventilation Airflow Rate

Sum of Space OA Airflows 1208 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-Main Corr/Lobby	1	2070.0	0.0	820.7	0.00	0.06	0.0	0.0	124.2
4-Stair 2	1	270.0	0.0	279.4	0.00	0.06	0.0	0.0	16.2
4-W. Toilet/Stair 1	1	500.0	0.0	545.2	0.00	0.06	0.0	0.0	30.0
4-E. Toilet/Stair 3	1	500.0	0.0	442.5	0.00	0.06	0.0	0.0	30.0
Zone 2									
4-NW Corridor	1	440.0	0.0	213.6	0.00	0.06	0.0	0.0	26.4
4-NW Wing 1	1	750.0	3.8	931.2	5.00	0.06	0.0	0.0	63.8
4-NW Wing 2	1	750.0	3.8	752.3	5.00	0.06	0.0	0.0	63.8
Zone 3									
4-N Corridor	1	970.0	0.0	292.1	0.00	0.06	0.0	0.0	58.2
4-N Wing 1	1	1055.0	5.3	1134.9	5.00	0.06	0.0	0.0	89.7
4-N Wing 2	1	1055.0	5.3	1023.0	5.00	0.06	0.0	0.0	89.7
Zone 4									
4-NE Corridor	1	440.0	0.0	213.6	0.00	0.06	0.0	0.0	26.4
4-NE Wing 1	1	630.0	3.2	681.9	5.00	0.06	0.0	0.0	53.6
4-NE Wing 2	1	645.0	3.2	785.7	5.00	0.06	0.0	0.0	54.8
Zone 5									
4-SW Corridor	1	440.0	0.0	299.8	0.00	0.06	0.0	0.0	26.4
4-SW Wing 1	1	595.0	3.0	787.8	5.00	0.06	0.0	0.0	50.6
4-SW Wing 2	1	695.0	3.5	854.4	5.00	0.06	0.0	0.0	59.1
4-SW Wing 3	1	1065.0	5.3	1139.8	5.00	0.06	0.0	0.0	90.5
Zone 6									
4-SE Corridor	1	440.0	0.0	299.8	0.00	0.06	0.0	0.0	26.4
4-SE Wing 1	1	920.0	4.6	1038.8	5.00	0.06	0.0	0.0	78.2
4-SE Wing 2	1	665.0	3.3	834.4	5.00	0.06	0.0	0.0	56.5
4-SE Wing 3	1	1105.0	5.5	1169.0	5.00	0.06	0.0	0.0	93.9
Totals (Incl. Space Multipliers)		14539.8				1208.3			

Air System Design Load Summary for 4th Floor

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600 COOLING OA DB / WB 91.4 °F / 73.8 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	1530 ft ²	75616	-	1530 ft ²	-	-
Wall Transmission	5717 ft ²	25843	-	5717 ft ²	86489	-
Roof Transmission	15730 ft ²	41669	-	15730 ft ²	42477	-
Window Transmission	1530 ft ²	20063	-	1530 ft ²	91665	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	21 ft ²	84	-	21 ft ²	384	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	418 ft ²	-1737	-	418 ft ²	12540	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	14483 W	49410	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	14895 W	50821	-	0	0	-
People	50	12163	10178	0	0	0
Infiltration	-	21218	32203	-	196874	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	295150	42381	-	430429	0
Zone Conditioning	-	293689	42381	-	429901	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	13687 CFM	21449	-	5816 CFM	-4626	-
Ventilation Load	1208 CFM	19200	32191	1208 CFM	79550	0
Supply Fan Load	13687 CFM	35915	-	5816 CFM	-6145	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	370254	74572	-	498679	0
Central Cooling Coil	-	370254	74578	-	-37204	0
Preheat Coil	-	0	-	-	13428	-
Terminal Reheat Coils	-	0	-	-	522455	-
>> Total Conditioning	-	370254	74578	-	498679	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for Chapel

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name Chapel
 Equipment Class CW AHU
 Air System Type SZCAV

Number of zones 1
 Floor Area 5555.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 41.0 Tons
 Total coil load 492.1 MBH
 Sensible coil load 368.6 MBH
 Coil CFM at Jul 1600 16979 CFM
 Max block CFM 16979 CFM
 Sum of peak zone CFM 16979 CFM
 Sensible heat ratio 0.749
 ft²/Ton 135.5
 BTU/(hr-ft²) 88.6
 Water flow @ 12.0 °F rise 82.07 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 76.8 / 65.2 °F
 Leaving DB / WB 56.5 / 55.4 °F
 Coil ADP 54.2 °F
 Bypass Factor 0.100
 Resulting RH 55 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 1 of 1 OK
 Max zone temperature deviation 0.0 °F

Central Heating Coil Sizing Data

Max coil load 534.3 MBH
 Coil CFM at Des Htg 16979 CFM
 Max coil CFM 16979 CFM
 Water flow @ 20.0 °F drop 53.46 gpm

Load occurs at Des Htg
 BTU/(hr-ft²) 96.2
 Ent. DB / Lvg DB 63.4 / 92.9 °F

Supply Fan Sizing Data

Actual max CFM 16979 CFM
 Standard CFM 16791 CFM
 Actual max CFM/ft² 3.06 CFM/ft²

Fan motor BHP 9.89 BHP
 Fan motor kW 7.38 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 1918 CFM
 CFM/ft² 0.35 CFM/ft²

CFM/person 6.05 CFM/person

Zone Sizing Summary for Chapel

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

Air System Information

Air System Name Chapel
 Equipment Class CW AHU
 Air System Type SZCAV

Number of zones 1
 Floor Area 5555.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	308.5	16979	16979	Jul 1600	431.5	5555.0	3.06

Zone Terminal Sizing Data

No Zone Terminal Sizing Data required for this system.

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
2-Chapel Assembly	1	217.2	Jul 1600	10170	249.7	3170.0	3.21
2-Chap. Platform/Storage	1	91.2	Jul 1600	6809	181.8	2385.0	2.85

Ventilation Sizing Summary for Chapel

12/06/2011
01:29PM

- 1. Summary**
Ventilation Sizing Method **Sum of Space OA Airflows**
Design Ventilation Airflow Rate **1918 CFM**

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1										
2-Chapel Assembly	1	3170.0	317.0	10170.2	5.00	0.06	0.0	0.0	0.0	1775.2
2-Chap. Platform/Storage	1	2385.0	0.0	6808.8	5.00	0.06	0.0	0.0	0.0	143.1
Totals (Incl. Space Multipliers)				16979.1						1918.3

Air System Design Load Summary for Chapel

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600		HEATING DATA AT DES HTG		HEATING DATA AT DES HTG	
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2354 ft ²	105398	-	2354 ft ²	-	-
Wall Transmission	3826 ft ²	18847	-	3826 ft ²	57879	-
Roof Transmission	2385 ft ²	5972	-	2385 ft ²	6440	-
Window Transmission	2354 ft ²	30865	-	2354 ft ²	141014	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	0 ft ²	0	-	0 ft ²	0	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	9721 W	33166	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	3578 W	12206	-	0	0	-
People	317	77660	64985	0	0	0
Infiltration	-	24378	24581	-	226193	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	308492	89566	-	431526	0
Zone Conditioning	-	309679	89566	-	433904	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	16979 CFM	0	-	16979 CFM	0	-
Ventilation Load	1918 CFM	33778	33957	1918 CFM	125619	0
Supply Fan Load	16979 CFM	25174	-	16979 CFM	-25174	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	368631	123523	-	534349	0
Central Cooling Coil	-	368631	123498	-	0	0
Central Heating Coil	-	0	-	-	534349	-
>> Total Conditioning	-	368631	123498	-	534349	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for N4 Core/Main Corr.

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:29PM

Air System Information

Air System Name **N4 Core/Main Corr.**
Equipment Class **CW AHU**
Air System Type **VAV**

Number of zones **4**
Floor Area **18365.0 ft²**
Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **29.1** Tons
Total coil load **349.4** MBH
Sensible coil load **277.4** MBH
Coil CFM at Jul 1600 **10095** CFM
Max block CFM at Jul 1600 **10537** CFM
Sum of peak zone CFM **10537** CFM
Sensible heat ratio **0.794**
ft²/Ton **630.8**
BTU/(hr-ft²) **19.0**
Water flow @ 12.0 °F rise **58.26** gpm

Load occurs at **Jul 1600**
OA DB / WB **91.4 / 73.8** °F
Entering DB / WB **78.3 / 63.6** °F
Leaving DB / WB **52.5 / 51.2** °F
Coil ADP **49.7** °F
Bypass Factor **0.100**
Resulting RH **46** %
Design supply temp. **55.0** °F
Zone T-stat Check **4 of 4** OK
Max zone temperature deviation **0.0** °F

Preheat Coil Sizing Data

Max coil load **28.1** MBH
Coil CFM at Des Htg **4215** CFM
Max coil CFM **10537** CFM
Water flow @ 20.0 °F drop **2.81** gpm

Load occurs at **Des Htg**
Ent. DB / Lvg DB **53.8 / 60.0** °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 **10537** CFM
Standard CFM **10420** CFM
Actual max CFM/ft² **0.57** CFM/ft²

Fan motor BHP **11.57** BHP
Fan motor kW **8.62** kW
Fan static **3.00** in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 **10537** CFM
Standard CFM **10420** CFM
Actual max CFM/ft² **0.57** CFM/ft²

Fan motor BHP **6.91** BHP
Fan motor kW **5.15** kW
Fan static **2.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **1155** CFM
CFM/ft² **0.06** CFM/ft²

CFM/person **109.45** CFM/person

Air System Sizing Summary for N4 Core/Main Corr.

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:29PM

Air System Information

Air System Name N4 Core/Main Corr.
Equipment Class CW AHU
Air System Type VAV

Number of zones 4
Floor Area 18365.0 ft²
Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
Space CFM Individual peak space loads

Calculation Months Jan to Dec
Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	94.5	4538	1815	Jul 1600	162.9	6420.0	0.71
Zone 2	38.4	1859	744	Jul 1600	77.7	3705.0	0.50
Zone 3	40.8	2003	801	Jul 1600	95.7	3630.0	0.55
Zone 4	44.6	2137	855	Jul 1600	98.2	4610.0	0.46

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coll Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	192.0	19.21	0.0	0.00	0
Zone 2	89.6	8.96	0.0	0.00	0
Zone 3	108.5	10.86	0.0	0.00	0
Zone 4	111.9	11.19	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-Main Corr/Lobby	1	17.5	Jul 1600	821	35.8	2070.0	0.40
4-N Corridor	1	6.2	Jul 1500	292	30.5	970.0	0.30
4-N Wing 1	1	24.2	Jul 1700	1135	26.6	1055.0	1.08
4-N Wing 2	1	21.9	Jul 1300	1023	26.6	1055.0	0.97
4-E. Toilet/Stair 3	1	9.5	Jul 1500	442	15.4	500.0	0.88
4-Stair 2	1	6.0	Sep 1400	279	12.6	270.0	1.03
4-W. Toilet/Stair 1	1	11.6	Jul 1700	545	15.4	500.0	1.09
Zone 2							
3-Main Corr/Lobby	1	13.7	Jul 1600	643	35.7	2435.0	0.26
3-E. Toilet/Stair 3	1	9.1	Jul 0900	428	14.7	500.0	0.86
3-Stair 2	1	5.6	Sep 1400	261	12.5	270.0	0.97
3-W. Toilet/Stair 1	1	11.3	Jul 1700	527	14.7	500.0	1.05
Zone 3							
2-Main Corr/Lobby	1	10.9	Jul 1500	510	43.6	2360.0	0.22
2-E. Toilet/Stair 3	1	11.4	Jul 0900	536	19.0	500.0	1.07
2-Stair 2	1	6.2	Sep 1400	292	14.2	270.0	1.08
2-W. Toilet/Stair 1	1	14.2	Jul 1700	665	19.0	500.0	1.33
Zone 4							
1-Main Corr/Lobby	1	9.1	Jul 1500	427	30.0	2255.0	0.19
1-Lounge/Corridor	1	14.6	Jul 0900	681	25.5	905.0	0.75
1-E. Toilet/Stair 3	1	6.7	Jul 1400	312	13.3	500.0	0.62
1-Stair 2	1	3.7	Aug 1900	172	12.2	270.0	0.64

B-160

Zone Sizing Summary for N4 Core/Main Corr.

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:29PM

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
1-W. Toilet/Vest/Stair1	1	11.6	Jul 1700	545	17.3	680.0	0.80

Ventilation Sizing Summary for N4 Core/Main Corr.

12/06/2011
01:29PM

1. Summary

Ventilation Sizing Method Design Ventilation Airflow Rate Sum of Space OA Airflows CFM
..... 1155 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-Main Corr/Lobby	1	2070.0	0.0	820.7	0.00	0.06	0.0	0.0	124.2
4-N Corridor	1	970.0	0.0	292.1	0.00	0.06	0.0	0.0	58.2
4-N Wing 1	1	1055.0	5.3	1134.9	5.00	0.06	0.0	0.0	89.7
4-N Wing 2	1	1055.0	5.3	1023.0	5.00	0.06	0.0	0.0	89.7
4-E. Toilet/Stair 3	1	500.0	0.0	442.5	0.00	0.06	0.0	0.0	30.0
4-Stair 2	1	270.0	0.0	279.4	0.00	0.06	0.0	0.0	16.2
4-W. Toilet/Stair 1	1	500.0	0.0	545.2	0.00	0.06	0.0	0.0	30.0
Zone 2									
3-Main Corr/Lobby	1	2435.0	0.0	643.0	0.00	0.06	0.0	0.0	146.1
3-E. Toilet/Stair 3	1	500.0	0.0	428.2	0.00	0.06	0.0	0.0	30.0
3-Stair 2	1	270.0	0.0	261.1	0.00	0.06	0.0	0.0	16.2
3-W. Toilet/Stair 1	1	500.0	0.0	527.0	0.00	0.06	0.0	0.0	30.0
Zone 3									
2-Main Corr/Lobby	1	2360.0	0.0	510.0	0.00	0.06	0.0	0.0	141.6
2-E. Toilet/Stair 3	1	500.0	0.0	535.7	0.00	0.06	0.0	0.0	30.0
2-Stair 2	1	270.0	0.0	292.1	0.00	0.06	0.0	0.0	16.2
2-W. Toilet/Stair 1	1	500.0	0.0	664.8	0.00	0.06	0.0	0.0	30.0
Zone 4									
1-Main Corr/Lobby	1	2255.0	0.0	426.7	0.00	0.06	0.0	0.0	135.3
1-Lounge/Corridor	1	905.0	0.0	681.2	0.00	0.06	0.0	0.0	54.3
1-E. Toilet/Stair 3	1	500.0	0.0	312.5	0.00	0.06	0.0	0.0	30.0
1-Stair 2	1	270.0	0.0	172.0	0.00	0.06	0.0	0.0	16.2
1-W. Toilet/Vest/Stair1	1	680.0	0.0	544.5	0.00	0.06	0.0	0.0	40.8
Totals (Incl. Space Multipliers)				10536.5					1154.7

Air System Design Load Summary for N4 Core/Main Corr.

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

ZONE LOADS	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600 COOLING OA DB / WB 91.4 °F / 73.8 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F		
	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	1374 ft ²	75271	-	1374 ft ²	-	-
Wall Transmission	4025 ft ²	20045	-	4025 ft ²	60889	-
Roof Transmission	6150 ft ²	15996	-	6150 ft ²	16607	-
Window Transmission	1374 ft ²	18016	-	1374 ft ²	82309	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	147 ft ²	589	-	147 ft ²	2690	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	418 ft ²	-1737	-	418 ft ²	12540	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	14301 W	48791	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	3165 W	10799	-	0	0	-
People	11	2585	2163	0	0	0
Infiltration	-	27954	40455	-	259370	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	218309	42618	-	434406	0
Zone Conditioning	-	216632	42618	-	433930	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	10095 CFM	15879	-	4215 CFM	-3339	-
Ventilation Load	1155 CFM	18338	29332	1155 CFM	76017	0
Supply Fan Load	10095 CFM	26589	-	4215 CFM	-4414	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	277438	71950	-	502194	0
Central Cooling Coil	-	277438	71955	-	-26921	0
Preheat Coil	-	0	-	-	28114	-
Terminal Reheat Coils	-	0	-	-	501001	-
>> Total Conditioning	-	277438	71955	-	502194	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for NE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name NE Core
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 4
 Floor Area 8840.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 26.5 Tons
 Total coil load 317.8 MBH
 Sensible coil load 270.8 MBH
 Coil CFM at Jul 1600 10068 CFM
 Max block CFM at Jul 1600 10334 CFM
 Sum of peak zone CFM 10334 CFM
 Sensible heat ratio 0.852
 ft²/Ton 333.8
 BTU/(hr-ft²) 35.9
 Water flow @ 12.0 °F rise 52.99 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.7 / 62.5 °F
 Leaving DB / WB 52.5 / 51.1 °F
 Coil ADP 49.7 °F
 Bypass Factor 0.100
 Resulting RH 44 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 4 of 4 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 26.4 MBH
 Coil CFM at Nov 0100 4134 CFM
 Max coil CFM 10334 CFM
 Water flow @ 20.0 °F drop 2.64 gpm

Load occurs at Nov 0100
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 10334 CFM
 Standard CFM 10220 CFM
 Actual max CFM/ft² 1.17 CFM/ft²

Fan motor BHP 11.34 BHP
 Fan motor kW 8.46 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 10334 CFM
 Standard CFM 10220 CFM
 Actual max CFM/ft² 1.17 CFM/ft²

Fan motor BHP 6.77 BHP
 Fan motor kW 5.05 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 716 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 19.29 CFM/person

Zone Sizing Summary for NE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:29PM

Air System Information

Air System Name NE Core
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 4
 Floor Area 8840.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	35.0	1681	672	Jul 1600	49.5	1715.0	0.98
Zone 2	51.1	2416	967	Jul 1600	72.5	2290.0	1.06
Zone 3	68.9	3302	1321	Jul 1600	92.1	2395.0	1.38
Zone 4	61.9	2935	1174	Jul 1600	81.5	2440.0	1.20

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coll Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	60.3	6.04	0.0	0.00	0
Zone 2	87.9	8.80	0.0	0.00	0
Zone 3	113.2	11.33	0.0	0.00	0
Zone 4	100.3	10.04	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-NE Corridor	1	4.6	Jul 1500	214	10.2	440.0	0.49
4-NE Wing 1	1	14.6	Jul 1400	682	19.5	630.0	1.08
4-NE Wing 2	1	16.8	Jul 1700	786	19.9	645.0	1.22
Zone 2							
3-NE Corridor	1	1.7	Jul 1500	79	5.6	305.0	0.26
3-NE Wing 1	1	16.8	Jul 1400	787	22.7	610.0	1.29
3-NE Wing 2	1	21.1	Jul 1700	988	24.3	730.0	1.35
3-NE Wing 3	1	12.0	Jul 1500	562	19.8	645.0	0.87
Zone 3							
2-NE Corridor	1	4.5	Jul 1500	209	11.8	335.0	0.62
2-NE Wing 1	1	22.9	Jul 0900	1072	27.6	645.0	1.66
2-NE Wing 2	1	28.2	Jul 1700	1321	28.6	730.0	1.81
2-NE Wing 3	1	14.9	Jul 1500	699	24.0	685.0	1.02
Zone 4							
1-NE Corridor	1	1.6	Jul 1500	76	5.8	335.0	0.23
1-NE Wing 1	1	18.9	Jul 0900	887	24.5	630.0	1.41
1-NE Wing 2	1	29.6	Jul 1700	1388	30.6	865.0	1.60
1-NE Wing 3	1	12.5	Jul 1500	585	20.6	610.0	0.96

Ventilation Sizing Summary for NE Core

12/06/2011
01:30PM

1. Summary

Ventilation Sizing Method
Design Ventilation Airflow Rate

Sum of Space OA Airflows 716 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-NE Corridor	1	440.0	0.0	213.6	0.00	0.06	0.0	0.0	26.4
4-NE Wing 1	1	630.0	3.2	681.9	5.00	0.06	0.0	0.0	53.6
4-NE Wing 2	1	645.0	3.2	785.7	5.00	0.06	0.0	0.0	54.8
Zone 2									
3-NE Corridor	1	305.0	0.0	79.3	0.00	0.06	0.0	0.0	18.3
3-NE Wing 1	1	610.0	3.1	786.6	5.00	0.06	0.0	0.0	51.9
3-NE Wing 2	1	730.0	3.7	988.4	5.00	0.06	0.0	0.0	62.1
3-NE Wing 3	1	645.0	3.2	562.1	5.00	0.06	0.0	0.0	54.8
Zone 3									
2-NE Corridor	1	335.0	0.0	209.3	0.00	0.06	0.0	0.0	20.1
2-NE Wing 1	1	645.0	3.2	1071.6	5.00	0.06	0.0	0.0	54.8
2-NE Wing 2	1	730.0	3.7	1321.5	5.00	0.06	0.0	0.0	62.1
2-NE Wing 3	1	685.0	3.4	699.3	5.00	0.06	0.0	0.0	58.2
Zone 4									
1-NE Corridor	1	335.0	0.0	75.9	0.00	0.06	0.0	0.0	20.1
1-NE Wing 1	1	630.0	3.2	886.8	5.00	0.06	0.0	0.0	53.6
1-NE Wing 2	1	865.0	4.3	1387.6	5.00	0.06	0.0	0.0	73.5
1-NE Wing 3	1	610.0	3.1	584.7	5.00	0.06	0.0	0.0	51.9
Totals (Incl. Space Multipliers)				10334.2					716.0

Air System Design Load Summary for NE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600 COOLING OA DB / WB 91.4 °F / 73.8 °F		HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F			
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2012 ft ²	84063	-	2012 ft ²	-	-
Wall Transmission	3337 ft ²	13142	-	3337 ft ²	50479	-
Roof Transmission	1715 ft ²	4305	-	1715 ft ²	4631	-
Window Transmission	2012 ft ²	26383	-	2012 ft ²	120537	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	42 ft ²	168	-	42 ft ²	769	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	8486 W	28952	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	11138 W	38000	-	0	0	-
People	37	9095	7611	0	0	0
Infiltration	-	12843	19876	-	119164	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	216952	27487	-	295579	0
Zone Conditioning	-	216098	27487	-	295204	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	10068 CFM	16217	-	4134 CFM	-3275	-
Ventilation Load	716 CFM	11343	19452	716 CFM	47140	0
Supply Fan Load	10068 CFM	27155	-	4134 CFM	-4329	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	270813	46939	-	334739	0
Central Cooling Coil	-	270813	46945	-	-26404	0
Preheat Coil	-	0	-	-	156	-
Terminal Reheat Coils	-	0	-	-	360987	-
>> Total Conditioning	-	270813	46945	-	334739	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for NW Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name NW Core
 Equipment Class CW AHU
 Air System Type VAV

Number of zones 4
 Floor Area 10690.0 ft²
 Location Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Central Cooling Coil Sizing Data

Total coil load 31.1 Tons
 Total coil load 372.7 MBH
 Sensible coil load 315.8 MBH
 Coil CFM at Jul 1600 11714 CFM
 Max block CFM at Jul 1600 12002 CFM
 Sum of peak zone CFM 12002 CFM
 Sensible heat ratio 0.847
 ft²/Ton 344.1
 BTU/(hr-ft²) 34.9
 Water flow @ 12.0 °F rise 62.16 gpm

Load occurs at Jul 1600
 OA DB / WB 91.4 / 73.8 °F
 Entering DB / WB 77.7 / 62.6 °F
 Leaving DB / WB 52.5 / 51.1 °F
 Coil ADP 49.7 °F
 Bypass Factor 0.100
 Resulting RH 45 %
 Design supply temp. 55.0 °F
 Zone T-stat Check 4 of 4 OK
 Max zone temperature deviation 0.0 °F

Preheat Coil Sizing Data

Max coil load 30.7 MBH
 Coil CFM at Nov 0000 4801 CFM
 Max coil CFM 12002 CFM
 Water flow @ 20.0 °F drop 3.07 gpm

Load occurs at Nov 0000
 Ent. DB / Lvg DB 54.0 / 60.0 °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 12002 CFM
 Standard CFM 11869 CFM
 Actual max CFM/ft² 1.12 CFM/ft²

Fan motor BHP 13.17 BHP
 Fan motor kW 9.82 kW
 Fan static 3.00 in wg

Return Fan Sizing Data

Actual max CFM at Jul 1600 12002 CFM
 Standard CFM 11869 CFM
 Actual max CFM/ft² 1.12 CFM/ft²

Fan motor BHP 7.87 BHP
 Fan motor kW 5.87 kW
 Fan static 2.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 872 CFM
 CFM/ft² 0.08 CFM/ft²

CFM/person 18.91 CFM/person

Air System Sizing Summary for NW Core

Project Name: ShipU, Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name	NW Core	Number of zones	4
Equipment Class	CW AHU	Floor Area	10690.0 ft ²
Air System Type	VAV	Location	Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM	Sum of space airflow rates	Calculation Months	Jan to Dec
Space CFM	Individual peak space loads	Sizing Data	Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	39.5	1897	759	Jul 1600	53.9	1940.0	0.98
Zone 2	56.1	2655	1062	Jul 1600	78.3	2495.0	1.06
Zone 3	74.3	3549	1420	Jul 1600	97.1	2580.0	1.38
Zone 4	82.5	3901	1560	Jul 1600	105.7	3675.0	1.06

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	66.1	6.61	0.0	0.00	0
Zone 2	95.3	9.54	0.0	0.00	0
Zone 3	119.8	11.99	0.0	0.00	0
Zone 4	130.7	13.08	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-NW Corridor	1	4.6	Jul 1500	214	10.2	440.0	0.49
4-NW Wing 1	1	19.9	Jul 1700	931	22.9	750.0	1.24
4-NW Wing 2	1	16.1	Jul 1300	752	20.9	750.0	1.00
Zone 2							
3-NW Corridor	1	2.8	Jul 1500	130	7.5	345.0	0.38
3-NW Wing 1	1	23.7	Jul 1700	1109	26.8	750.0	1.48
3-NW Wing 2	1	18.2	Jul 1400	852	24.2	750.0	1.14
3-NW Wing 3	1	12.1	Jul 1500	565	19.9	650.0	0.87
Zone 3							
2-NW Corridor	1	4.5	Jul 1500	213	12.1	350.0	0.61
2-NW Wing 1	1	31.5	Jul 1700	1473	31.1	685.0	2.15
2-NW Wing 2	1	25.3	Jul 0900	1185	30.5	900.0	1.32
2-NW Wing 3	1	14.5	Jul 1500	678	23.5	645.0	1.05
Zone 4							
1-NW Corridor	1	1.6	Jul 1500	75	5.7	335.0	0.22
1-NW Wing 1	1	26.5	Jul 1700	1239	28.3	730.0	1.70
1-NW Wing 2	1	19.7	Jul 0900	920	25.1	715.0	1.29
1-NW Wing 3	1	13.1	Jul 1500	614	21.4	665.0	0.92
1-NW Wing 4	1	22.5	Jul 1700	1053	25.2	1230.0	0.86

Ventilation Sizing Summary for NW Core

12/06/2011
01:30PM

1. Summary

Ventilation Sizing Method Design Ventilation Airflow Rate **Sum of Space OA Airflows** **872 CFM**

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-NW Corridor	1	440.0	0.0	213.6	0.00	0.06	0.0	0.0	26.4
4-NW Wing 1	1	750.0	3.8	931.2	5.00	0.06	0.0	0.0	63.8
4-NW Wing 2	1	750.0	3.8	762.3	5.00	0.06	0.0	0.0	63.8
Zone 2									
3-NW Corridor	1	345.0	0.0	129.5	0.00	0.06	0.0	0.0	20.7
3-NW Wing 1	1	750.0	3.8	1108.9	5.00	0.06	0.0	0.0	63.8
3-NW Wing 2	1	750.0	3.8	852.1	5.00	0.06	0.0	0.0	63.8
3-NW Wing 3	1	650.0	3.3	564.7	5.00	0.06	0.0	0.0	55.3
Zone 3									
2-NW Corridor	1	350.0	0.0	212.6	0.00	0.06	0.0	0.0	21.0
2-NW Wing 1	1	685.0	3.4	1472.7	5.00	0.06	0.0	0.0	58.2
2-NW Wing 2	1	900.0	4.5	1185.4	5.00	0.06	0.0	0.0	76.5
2-NW Wing 3	1	645.0	3.2	678.2	5.00	0.06	0.0	0.0	54.8
Zone 4									
1-NW Corridor	1	335.0	0.0	74.5	0.00	0.06	0.0	0.0	20.1
1-NW Wing 1	1	730.0	3.7	1239.1	5.00	0.06	0.0	0.0	62.1
1-NW Wing 2	1	715.0	3.6	920.4	5.00	0.06	0.0	0.0	60.8
1-NW Wing 3	1	665.0	3.3	613.7	5.00	0.06	0.0	0.0	56.5
1-NW Wing 4	1	1230.0	6.2	1052.8	5.00	0.06	0.0	0.0	104.6
Totals (incl. Space Multipliers)				12001.7					871.9

Air System Design Load Summary for NW Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600		HEATING DATA AT DES HTG		HEATING DATA AT DES HTG	
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2172 ft ²	95644	-	2172 ft ²	-	-
Wall Transmission	3659 ft ²	14136	-	3659 ft ²	55351	-
Roof Transmission	1940 ft ²	4858	-	1940 ft ²	5239	-
Window Transmission	2172 ft ²	28480	-	2172 ft ²	130120	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	21 ft ²	84	-	21 ft ²	384	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	10323 W	35217	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	13830 W	47187	-	0	0	-
People	46	11294	9451	0	0	0
Infiltration	-	15517	23906	-	143973	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	252417	33357	-	335067	0
Zone Conditioning	-	251413	33357	-	334649	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	11714 CFM	18913	-	4801 CFM	-3803	-
Ventilation Load	872 CFM	13808	23579	872 CFM	57402	0
Supply Fan Load	11714 CFM	31669	-	4801 CFM	-5028	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	315804	56936	-	383220	0
Central Cooling Coil	-	315804	56946	-	-30664	0
Preheat Coil	-	0	-	-	2837	-
Terminal Reheat Coils	-	0	-	-	411047	-
>> Total Conditioning	-	315804	56946	-	383220	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for SE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name **SE Core**
 Equipment Class **CW AHU**
 Air System Type **VAV**

Number of zones **4**
 Floor Area **12060.0 ft²**
 Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
 Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **35.2** Tons
 Total coil load **422.2** MBH
 Sensible coil load **358.4** MBH
 Coil CFM at Aug 1500 **13389** CFM
 Max block CFM at Aug 1500 **14243** CFM
 Sum of peak zone CFM **14243** CFM
 Sensible heat ratio **0.849**
 ft²/Ton **342.8**
 BTU/(hr-ft²) **35.0**
 Water flow @ 12.0 °F rise **70.40** gpm

Load occurs at **Aug 1500**
 OA DB / WB **92.0 / 74.0** °F
 Entering DB / WB **77.7 / 62.6** °F
 Leaving DB / WB **52.6 / 51.3** °F
 Coil ADP **49.8** °F
 Bypass Factor **0.100**
 Resulting RH **45** %
 Design supply temp. **55.0** °F
 Zone T-stat Check **4 of 4** OK
 Max zone temperature deviation **0.0** °F

Preheat Coil Sizing Data

Max coil load **36.4** MBH
 Coil CFM at Jan 1300 **5697** CFM
 Max coil CFM **14243** CFM
 Water flow @ 20.0 °F drop **3.64** gpm

Load occurs at **Jan 1300**
 Ent. DB / Lvg DB **54.0 / 60.0** °F

Supply Fan Sizing Data

Actual max CFM at Aug 1500 **14243** CFM
 Standard CFM **14085** CFM
 Actual max CFM/ft² **1.18** CFM/ft²

Fan motor BHP **15.63** BHP
 Fan motor kW **11.66** kW
 Fan static **3.00** in wg

Return Fan Sizing Data

Actual max CFM at Aug 1500 **14243** CFM
 Standard CFM **14085** CFM
 Actual max CFM/ft² **1.18** CFM/ft²

Fan motor BHP **9.34** BHP
 Fan motor kW **6.96** kW
 Fan static **2.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **985** CFM
 CFM/ft² **0.08** CFM/ft²

CFM/person **18.83** CFM/person

Air System Sizing Summary for SE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name	SE Core	Number of zones	4
Equipment Class	CW AHU	Floor Area	12060.0 ft ²
Air System Type	VAV	Location	Harrisburg, Pennsylvania

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM Sum of space airflow rates
 Space CFM Individual peak space loads

Calculation Months Jan to Dec
 Sizing Data Calculated

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	68.0	3342	1337	Aug 1500	86.7	3130.0	1.07
Zone 2	66.3	3262	1305	Aug 1500	88.5	3065.0	1.06
Zone 3	78.8	3903	1561	Aug 1500	102.4	2980.0	1.31
Zone 4	75.2	3736	1494	Aug 1500	95.8	2885.0	1.29

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Coll Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	108.1	10.81	0.0	0.00	0
Zone 2	109.4	10.94	0.0	0.00	0
Zone 3	127.4	12.75	0.0	0.00	0
Zone 4	119.8	11.98	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-SE Corridor	1	6.4	Sep 1400	300	10.2	440.0	0.68
4-SE Wing 1	1	22.2	Jul 1400	1039	28.3	920.0	1.13
4-SE Wing 2	1	17.8	Jul 1700	834	20.5	665.0	1.25
4-SE Wing 3	1	25.0	Sep 1400	1169	27.6	1105.0	1.06
Zone 2							
3-SE Corridor	1	2.3	Aug 1500	109	6.5	375.0	0.29
3-SE Wing 1	1	23.1	Jul 1400	1082	30.5	920.0	1.18
3-SE Wing 2	1	21.6	Aug 1600	1012	25.8	920.0	1.10
3-SE Wing 3	1	22.6	Sep 1400	1059	25.7	850.0	1.25
Zone 3							
2-SE Corridor	1	4.1	Sep 1400	194	10.9	430.0	0.45
2-SE Wing 1	1	29.2	Jul 0900	1367	35.3	900.0	1.52
2-SE Wing 2	1	26.3	Aug 1600	1231	27.9	800.0	1.54
2-SE Wing 3	1	23.7	Sep 1400	1111	28.3	850.0	1.31
Zone 4							
1-SE Corridor	1	7.3	Sep 1300	343	9.2	350.0	0.98
1-SE Wing 1	1	24.5	Jul 1400	1146	31.3	850.0	1.35
1-SE Wing 2	1	26.7	Jul 1700	1250	28.2	850.0	1.47
1-SE Wing 3	1	21.3	Sep 1400	997	27.1	835.0	1.19

Ventilation Sizing Summary for SE Core

Project Name: ShipU, Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:30PM

1. Summary

Ventilation Sizing Method Design Ventilation Airflow Rate Sum of Space OA Airflows 985 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-SE Corridor	1	440.0	0.0	299.8	0.00	0.06	0.0	0.0	26.4
4-SE Wing 1	1	920.0	4.6	1038.8	5.00	0.06	0.0	0.0	78.2
4-SE Wing 2	1	665.0	3.3	834.4	5.00	0.06	0.0	0.0	56.5
4-SE Wing 3	1	1105.0	5.5	1169.0	5.00	0.06	0.0	0.0	93.9
Zone 2									
3-SE Corridor	1	375.0	0.0	109.4	0.00	0.06	0.0	0.0	22.5
3-SE Wing 1	1	920.0	4.6	1081.8	5.00	0.06	0.0	0.0	78.2
3-SE Wing 2	1	920.0	4.6	1011.6	5.00	0.06	0.0	0.0	78.2
3-SE Wing 3	1	850.0	4.3	1059.3	5.00	0.06	0.0	0.0	72.3
Zone 3									
2-SE Corridor	1	430.0	0.0	194.2	0.00	0.06	0.0	0.0	25.8
2-SE Wing 1	1	900.0	4.5	1367.3	5.00	0.06	0.0	0.0	76.5
2-SE Wing 2	1	800.0	4.0	1230.5	5.00	0.06	0.0	0.0	68.0
2-SE Wing 3	1	850.0	4.3	1111.2	5.00	0.06	0.0	0.0	72.3
Zone 4									
1-SE Corridor	1	350.0	0.0	342.6	0.00	0.06	0.0	0.0	21.0
1-SE Wing 1	1	850.0	4.3	1146.3	5.00	0.06	0.0	0.0	72.3
1-SE Wing 2	1	850.0	4.3	1249.8	5.00	0.06	0.0	0.0	72.3
1-SE Wing 3	1	835.0	4.2	997.3	5.00	0.06	0.0	0.0	71.0
Totals (incl. Space Multipliers)				14243.3					985.2

Air System Design Load Summary for SE Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Aug 1500 COOLING OA DB / WB 92.0 °F / 74.0 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2224 ft ²	104686	-	2224 ft ²	-	-
Wall Transmission	4597 ft ²	21372	-	4597 ft ²	69549	-
Roof Transmission	3130 ft ²	8325	-	3130 ft ²	8452	-
Window Transmission	2224 ft ²	29623	-	2224 ft ²	133199	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	63 ft ²	256	-	63 ft ²	1153	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	11661 W	39784	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	15698 W	53559	-	0	0	-
People	52	12819	10727	0	0	0
Infiltration	-	17951	26602	-	161031	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	288375	37329	-	373384	0
Zone Conditioning	-	287291	37329	-	372919	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	13389 CFM	20481	-	5697 CFM	-4514	-
Ventilation Load	985 CFM	16287	26509	985 CFM	64863	0
Supply Fan Load	13389 CFM	34294	-	5697 CFM	-5967	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	358352	63837	-	427301	0
Central Cooling Coil	-	358353	63848	-	-36392	0
Preheat Coil	-	0	-	-	107	-
Terminal Reheat Coils	-	0	-	-	463586	-
>> Total Conditioning	-	358353	63848	-	427301	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for Staff Office Bldg.

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

Air System Information

Air System Name **Staff Office Bldg.**
 Equipment Class **CW AHU**
 Air System Type **SZCAV**

Number of zones **1**
 Floor Area **2045.0 ft²**
 Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
 Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **5.9 Tons**
 Total coil load **70.8 MBH**
 Sensible coil load **60.6 MBH**
 Coil CFM at Jul 1500 **2594 CFM**
 Max block CFM **2594 CFM**
 Sum of peak zone CFM **2594 CFM**
 Sensible heat ratio **0.856**
 ft²/Ton **346.7**
 BTU/(hr-ft²) **34.6**
 Water flow @ 12.0 °F rise **11.80 gpm**

Load occurs at **Jul 1500**
 OA DB / WB **92.0 / 74.0 °F**
 Entering DB / WB **76.1 / 62.7 °F**
 Leaving DB / WB **54.2 / 53.0 °F**
 Coil ADP **51.8 °F**
 Bypass Factor **0.100**
 Resulting RH **47 %**
 Design supply temp. **55.0 °F**
 Zone T-stat Check **1 of 1 OK**
 Max zone temperature deviation **0.0 °F**

Central Heating Coil Sizing Data

Max coil load **77.0 MBH**
 Coil CFM at Des Htg **2594 CFM**
 Max coil CFM **2594 CFM**
 Water flow @ 20.0 °F drop **7.71 gpm**

Load occurs at **Des Htg**
 BTU/(hr-ft²) **37.7**
 Ent. DB / Lvg DB **65.8 / 93.6 °F**

Supply Fan Sizing Data

Actual max CFM **2594 CFM**
 Standard CFM **2566 CFM**
 Actual max CFM/ft² **1.27 CFM/ft²**

Fan motor BHP **1.51 BHP**
 Fan motor kW **1.13 kW**
 Fan static **2.00 in wg**

Outdoor Ventilation Air Data

Design airflow CFM **174 CFM**
 CFM/ft² **0.09 CFM/ft²**

CFM/person **17.00 CFM/person**

Air System Sizing Summary for Staff Office Bldg.

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

Air System Information

Air System Name **Staff Office Bldg.**
 Equipment Class **CW AHU**
 Air System Type **SZCAV**

Number of zones **1**
 Floor Area **2045.0 ft²**
 Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
 Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	53.1	2594	2594	Jul 1500	69.3	2045.0	1.27

Zone Terminal Sizing Data

No Zone Terminal Sizing Data required for this system.

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
Inst. Research Bldg.	1	53.1	Jul 1500	2594	69.3	2045.0	1.27

Ventilation Sizing Summary for Staff Office Bldg.

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:30PM

1. Summary

Ventilation Sizing Method Sum of Space OA Airflows 174 CFM
Design Ventilation Airflow Rate 174 CFM

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
Inst. Research Bldg.	1	2045.0	10.2	2594.4	5.00	0.06	0.0	0.0	173.8
Totals (incl. Space Multipliers)				2594.4					173.8

Air System Design Load Summary for Staff Office Bldg.

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1500		HEATING DATA AT DES HTG		HEATING DATA AT DES HTG	
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	350 ft ²	14456	-	350 ft ²	-	-
Wall Transmission	1076 ft ²	4709	-	1076 ft ²	16277	-
Roof Transmission	2040 ft ²	6223	-	2040 ft ²	5509	-
Window Transmission	350 ft ²	4663	-	350 ft ²	20968	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	84 ft ²	342	-	84 ft ²	1537	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	2045 W	6977	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	3068 W	10466	-	0	0	-
People	10	2505	2096	0	0	0
Infiltration	-	2785	3795	-	24981	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	53125	5891	-	69272	0
Zone Conditioning	-	53584	5891	-	69553	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	2594 CFM	0	-	2594 CFM	0	-
Ventilation Load	174 CFM	3164	4300	174 CFM	11306	0
Supply Fan Load	2594 CFM	3846	-	2594 CFM	-3846	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	60595	10191	-	77012	0
Central Cooling Coil	-	60595	10196	-	0	0
Central Heating Coil	-	0	-	-	77012	-
>> Total Conditioning	-	60595	10196	-	77012	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for SW Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name **SW Core**
 Equipment Class **CW AHU**
 Air System Type **VAV**

Number of zones **4**
 Floor Area **10710.0 ft²**
 Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
 Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **31.2** Tons
 Total coil load **374.3** MBH
 Sensible coil load **317.7** MBH
 Coil CFM at Aug 1500 **11864** CFM
 Max block CFM at Aug 1500 **12603** CFM
 Sum of peak zone CFM **12621** CFM
 Sensible heat ratio **0.849**
 ft²/Ton **343.3**
 BTU/(hr-ft²) **35.0**
 Water flow @ 12.0 °F rise **62.42** gpm

Load occurs at **Aug 1500**
 OA DB / WB **92.0 / 74.0** °F
 Entering DB / WB **77.7 / 62.6** °F
 Leaving DB / WB **52.6 / 51.2** °F
 Coil ADP **49.8** °F
 Bypass Factor **0.100**
 Resulting RH **45** %
 Design supply temp. **55.0** °F
 Zone T-stat Check **4 of 4** OK
 Max zone temperature deviation **0.0** °F

Preheat Coil Sizing Data

Max coil load **32.3** MBH
 Coil CFM at Feb 1300 **5048** CFM
 Max coil CFM **12603** CFM
 Water flow @ 20.0 °F drop **3.23** gpm

Load occurs at **Feb 1300**
 Ent. DB / Lvg DB **54.0 / 60.0** °F

Supply Fan Sizing Data

Actual max CFM at Aug 1500 **12603** CFM
 Standard CFM **12463** CFM
 Actual max CFM/ft² **1.18** CFM/ft²

Fan motor BHP **13.83** BHP
 Fan motor kW **10.32** kW
 Fan static **3.00** in wg

Return Fan Sizing Data

Actual max CFM at Aug 1500 **12603** CFM
 Standard CFM **12463** CFM
 Actual max CFM/ft² **1.18** CFM/ft²

Fan motor BHP **8.26** BHP
 Fan motor kW **6.16** kW
 Fan static **2.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **875** CFM
 CFM/ft² **0.08** CFM/ft²

CFM/person **18.85** CFM/person

Zone Sizing Summary for SW Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

Air System Information

Air System Name **SW Core**
 Equipment Class **CW AHU**
 Air System Type **VAV**

Number of zones **4**
 Floor Area **10710.0 ft²**
 Location **Harrisburg, Pennsylvania**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
 Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (MBH)	Design Air Flow (CFM)	Minimum Air Flow (CFM)	Time of Peak Load	Maximum Heating Load (MBH)	Zone Floor Area (ft ²)	Zone CFM/ft ²
Zone 1	62.5	3082	1233	Aug 1600	77.4	2795.0	1.10
Zone 2	58.6	2884	1153	Aug 1500	78.2	2655.0	1.09
Zone 3	73.3	3658	1463	Sep 1500	92.7	2620.0	1.40
Zone 4	61.6	2998	1199	Aug 1500	81.3	2640.0	1.14

Zone Terminal Sizing Data

Zone Name	Reheat Coil Load (MBH)	Reheat Water gpm @ 20.0 °F	Zone Htg Coil Load (MBH)	Zone Htg Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	97.2	9.72	0.0	0.00	0
Zone 2	96.7	9.68	0.0	0.00	0
Zone 3	116.2	11.62	0.0	0.00	0
Zone 4	100.6	10.06	0.0	0.00	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
4-SW Corridor	1	6.4	Sep 1400	300	10.2	440.0	0.68
4-SW Wing 1	1	16.8	Jul 1700	788	19.5	595.0	1.32
4-SW Wing 2	1	18.3	Jul 1700	854	21.0	695.0	1.23
4-SW Wing 3	1	24.3	Sep 1400	1140	26.8	1065.0	1.07
Zone 2							
3-SW Corridor	1	2.2	Aug 1500	104	6.1	345.0	0.30
3-SW Wing 1	1	18.0	Jul 1700	843	21.4	595.0	1.42
3-SW Wing 2	1	15.8	Jul 1400	741	21.4	595.0	1.25
3-SW Wing 3	1	25.5	Sep 1400	1196	29.3	1120.0	1.07
Zone 3							
2-SW Corridor	1	3.8	Sep 1400	176	9.1	335.0	0.53
2-SW Wing 1	1	27.1	Jul 1700	1268	26.7	575.0	2.20
2-SW Wing 2	1	20.8	Aug 1400	975	26.7	845.0	1.15
2-SW Wing 3	1	26.5	Sep 1400	1239	30.3	865.0	1.43
Zone 4							
1-SW Corridor	1	2.7	Sep 1400	126	6.0	310.0	0.41
1-SW Wing 1	1	23.0	Jul 1700	1076	24.5	630.0	1.71
1-SW Wing 2	1	18.6	Aug 1400	871	24.8	850.0	1.03
1-SW Wing 3	1	19.7	Sep 1400	924	25.9	850.0	1.09

Ventilation Sizing Summary for SW Core

Project Name: ShipU. Old Main HVAC Study
Prepared by: Century Engineering

12/06/2011
01:30PM

1. Summary		Sum of Space OA Airflows		875 CFM
Ventilation Sizing Method	Design Ventilation Airflow Rate			

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (ft ²)	Maximum Occupants	Maximum Supply Air (CFM)	Required Outdoor Air (CFM/person)	Required Outdoor Air (CFM/ft ²)	Required Outdoor Air (CFM)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (CFM)
Zone 1									
4-SW Corridor	1	440.0	0.0	299.8	0.00	0.06	0.0	0.0	26.4
4-SW Wing 1	1	595.0	3.0	787.8	5.00	0.06	0.0	0.0	50.6
4-SW Wing 2	1	695.0	3.5	854.4	5.00	0.06	0.0	0.0	59.1
4-SW Wing 3	1	1065.0	5.3	1139.8	5.00	0.06	0.0	0.0	90.5
Zone 2									
3-SW Corridor	1	345.0	0.0	103.8	0.00	0.06	0.0	0.0	20.7
3-SW Wing 1	1	595.0	3.0	842.7	5.00	0.06	0.0	0.0	50.6
3-SW Wing 2	1	595.0	3.0	741.3	5.00	0.06	0.0	0.0	50.6
3-SW Wing 3	1	1120.0	5.6	1195.9	5.00	0.06	0.0	0.0	95.2
Zone 3									
2-SW Corridor	1	335.0	0.0	176.4	0.00	0.06	0.0	0.0	20.1
2-SW Wing 1	1	575.0	2.9	1267.8	5.00	0.06	0.0	0.0	48.9
2-SW Wing 2	1	845.0	4.2	974.9	5.00	0.06	0.0	0.0	71.8
2-SW Wing 3	1	865.0	4.3	1238.7	5.00	0.06	0.0	0.0	73.5
Zone 4									
1-SW Corridor	1	310.0	0.0	126.2	0.00	0.06	0.0	0.0	18.6
1-SW Wing 1	1	630.0	3.2	1076.3	5.00	0.06	0.0	0.0	53.6
1-SW Wing 2	1	850.0	4.3	871.5	5.00	0.06	0.0	0.0	72.3
1-SW Wing 3	1	850.0	4.3	923.9	5.00	0.06	0.0	0.0	72.3
Totals (incl. Space Multipliers)				12621.1					874.6

Air System Design Load Summary for SW Core

Project Name: ShipU. Old Main HVAC Study
 Prepared by: Century Engineering

12/06/2011
 01:30PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Aug 1500 COOLING OA DB / WB 92.0 °F / 74.0 °F			HEATING DATA AT DES HTG HEATING OA DB / WB 9.0 °F / 6.7 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	1901 ft ²	92904	-	1901 ft ²	-	-
Wall Transmission	4255 ft ²	18905	-	4255 ft ²	64373	-
Roof Transmission	2795 ft ²	8097	-	2795 ft ²	7547	-
Window Transmission	1901 ft ²	25322	-	1901 ft ²	113859	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	63 ft ²	256	-	63 ft ²	1153	-
Floor Transmission	0 ft ²	0	-	0 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	10353 W	35319	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	13920 W	47494	-	0	0	-
People	46	11367	9512	0	0	0
Infiltration	-	15917	23592	-	142782	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	255581	33104	-	329714	0
Zone Conditioning	-	254565	33104	-	329304	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	11864 CFM	18187	-	5048 CFM	-4001	-
Ventilation Load	875 CFM	14455	23536	875 CFM	57580	0
Supply Fan Load	11864 CFM	30452	-	5048 CFM	-5292	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	317659	56640	-	377591	0
Central Cooling Coil	-	317659	56656	-	-32251	0
Preheat Coil	-	0	-	-	198	-
Terminal Reheat Coils	-	0	-	-	409645	-
>> Total Conditioning	-	317659	56656	-	377591	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Appendix C

Sample Equipment Submittals

Appendix C-1

McQuay



Submittal Package

Prepared For:

Date: 10/28/2011

Prepared By:

{Insert Your Text here...}

Sold To:

Customer P.O. Number:

Notes

Table of Contents

TECHNICAL DATA SHEET FOR AHU-40 TON	3
FAN CURVE FOR AHU-40 TON	8
DRAWING FOR AHU-40 TON	10
TECHNICAL DATA SHEET FOR AHU-80 TON	13
FAN CURVE FOR AHU-80 TON	18
DRAWING FOR AHU-80 TON	20
TECHNICAL DATA SHEET FOR 100% OA ERU	23
FAN CURVE FOR 100% OA ERU	28
DRAWING FOR 100% OA ERU	30
TECHNICAL DATA SHEET FOR FAN COIL	33
UNIT DESCRIPTION:.....	33
UNIT DIMENSIONS & WEIGHTS:.....	33
ELECTRIC DATA:	33
FILTERS:.....	33
HOT WATER PREHEAT COIL:	33
CHILLED WATER COOLING COIL:	33
FAN COIL	33
SUPPLY FAN:	34
UNIT DATA:.....	35
VALVE PACKAGE CONFIGURATION:.....	35
FAN CO : VP : VP 001	35
UNIT DATA:.....	36
VALVE PACKAGE CONFIGURATION:.....	36
FAN CO : VS : VP 001	36
FANCOIL_DRAWING FOR FAN COIL.....	37
FANCOIL_DRAWING FOR FAN COIL.....	38
FANCOIL_DRAWING FOR FAN COIL.....	39
DOCUMENT SUMMARY PAGE	ERROR! BOOKMARK NOT DEFINED.

Technical Data Sheet for AHU-40 Ton

QUOTE ID	KY8MGV(XX.000)	REP. OFFICE	TriState HVAC-York
JOB NAME	Shippensburg Old Main	SALESPERSON	SW
MODEL NUMBER	CAH030GDAC	ENGINEER	
UNIT TAGGING	AHU-40 Ton	VERSION	9.43

Unit configuration	Inline horizontal	SUPPLY	RETURN / EXHAUST
Drive (handing) location	Right		
Air volume	13000	14000	s cfm
Altitude	0	0	ft
Turning loss	0.00	0.00	in WC.
External static	1.50	1.00	in WC.
Total static	3.00	1.08	in WC.
External H x W	60 x 98	60 x 98 (Not including base rails)	ins

CASING DETAILS	
Outer panel	Standard G90 galv steel (unpainted)
Liner	Galvanized steel (Unless noted per section)
Insulation	R-13 Injected Foam (Unless noted per section)
Frame	2 ins
Base	6" formed channel
Sound baffles	None (Unless noted per section)
Tread Plate floor liner	None (unless noted per section)
Shrink wrapping	No

1 RETURN/EXHAUST FAN SECTION(56 ins)			SECTION	1
Air volume	14000	cfm	Motor power	10.0
External static pressure	1.00	ins WC	Motor type	ODP
Total static pressure	1.08	ins WC	Frame size	215 T frame
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3
Type	Centrifugal DWDI		Motor efficiency	Premium
Blade type/Class	Forward Curved / 2		Motor speed	1750 rpm
Quantity of Fans	1		Block-off Plate	No
Fan wheel diameter	22.25	ins	Motor pole	4
Brake horsepower	8.47	HP	Full load current	12.8
Operating/Max speed	580 / 1030	rpm	Lock rotor current	106 A
Orientation	Top horizontal		Motor supplier	Generic
Air modulation	None		Actual drive service fac.	1.42
Drip pan	None		Bearing type	Standard - L50 (200K)
Drip pan side	-		Outlet velocity	2222 ft/m
Wheel guard	None		Inlet screen	None
Belt guard	None		Outlet screen	None
Inspection port	None		Motor location	To Side of Fan
Material type	N/A		Number of blades	N/A

DRIVES *			
Fan sheave	2B5V136	Motor sheave	2BK50H
Number of belts	2	Belt	BX70

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS			
Type	Spring		
Seismic restraint	None		

DOOR DATA			
Door location	Drive side	Window size	None
Door width	16	ins	None

1 RETURN/EXHAUST FAN SECTION(56 ins)

 SECTION **1**

Door opening Outward

VFD / STARTER / DISCONNECT DATA

Selection type	VFD - NEMA 1	Vendor	ABB	
Auxiliary Control	Combination Disconnect and Bypass	Voltage	460	
Disconnect Type	Fused			
Mounting	Door Side	H x W x D	19.09 x 7.42 x 9.89	ins
Enclosure	NEMA 1	Coil Voltage	N/A	
Line Reactor	None	Hand Off Auto Switch	None	
120V Ctrl Transformer	Provided			
VFD Quantity	1			

2 ECONOMIZER(64 ins)

 SECTION **1 & 2**

Drip pan	None	Drip side
Floor grating	No	

	OUTSIDE AIR	RETURN AIR	EXHAUST AIR	
Length x Width	28.00 x 94.00	28.00 x 94.00	28.00 x 94.00	ins
Location	Top	Internal	Top	
Dampers	UltraSeal Low Leak	UltraSeal Low Leak	UltraSeal Low Leak	
Actuation	-	-	-	
Hoods				
Rated cfm	13000	14000	14000	cfm
Air pressure drop	0.07	0.08	0.08	in WC
Quantity	1	1	1	

DOOR DATA

Door location	Drive side	Window size	None
Door width	28	ins	None
Door opening	Outward	Light	

3 PANEL FILTER(12 ins)

 SECTION **2**

Type	Pleated	Clean air press. drop	0.30	ins WC
Efficiency	MERV 8	Mean air press. drop	0.65	ins WC
Face velocity	397	fpm	Dirty air press. drop	1.00
Face area	32.7	ft ²	Access	Side
Air volume	13000	cfm		

BANK ARRANGEMENT

No. of Filters	Size H x W x D	Ins
8.0	20 x 24 x 2	
4.0	12 x 24 x 2	

DOOR DATA

Door location	Drive side	Window size	None
Door width	8	ins	None
Door opening	Outward	Light	

SPECIAL

Intercept Antimicrobial treatment

Tread Plate floor liner	None		
Liner	(As casing details)		
Insulation	(As casing details)		
Sound baffles	None		
Special static pressure		ins WC	Filter Gauge
			None

4 HOT WATER COIL(24 ins)				SECTION	2
Coil model	5WH0902B		Number of coils	2	
Capacity	743531	Btu/h	Number of rows	2	
			Fins per inch	9	
Air volume	13000	cfm			
Entering db	40.0	F	Entering water	160.0	F
Leaving db	92.3	F	Leaving water	139.1	F
Finned height x length	24 x 82	ins	Water flow rate	71.10	gpm
Face area	27.33	ft ²	Water pressure drop	6.80	ftHD
Face velocity	476	ft/m	Water velocity	4.70	ft/s
Coil air pressure drop	0.16	ins WC	Fluid volume	9.0	gal
			Fluid weight	76.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 2.50	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galvanized track	
Glycol type (%)	- (0 %)		Drip pan	None	
Fouling Factor	0		Drip pan side	-	
			Turbospirals	No	
Coil code	5WH0902B		Electro-fin coat	None	

DOOR DATA				
Door location	Drive side		Window size	None
Door width	14	ins	Light	None
Door opening	Outward			

5 CHILLED WATER COIL(28 ins)				SECTION	2
Coil model	5WL1205B		Number of coils	2	
Total capacity	530433	Btu/h	Number of rows	5	
Sensible capacity	365565	Btu/h	Fins per inch	12	
Air volume	13000	cfm			
Entering db/wb	80.0 / 67.0	F	Entering water	45.0	F
Leaving db/wb	54.3 / 53.7	F	Leaving water	55.2	F
Finned height x length	24 x 85	ins	Water flow rate	104.10	gpm
Face area	28.33	ft ²	Water pressure drop	12.90	ftHD
Face velocity	459	ft/m	Water velocity	4.70	ft/s
Coil air pressure drop	0.61	ins WC	Fluid volume	19.0	gal
			Fluid weight	162.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 2.00	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galv. steel	
Glycol type (%)	- (0 %)		Drain pan	Stainless steel	
Fouling Factor	0		Drain pan side	Drive side	
			Turbospirals	No	
Coil code	5WL1205B		Electro-fin coat	None	

6 SUPPLY FAN SECTION(58 ins)				SECTION	3
Air volume	13000	cfm	Motor power	15.0	HP
External static pressure	1.50	ins WC	Motor type	ODP	
Total static pressure	3.00	ins WC	Frame size	254 T frame	
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3	
Type	Centrifugal DWDI		Motor efficiency	Premium	
Blade type/Class	Airfoil / 2		Motor speed	1750	rpm
Quantity of Fans	1		Block-off Plate	No	
Fan wheel diameter	24.00	ins	Motor pole	4	
Brake horsepower	9.28	HP	Full load current	18.9	A
Operating/Max speed	1554 / 2255	rpm	Lock rotor current	118	A
Orientation	Top horizontal		Motor supplier	Generic	
Air modulation	None		Actual drive service fac.	1.34	
Drip pan	None		Bearing type	Standard - L50 (200K)	
Drip pan side	-		Outlet velocity	1847	ft/m
Wheel guard	None		Inlet screen	None	
Belt guard	None		Outlet screen	None	
Inspection port	None		Motor location	To Side of Fan	
Material type	N/A		Number of blades	N/A	

DRIVES *

Fan sheave	2B5V54	Motor sheave	2B5V48
Number of belts	2	Belt	5VX560

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS

Type	Spring
Seismic restraint	None

DOOR DATA

Door location	Drive side	Window size	None
Door width	18	ins	Light
Door opening	Outward		

VFD / STARTER / DISCONNECT DATA

Selection type	VFD - NEMA 1	Vendor	ABB
Auxiliary Control	Combination Disconnect and Bypass	Voltage	460
Disconnect Type	Fused		
Mounting	Door Side	H x W x D	19.09 x 7.42 x 9.89
Enclosure	NEMA 1	Coil Voltage	ins
Line Reactor	None	Hand Off Auto Switch	N/A
120V Ctrl Transformer	Provided		None
VFD Quantity	1		

NOTES

Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ARI Standard 430.

As a standalone component, unit meets or exceeds requirements of ASHRAE 90.1 - 2007. The approving authority is responsible for compliance of multi-component building systems.


SHIPPING SECTION DETAILS

	Length (inches)	Weight (lb)	
Section 1	88	1746	
Section 2	96	2502	
Section 3	58	1703	
TOTALS	242.00 (Lower level total)	5951 (Entire unit weight)	

UNIT SOUND	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
Radiated	88	88	83	75	69	61	44	36
Unit discharge	90	92	93	88	85	79	75	67
Unit return	95	94	92	90	88	83	78	71


Fan Curve for AHU-40 Ton

MCQUAY INTERNATIONAL FAN SELECTION



22.25" Forward Curved Ret/Exh Fan at Standard Conditions			
Air volume	14000 cfm	Fan speed	580 rpm
Total static	1.08 inswg	Max speed	1030 rpm
Brake horsepower	8.5 bhp	Efficiency	28.0 %
Unit tagging	AHU-40 Ton	Date	October-28-2011
Job name	Shippensburg Old Main	Time	13:54

MCQUAY INTERNATIONAL FAN SELECTION




24.00" Airfoil Supply Fan at Standard Conditions			
Air volume	13000 cfm	Fan speed	1554 rpm
Total static	3.00 inwg	Max speed	2255 rpm
Brake horsepower	9.3 bhp	Efficiency	66.0 %
Unit tagging	AHL-40 Ton	Date	October-28-2011
Job name	Shippensburg Old Main	Time	13:54
Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ARI Standard 430.			



Drawing for AHU-40 Ton


Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	94.00	56.00
B Damper	58.00	2.00	66.00	94.00	28.00
C Damper	90.00	2.00	66.00	94.00	28.00
D Hot water outlet	136.57	-7.00	34.05	2.50ins. MPS	-
E Hot water inlet	136.57	-7.00	13.40	2.50ins. MPS	-
F Hot water outlet	136.57	-7.00	59.45	2.50ins. MPS	-
G Hot water inlet	136.57	-7.00	38.80	2.50ins. MPS	-
H Cold water outlet	160.60	-7.00	34.94	2.00ins. MPS	-
I Cold water inlet	165.85	-7.00	13.06	2.00ins. MPS	-
J Cold water outlet	160.60	-7.00	60.94	2.00ins. MPS	-
K Cold water inlet	165.85	-7.00	39.06	2.00ins. MPS	-
L Condensate drain conn.	170.00	-2.90	9.00	1.25ins. MPS	-
M Fan discharge	243.00	31.03	23.61	35.95	29.51

Dimensions measured from \oplus




NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: General Arrangement No Ends
 DRAWN: October-28-2011 (13:53)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: AHU-40 Ton
 MODEL: CAH030GDAC




Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	94.00	56.00
B Damper	58.00	2.00	66.00	94.00	28.00
C Damper	90.00	2.00	66.00	94.00	28.00
D Hot water outlet	136.57	-7.00	34.05	2.50ins. MPS	-
E Hot water inlet	136.57	-7.00	13.40	2.50ins. MPS	-
F Hot water outlet	136.57	-7.00	59.45	2.50ins. MPS	-
G Hot water inlet	136.57	-7.00	38.80	2.50ins. MPS	-
H Cold water outlet	160.60	-7.00	34.94	2.00ins. MPS	-
I Cold water inlet	165.85	-7.00	13.06	2.00ins. MPS	-
J Cold water outlet	160.60	-7.00	60.94	2.00ins. MPS	-
K Cold water inlet	165.85	-7.00	39.06	2.00ins. MPS	-
L Condensate drain conn.	170.00	-2.90	9.00	1.25ins. MPS	-
M Fan discharge	243.00	31.03	23.61	35.95	29.51

Dimensions measured from \oplus




NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: Right Side
 DRAWN: October-28-2011 (13:53)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: AHU-40 Ton
 MODEL: CAH030GDAC




Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	94.00	56.00
B Damper	58.00	2.00	66.00	94.00	28.00
C Damper	90.00	2.00	66.00	94.00	28.00
D Hot water outlet	136.57	-7.00	34.05	2.50ins. MPS	-
E Hot water inlet	136.57	-7.00	13.40	2.50ins. MPS	-
F Hot water outlet	136.57	-7.00	59.45	2.50ins. MPS	-
G Hot water inlet	136.57	-7.00	38.80	2.50ins. MPS	-
H Cold water outlet	160.60	-7.00	34.94	2.00ins. MPS	-
I Cold water inlet	165.85	-7.00	13.06	2.00ins. MPS	-
J Cold water outlet	160.60	-7.00	60.94	2.00ins. MPS	-
K Cold water inlet	165.85	-7.00	39.06	2.00ins. MPS	-
L Condensate drain conn.	170.00	-2.90	9.00	1.25ins. MPS	-
M Fan discharge	243.00	31.03	23.61	35.95	29.51

Dimensions measured from \oplus



NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: Top
 DRAWN: October-28-2011 (13:53)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: AHU-40 Ton
 MODEL: CAH030GDAC



Technical Data Sheet for AHU-80 ton

QUOTE ID	KY8MGV(XX.001)	REP. OFFICE	TriState HVAC-York
JOB NAME	Shippensburg Old Main	SALESPERSON	SW
MODEL NUMBER	CAH065GDAC	ENGINEER	
UNIT TAGGING	AHU-80 ton	VERSION	9.43

Unit configuration	Inline horizontal	SUPPLY	RETURN / EXHAUST
Drive (handing) location	Right		
Air volume	26000	28000	s cfm
Altitude	0	0	ft
Turning loss	0.00	0.00	in WC.
External static	1.50	1.00	in WC.
Total static	2.78	1.06	in WC.
External H x W	92 x 136	92 x 136 (Not including base rails)	ins

CASING DETAILS	
Outer panel	Standard G90 galv steel (unpainted)
Liner	Galvanized steel (Unless noted per section)
Insulation	R-13 Injected Foam (Unless noted per section)
Frame	2 ins
Base	6" formed channel
Sound baffles	None (Unless noted per section)
Tread Plate floor liner	None (unless noted per section)
Shrink wrapping	No

1 RETURN/EXHAUST FAN SECTION(82 ins)				SECTION	1
Air volume	28000	cfm	Motor power	15.0	HP
External static pressure	1.00	ins WC	Motor type	ODP	
Total static pressure	1.06	ins WC	Frame size	254 T frame	
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3	
Type	Centrifugal DWDI		Motor efficiency	Premium	
Blade type/Class	Forward Curved / 2		Motor speed	1750	rpm
Quantity of Fans	1		Block-off Plate	No	
Fan wheel diameter	33.00	ins	Motor pole	4	
Brake horsepower	11.15	HP	Full load current	18.9	A
Operating/Max speed	351 / 763	rpm	Lock rotor current	118	A
Orientation	Top horizontal		Motor supplier	Generic	
Air modulation	None		Actual drive service fac.	1.38	
Drip pan	None		Bearing type	Standard - L50 (200K)	
Drip pan side	-		Outlet velocity	2363	ft/m
Wheel guard	None		Inlet screen	None	
Belt guard	None		Outlet screen	None	
Inspection port	None		Motor location	To Side of Fan	
Material type	N/A		Number of blades	N/A	

DRIVES *			
Fan sheave	3TB250	Motor sheave	3B5V48
Number of belts	3	Belt	B116

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS			
Type	Spring		
Seismic restraint	None		

DOOR DATA				
Door location	Drive side		Window size	None
Door width	30	ins	Light	None
Door opening	Outward			

VFD / STARTER / DISCONNECT DATA				
Selection type	VFD - NEMA 1	Vendor	ABB	
Auxiliary Control	Combination Disconnect and Bypass	Voltage	460	
Disconnect Type	Fused			
Mounting	Door Side	H x W x D	19.09 x 7.42 x 9.89	ins
Enclosure	NEMA 1	Coil Voltage	N/A	
Line Reactor	None	Hand Off Auto Switch	None	
120V Ctrl Transformer	Provided			
VFD Quantity	1			
2 ECONOMIZER(92 ins)				
SECTION 2				
Drip pan	None	Drip side	-	
Floor grating	No			
OUTSIDE AIR		RETURN AIR	EXHAUST AIR	
Length x Width	42.00 x 132.00	42.00 x 132.00	42.00 x 132.00	ins
Location	Top	Internal	Top	
Dampers	UltraSeal Low Leak	UltraSeal Low Leak	UltraSeal Low Leak	
Actuation	-	-	-	
Hoods				
Rated cfm	26000	28000	28000	cfm
Air pressure drop	0.05	0.06	0.06	in WC
Quantity	1	1	1	
DOOR DATA				
Door location	Drive side	Window size	None	
Door width	30	ins	Light	None
Door opening	Outward			
3 PANEL FILTER(12 ins)				
SECTION 3				
Type	Pleated	Clean air press. drop	0.26	ins WC
Efficiency	MERV 8	Mean air press. drop	0.63	ins WC
Face velocity	353	Dirty air press. drop	1.00	ins WC
Face area	73.6	Access	Side	
Air volume	26000	cfm		
BANK ARRANGEMENT				
No. of Filters	Size H x W x D			
3.0	24 x 24 x 2		Ins	
15.0	24 x 20 x 2			
3.0	24 x 12 x 2			
5.0	12 x 24 x 2			
DOOR DATA				
Door location	Drive side	Window size	None	
Door width	8	ins	Light	None
Door opening	Outward			
SPECIAL				
Intercept Antimicrobial treatment				
Tread Plate floor liner	None			
Liner	(As casing details)			
Insulation	(As casing details)			
Sound baffles	None			
Special static pressure	±	ins WC	Filter Gauge	None

4 HOT WATER COIL(24 ins)				SECTION	3
Coil model	5WB1202B		Number of coils	2	
Capacity	1455556	Btu/h	Number of rows	2	
			Fins per inch	12	
Air volume	26000	cfm			
Entering db	40.0	F	Entering water	160.0	F
Leaving db	91.2	F	Leaving water	139.5	F
Finned height x length	39 x 120	ins	Water flow rate	142.20	gpm
Face area	65.00	ft ²	Water pressure drop	8.80	ftHD
Face velocity	400	ft/m	Water velocity	5.80	ft/s
Coil air pressure drop	0.15	ins WC	Fluid volume	11.0	gal
			Fluid weight	99.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 2.50	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galvanized track	
Glycol type (%)	- (0 %)		Drip pan	None	
Fouling Factor	0		Drip pan side	-	
Coil code	5WB1202B		Turbospirals	No	
			Electro-fin coat	None	
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	14	ins	Light	None	
Door opening	Outward				
5 CHILLED WATER COIL(28 ins)				SECTION	3
Coil model	5WS0806B		Number of coils	2	
Total capacity	1062272	Btu/h	Number of rows	6	
Sensible capacity	725066	Btu/h	Fins per inch	8	
Air volume	26000	cfm			
Entering db/wb	80.0 / 67.0	F	Entering water	45.0	F
Leaving db/wb	54.5 / 53.7	F	Leaving water	55.2	F
Finned height x length	39 x 123	ins	Water flow rate	208.20	gpm
Face area	66.63	ft ²	Water pressure drop	16.00	ftHD
Face velocity	390	ft/m	Water velocity	4.30	ft/s
Coil air pressure drop	0.44	ins WC	Fluid volume	51.0	gal
			Fluid weight	431.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 2.50	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galv. steel	
Glycol type (%)	- (0 %)		Drain pan	Stainless steel	
Fouling Factor	0		Drain pan side	Drive side	
Coil code	5WS0806B		Turbospirals	No	
			Electro-fin coat	None	

6 SUPPLY FAN SECTION(80 ins)					SECTION	4
Air volume	26000	cfm	Motor power	20.0	HP	
External static pressure	1.50	ins WC	Motor type	ODP		
Total static pressure	2.78	ins WC	Frame size	256 T frame		
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3		
Type	Centrifugal DWDI		Motor efficiency	Premium		
Blade type/Class	Airfoil / 2		Motor speed	1750	rpm	
Quantity of Fans	1		Block-off Plate	No		
Fan wheel diameter	33.00	ins	Motor pole	4		
Brake horsepower	16.48	HP	Full load current	24.5	A	
Operating/Max speed	1006 / 1579	rpm	Lock rotor current	160.8	A	
Orientation	Top horizontal		Motor supplier	Generic		
Air modulation	None		Actual drive service fac.	1.31		
Drip pan	None		Bearing type	Standard - L50 (200K)		
Drip pan side	-		Outlet velocity	2271	ft/m	
Wheel guard	None		Inlet screen	None		
Belt guard	None		Outlet screen	None		
Inspection port	None		Motor location	To Side of Fan		
Material type	N/A		Number of blades	N/A		

DRIVES *

Fan sheave	2B5V90	Motor sheave	2B5V52
Number of belts	2	Belt	5VX880

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS

Type	Spring
Seismic restraint	None

DOOR DATA

Door location	Drive side	Window size	None
Door width	30	ins	None
Door opening	Outward	Light	

VFD / STARTER / DISCONNECT DATA

Selection type	VFD - NEMA 1	Vendor	ABB
Auxiliary Control	Combination Disconnect and Bypass	Voltage	460
Disconnect Type	Fused		
Mounting	Door Side	H x W x D	23.58 x 10.49 x 10.25 ins
Enclosure	NEMA 1	Coil Voltage	N/A
Line Reactor	None	Hand Off Auto Switch	None
120V Ctrl Transformer	Provided		
VFD Quantity	1		

NOTES

Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ARI Standard 430.

As a standalone component, unit meets or exceeds requirements of ASHRAE 90.1 - 2007. The approving authority is responsible for compliance of multi-component building systems.


SHIPPING SECTION DETAILS

	Length (inches)			Weight (lb)		
Section 1	82			3283		
Section 2	92			1704		
Section 3	64			3702		
Section 4	80			3549		
TOTALS	318.00 (Lower level total)			12238 (Entire unit weight)		


UNIT SOUND	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
Radiated	85	89	80	73	67	58	42	33
Unit discharge	92	97	92	90	87	81	77	69
AHU-80 ton								

Unit return	87	84	83	79	76	75	70	63
-------------	----	----	----	----	----	----	----	----

Fan Curve for AHU-80 ton



MCQUAY INTERNATIONAL FAN SELECTION



33.00" Airfoil Supply Fan at Standard Conditions			
Air volume	cfm	Fan speed	1006 rpm
Total static	in ³ /lb	Max speed	1579 rpm
Brake horsepower	bhp	Efficiency	68.9 %
Unit tagging	AHU-80 ton	Date	October-28-2011
Job name	Shippensburg Old Main	Time	13:54


Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ASHRAE Standard 430.

ASHRAE

Drawing for AHU-80 ton


Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	132.00	88.00
B Fan discharge	83.00	47.73	31.90	40.55	43.74
C Damper	84.00	2.00	98.00	132.00	42.00
D Damper	130.00	2.00	98.00	132.00	42.00
E Hot water outlet	190.57	-7.00	50.32	2.50ins. MPS	-
F Hot water inlet	190.57	-7.00	15.40	2.50ins. MPS	-
G Hot water outlet	190.57	-7.00	90.72	2.50ins. MPS	-
H Hot water inlet	190.57	-7.00	55.80	2.50ins. MPS	-
I Cold water outlet	214.66	-7.00	51.69	2.50ins. MPS	-
J Cold water inlet	221.16	-7.00	15.31	2.50ins. MPS	-
K Cold water outlet	214.66	-7.00	92.69	2.50ins. MPS	-
L Cold water inlet	221.16	-7.00	56.31	2.50ins. MPS	-
M Condensate drain conn.	224.00	-3.40	9.73	1.50ins. MPS	-
N Fan discharge	319.00	44.01	44.15	47.99	35.74

Dimensions measured from \oplus




NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: General Arrangement No Ends
 DRAWN: October-28-2011 (13:53)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: AHU-80 ton
 MODEL: CAH065GDAC




Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	132.00	88.00
B Fan discharge	83.00	47.73	31.90	40.55	43.74
C Damper	84.00	2.00	98.00	132.00	42.00
D Damper	130.00	2.00	98.00	132.00	42.00
E Hot water outlet	190.57	-7.00	50.32	2.50ins. MPS	-
F Hot water inlet	190.57	-7.00	15.40	2.50ins. MPS	-
G Hot water outlet	190.57	-7.00	90.72	2.50ins. MPS	-
H Hot water inlet	190.57	-7.00	55.80	2.50ins. MPS	-
I Cold water outlet	214.66	-7.00	51.69	2.50ins. MPS	-
J Cold water inlet	221.16	-7.00	15.31	2.50ins. MPS	-
K Cold water outlet	214.66	-7.00	92.69	2.50ins. MPS	-
L Cold water inlet	221.16	-7.00	56.31	2.50ins. MPS	-
M Condensate drain conn.	224.00	-3.40	9.73	1.50ins. MPS	-
N Fan discharge	319.00	44.01	44.15	47.99	35.74

Dimensions measured from \oplus




NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: Right Side
DRAWN: October-28-2011 (13:53)
JOB NAME: Shippensburg Old Main
UNIT TAGGING: AHU-80 ton
MODEL: CAH065GDAC




Opening	X	Y	Z	W(Width)	H(Height)
A Exhaust inlet	0.00	2.00	8.00	132.00	88.00
B Fan discharge	83.00	47.73	31.90	40.55	43.74
C Damper	84.00	2.00	98.00	132.00	42.00
D Damper	130.00	2.00	98.00	132.00	42.00
E Hot water outlet	190.57	-7.00	50.32	2.50ins. MPS	-
F Hot water inlet	190.57	-7.00	15.40	2.50ins. MPS	-
G Hot water outlet	190.57	-7.00	90.72	2.50ins. MPS	-
H Hot water inlet	190.57	-7.00	55.80	2.50ins. MPS	-
I Cold water outlet	214.66	-7.00	51.69	2.50ins. MPS	-
J Cold water inlet	221.16	-7.00	15.31	2.50ins. MPS	-
K Cold water outlet	214.66	-7.00	92.69	2.50ins. MPS	-
L Cold water inlet	221.16	-7.00	56.31	2.50ins. MPS	-
M Condensate drain conn.	224.00	-3.40	9.73	1.50ins. MPS	-
N Fan discharge	319.00	44.01	44.15	47.99	35.74

Dimensions measured from ⊕



NOTE: Base 6.00ins deep, Cross members extend 4ins on each side of the unit.

VIEW: Top
 DRAWN: October-28-2011 (13:53)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: AHU-80 ton
 MODEL: CAH065GDAC



Technical Data Sheet for 100% OA ERU

QUOTE ID	KY8MGV(XX.002)	REP. OFFICE	TriState HVAC-York
JOB NAME	Shippensburg Old Main	SALESPERSON	SW
MODEL NUMBER	CAH008GDAC	ENGINEER	
UNIT TAGGING	100% OA ERU	VERSION	9.43

Unit configuration	Stacked with opposed air flows
Drive (handing) location	Right

	SUPPLY	RETURN / EXHAUST	
Air volume	2500	2500	s cfm
Altitude	0	0	ft
Turning loss	0.00	0.00	in WC.
External static	1.50	1.00	in WC.
Total static	3.55	2.53	in WC.
External H x W	34 x 58	34 x 58 (Not including base rails)	ins

CASING DETAILS	
Outer panel	Standard G90 galv steel (unpainted)
Liner	Galvanized steel (Unless noted per section)
Insulation	R-13 Injected Foam (Unless noted per section)
Frame	2 ins
Base	None
Sound baffles	None (Unless noted per section)
Tread Plate floor liner	None (unless noted per section)
Shrink wrapping	No

Exhaust Air Stream

1 PANEL FILTER(12 ins)			SECTION	4
Type	Throwaway	Clean air press. drop	0.11	ins WC
Efficiency	MERV 7	Mean air press. drop	0.56	ins WC
Face velocity	283	fpm	Dirty air press. drop	1.00
Face area	8.8	ft ²	Access	Side
Air volume	2500	cfm		

BANK ARRANGEMENT		
No. of Filters	Size H x W x D	
1.0	24 x 24 x 2	Ins
1.0	24 x 20 x 2	
1.0	24 x 12 x 2	

DOOR DATA			
Door location	Drive side	Window size	None
Door width	8	ins	Light
Door opening	Outward		None

2 ACCESS SECTION(16 ins)			SECTION	4
Drip pan	None	Drip side	-	Ins WC
		Air pressure drop	0.00	

DOOR DATA			
Door location	Drive side	Window size	None
Door width	12	ins	Light
Door opening	Outward		None

3 ENERGY RECOVERY SECTION (14 ins)			SECTION	3
Heat Wheel Model	ECW 424			
Media Type	Synthetic fiber - 4 angstrom	Electrical Supply Volt	115/60/1	Volt

3 ENERGY RECOVERY SECTION (14 ins)					SECTION	3
Wheel Diameter	42.00	ins	Bypass Damp	Opening	No Bypass	ins
Supply air CFM	2500	CFM	Supply air PD	Sum/Win	1.02 / 0.93	ins WC
Supply air FV Sum/Win	578 / 576	ft/min	Exhaust air CFM		2500	CFM
Return air PD Sum/Win	0.98 / 0.89	ins WC	Motor HP		0.5	
Segmented Wheel	No					
Summer Conditions						
Outside air DB	90.0	F	Outside air DB		10.0	F
Outside air WB	78.0	F	Outside air WB		10.0	F
Return air DB	75.0	F	Return air DB		75.0	F
Return air WB	62.0	F	Return air WB		62.0	F
Supply air DB	79.2	F	Supply air DB		56.7	F
Supply air WB	67.8	F	Supply air WB		51.0	F
Exhaust air DB	86.0	F	Exhaust air DB		29.2	F
Exhaust air WB	74.2	F	Exhaust air WB		29.2	F
Latent effectiveness	72.54	%	Latent effectiveness		72.54	%
Sensible effectiveness	75.83	%	Sensible effectiveness		75.83	%
Total effectiveness	73.51	%	Total effectiveness		74.49	%
Total Energy Recovered	107853	Btu/hr	Total Energy Recovered		191172	Btu/hr

4 RETURN/EXHAUST FAN SECTION(40 ins)					SECTION	1
Air volume	2500	cfm	Motor power	2.0	HP	
External static pressure	1.00	ins WC	Motor type	ODP		
Total static pressure	2.53	ins WC	Frame size	145 T frame		
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3		
Type	Centrifugal DWDI		Motor efficiency	Premium		
Blade type/Class	Airfoil / 2		Motor speed	1750	rpm	
Quantity of Fans	1		Block-off Plate	No		
Fan wheel diameter	13.22	ins	Motor pole	4		
Brake horsepower	1.59	HP	Full load current	2.9	A	
Operating/Max speed	2280 / 4335	rpm	Lock rotor current	26.5	A	
Orientation	Top horizontal		Motor supplier	Generic		
Air modulation	None		Actual drive service fac.	1.19		
Drip pan	None		Bearing type	Standard - L50 (200K)		
Drip pan side	-		Outlet velocity	1174	ft/m	
Wheel guard	None		Inlet screen	None		
Belt guard	None		Outlet screen	None		
Inspection port	None		Motor location	To Side of Fan		
Material type	N/A		Number of blades	N/A		

DRIVES *

Fan sheave	AK32H	Motor sheave	AK44H
Number of belts	1	Belt	A32

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS

Type	Spring
Seismic restraint	None

DOOR DATA

Door location	Drive side		Window size	None
Door width	30	ins	Light	None
Door opening	Outward			

Supply Air Stream

1 ACCESS SECTION(16 ins)				SECTION	2
Drip pan	None	Drip side	-		
		Air pressure drop	0.00	Ins WC	
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	12	ins	Light	None	
Door opening	Outward				
2 PANEL FILTER(12 ins)				SECTION	2
Type	Throwaway		Clean air press. drop	0.11	ins WC
Efficiency	MERV 7		Mean air press. drop	0.56	ins WC
Face velocity	283	fpm	Dirty air press. drop	1.00	ins WC
Face area	8.8	ft ²	Access	Side	
Air volume	2500	cfm			
BANK ARRANGEMENT					
No. of Filters	Size H x W x D				
1.0	24 x 24 x 2	Ins			
1.0	24 x 20 x 2				
1.0	24 x 12 x 2				
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	8	ins	Light	None	
Door opening	Outward				
3 ACCESS SECTION(16 ins)				SECTION	2
Drip pan	None	Drip side	-		
		Air pressure drop	0.00	Ins WC	
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	12	ins	Light	None	
Door opening	Outward				
4 ENERGY RECOVERY SECTION (14 ins)				SECTION	3
5 ACCESS SECTION(16 ins)				SECTION	5
Drip pan	None	Drip side	-		
		Air pressure drop	0.00	Ins WC	
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	12	ins	Light	None	
Door opening	Outward				

6 CHILLED WATER COIL(30 ins)				SECTION	5
Coil model	5WH1105B		Number of coils	1	
Total capacity	102862	Btu/h	Number of rows	5	
Sensible capacity	70864	Btu/h	Fins per inch	11	
Air volume	2500	cfm			
Entering db/wb	80.0 / 67.0	F	Entering water	45.0	F
Leaving db/wb	54.1 / 53.6	F	Leaving water	55.3	F
Finned height x length	24 x 45	ins	Water flow rate	20.00	gpm
Face area	7.50	ft ²	Water pressure drop	4.90	ftHD
Face velocity	333	ft/m	Water velocity	2.70	ft/s
Coil air pressure drop	0.35	ins WC	Fluid volume	5.0	gal
			Fluid weight	48.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 1.50	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galv. steel	
Glycol type (%)	- (0 %)		Drain pan	Microbial resistant coated galvanized	
Fouling Factor	0		Drain pan side	Drive side	
Coil code	5WH1105B		Turbospirals	No	
DOOR DATA					
Door location	Drive side		Window size	None	
Door width	14	ins	Light	None	
Door opening	Outward				
7 HOT WATER COIL(12 ins)				SECTION	5
Coil model	5WB1302B		Number of coils	1	
Capacity	137191	Btu/h	Number of rows	2	
			Fins per inch	13	
Air volume	2500	cfm			
Entering db	40.0	F	Entering water	160.0	F
Leaving db	90.2	F	Leaving water	139.9	F
Finned height x length	24 x 42	ins	Water flow rate	13.70	gpm
Face area	7.00	ft ²	Water pressure drop	0.40	ftHD
Face velocity	357	ft/m	Water velocity	1.80	ft/s
Coil air pressure drop	0.13	ins WC	Fluid volume	2.0	gal
			Fluid weight	18.00	lb
Connection type	Threaded		Fin material	Aluminum (.0075)	
Connection Qty x size	2 x 2.50	ins	Tube material	Copper (.020)	
Connection location	Drive side		Header material	Copper	
Connection material	Carbon steel		Case material	Galvanized track	
Glycol type (%)	- (0 %)		Drip pan	None	
Fouling Factor	0		Drip pan side	No	
Coil code	5WB1302B		Turbospirals	None	

8 SUPPLY FAN SECTION(40 ins)				SECTION	5
Air volume	2500	cfm	Motor power	3.0	HP
External static pressure	1.50	ins WC	Motor type	ODP	
Total static pressure	3.55	ins WC	Frame size	182 T frame	
Cabinet static pressure	0	ins WC	Electrical supply	460/60/3	
Type	Centrifugal DW/DI		Motor efficiency	Premium	
Blade type/Class	Airfoil / 2		Motor speed	1750	rpm
Quantity of Fans	1		Block-off Plate	No	
Fan wheel diameter	13.22	ins	Motor pole	4	
Brake horsepower	2.21	HP	Full load current	4	A
Operating/Max speed	2541 / 4335	rpm	Lock rotor current	32	A
Orientation	Top horizontal		Motor supplier	Generic	
Air modulation	None		Actual drive service fac.	1.19	
Drip pan	None		Bearing type	Standard - L50 (200K)	
Drip pan side	-		Outlet velocity	1174	ft/m
Wheel guard	None		Inlet screen	None	
Belt guard	None		Outlet screen	None	
Inspection port	None		Motor location	To Side of Fan	
Material type	N/A		Number of blades	N/A	

DRIVES *

Fan sheave	AK39H	Motor sheave	AK56H
Number of belts	1	Belt	A32

* McQuay reserves the right to provide a different but equivalent drive package.

ANTI-VIBRATION MOUNTS / SPRINGS

Type	Spring
Seismic restraint	None

DOOR DATA

Door location	Drive side	Window size	None
Door width	30	ins	Light
Door opening	Outward		None

NOTES

Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ARI Standard 430.


As a standalone component, unit meets or exceeds requirements of ASHRAE 90.1 - 2007. The approving authority is responsible for compliance of multi-component building systems.

SHIPPING SECTION DETAILS

	Length (inches)		Weight (lb)	
Section 1	40		508	
Section 2	44		287	
Section 3	16		483	
Section 4	28		203	
Section 5	98		1199	
TOTALS	158.00 (Lower level total)		2680 (Entire unit weight)	


UNIT SOUND	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
Radiated	74	76	70	66	57	48	32	23
Unit discharge	81	83	81	82	76	70	66	58
Unit return	76	78	76	77	71	65	61	53

Fan Curve for 100% OA ERU



13.22" Airfoil Ret/Exh Fan at Standard Conditions			
Air volume	2500 cfm	Fan speed rpm	2280 rpm
Total static	2.53 insWg	Max speed rpm	4335 rpm
Brake horsepower	1.6 bhp	Efficiency	62.6 %
Unit tagging	100% OA ERU	Date	October-28-2011
Job name	Shippensburg Old Main	Time	14:02

McQUAY INTERNATIONAL FAN SELECTION




13.22" Airfoil Supply Fan at Standard Conditions			
	cfm	Fan speed insWg	rpm
Air volume	2500	2541	rpm
Total static	3.55	4335	rpm
Brake horsepower	2.2	Efficiency	63.4 %
Unit tagging	100% OA ERU	Date	October-28-2011
Job name	Shippensburg Old Main	Time	14:02
Supply fan performance is certified in accordance with the Central Station Air-Handling Unit Certification Program, which is based on ARI Standard 430.			




Drawing for 100% OA ERU

Opening	X	Y	Z	W(Width)	H(Height)
A Supply inlet	0.00	2.00	2.00	54.00	30.00
B Cold water outlet	80.60	-7.00	29.19	1.50ins. MPS	-
C Cold water inlet	85.85	-7.00	6.81	1.50ins. MPS	-
D Condensate drain conn.	91.00	-2.90	3.00	1.25ins. MPS	-
E Hot water outlet	110.57	-7.00	26.58	2.50ins. MPS	-
F Hot water inlet	110.57	-7.00	6.66	2.50ins. MPS	-
G Fan discharge	159.00	23.03	13.49	19.94	16.68
H Fan discharge	3.00	25.07	47.49	19.94	16.68
I Exhaust inlet	88.00	2.00	36.00	54.00	30.00

Dimensions measured from \oplus




VIEW: General Arrangement No Ends
 DRAWN: October-28-2011 (14:01)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: 100% OA ERU
 MODEL: CAH008GDAC



Opening	X	Y	Z	W(Width)	H(Height)
A Supply inlet	0.00	2.00	2.00	54.00	30.00
B Cold water outlet	80.60	-7.00	29.19	1.50ins. MPS	-
C Cold water inlet	85.85	-7.00	6.81	1.50ins. MPS	-
D Condensate drain conn.	91.00	-2.90	3.00	1.25ins. MPS	-
E Hot water outlet	110.57	-7.00	26.58	2.50ins. MPS	-
F Hot water inlet	110.57	-7.00	6.66	2.50ins. MPS	-
G Fan discharge	159.00	23.03	13.49	19.94	16.68
H Fan discharge	3.00	25.07	47.49	19.94	16.68
I Exhaust inlet	88.00	2.00	36.00	54.00	30.00

Dimensions measured from \oplus




VIEW: General Arrangement No Ends
 DRAWN: October-28-2011 (14:01)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: 100% OA ERU
 MODEL: CAH008GDAC



Opening	X	Y	Z	W(Width)	H(Height)
A Supply inlet	0.00	2.00	2.00	54.00	30.00
B Cold water outlet	80.60	-7.00	29.19	1.50ins. MPS	-
C Cold water inlet	85.85	-7.00	6.81	1.50ins. MPS	-
D Condensate drain conn.	91.00	-2.90	3.00	1.25ins. MPS	-
E Hot water outlet	110.57	-7.00	26.58	2.50ins. MPS	-
F Hot water inlet	110.57	-7.00	6.66	2.50ins. MPS	-
G Fan discharge	159.00	23.03	13.49	19.94	16.68
H Fan discharge	3.00	25.07	47.49	19.94	16.68
I Exhaust inlet	88.00	2.00	36.00	54.00	30.00

Dimensions measured from \oplus



VIEW: General Arrangement No Ends
 DRAWN: October-28-2011 (14:01)
 JOB NAME: Shippensburg Old Main
 UNIT TAGGING: 100% OA ERU
 MODEL: CAH008GDAC



Technical Data Sheet for Fan Coil

Job Name: Shippensburg Old Main
Date: 12/8/2011
Submitted By: Scott Wolf

Unit Description:

McQuay Model Number::	FCVC104
Unit Size:	04
Air Flow:	338 CFM
External Static Pressure:	0.00 inH ₂ O
Unit Configuration:	Vertical

Unit Dimensions & Weights:

Unit Depth:	10.0 in
Unit Width:	46.0 in
Unit Height:	25.0 in
Unit Shipping Weight:	108 lb

Electric Data:

Voltage:	115/60/1
Fan Motor Amps:	0.7 A
Unit MCA:	0.9 A
Unit MROPD:	1 A

Filters:

Type:	1" Throwaway
Qty./Size:	1/ 27 x 8.75 x 1

Hot Water Preheat Coil:

Coil:

Coil FPI:	12
Coil Rows:	1
Face Area:	1.0 ft ²
Face Velocity:	355.9 ft/min

Performance:

Total Capacity:	14206 Btu/hr
Entering Air Temperature:	70.0 °F
Leaving Air Temperature	108.4 °F
Entering Fluid Temperature:	160.0 °F
Leaving Fluid Temperature:	140.1 °F
Glycol:	Water/ 0%
Fluid Flow Rate:	1.4 gpm
Fluid Pressure Drop:	5.1 ft H ₂ O

Chilled Water Cooling Coil:

Coil:

Coil FPI:	12
Coil Rows:	4
Face Area:	1.4 ft ²
Face Velocity:	236.4 ft/min

Performance:

Total Capacity:	13340 Btu/hr
Sensible Capacity:	9459 Btu/hr
Entering Air Temperature:	80.0 °F/67.0 °F
Leaving Air Temperature:	54.4 °F/ 54.2 °F
Entering Fluid Temperature:	45.0 °F

Leaving Fluid Temperature: 55.0 °F
Glycol: Water/ 0%
Fluid Flow Rate: 2.7 gpm
Fluid Pressure Drop: 3.0 ft H₂O

Supply Fan:

Fan:	
Fan Wheel Size:	6.26 x 6.3
Fan Quantity:	2
Motor:	
Horsepower:	1/25
Quantity:	1

Unit Data:

Main Unit Tagging:	Fan Coil
Main Unit Model Number::	VLVFCVY
Valve Package Location:	Primary
Connection Hand:	Left

Valve Package Configuration:

Coil Control:	
Flow Control:	Floating, 3-Wire, Modulating
Valve Body Type	3-Way
Voltage:	115/60/1
Coil Connection	
Connection Size:	5/8" Connection
Connection Type:	Sweat Connection
Valve Shutoff Control:	
Shut Off Pressure:	High Close Off
Valve Position:	Normally Closed
Valve CV Value	1 CV
Valve Piping Package	
Shut-off Isolation Valve Type:	Ball Valve, Open-Close
Strainer	None
PT Ports	PT Ports
Field Connection Type:	
Connection Type	Sweat
Stainless Steel Hose Length	None
Flow Control	
Flow Control Type:	Auto (Cartridge) Flow
Flow Control Volume	2.50

Unit Data:

Main Unit Tagging:	Fan Coil
Main Unit Model Number::	N/A
Valve Package Location:	Preheat
Connection Hand:	Left



Valve Package Configuration:

Coil Control:	
Flow Control:	Floating, 3-Wire, Modulating
Valve Body Type	3-Way
Voltage:	115/60/1
Coil Connection	
Connection Size:	5/8" Connection
Connection Type:	Sweat Connection
Valve Shutoff Control:	
Shut Off Pressure:	High Close Off
Valve Position:	Normally Closed
Valve CV Value	1 CV
Valve Piping Package	
Shut-off Isolation Valve Type:	Ball Valve, Open-Close
Strainer	None
PT Ports	PT Ports
Field Connection Type:	
Connection Type	Sweat
Stainless Steel Hose Length	None
Flow Control	
Flow Control Type:	Auto (Cartridge) Flow
Flow Control Volume	1.00

FanCoil_Drawing for Fan Coil



Fancoil Certified Drawing	
View:	Unit Layout
Model:	FCU/04
Date:	10/28/2011
Unit Tag:	Fan Coil

Description	Letter	Dimension in
Width	A	46.0
Dim AA	AA	15.00
Height	B	25.0
Dim BB	BB	16.70
Depth	C	10.0
Dim CC	C	18.70
Dim DD	DD	21.90
Dim E	E	27.30
Dim EE	EE	1.10
Dim F	F	27.20
Dim FF	FF	4.70
Dim G	G	17.90
Dim GG	GG	7.80
Dim H	H	15.70
Dim HH	HH	1.20
Dim K	K	5.00
Dim L	L	4.50
Dim M	M	4.60
Sub. base depth	N	9.30
Dim P	P	3.40
Dim T	T	8.80





McQuay
A Carrier Company

FanCoil_Drawing for Fan Coil



McQuay
Air Conditioning

FanCoil_Drawing for Fan Coil



McQuay
Air Conditioning

Appendix C-2

Johnson Controls



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Unit Sequence

Tier 1

FS <<< CC <<< XA <<< HC <<< AF <<< EE <<< FR

Basic Unit Options

Insulation Type: (Refer to Each Segment)

Base Rail Height: 6"

Performance: High Performance

Unit Special Quotes

None

*Note: Component locations are listed as Segment Hand (Unit Hand) : ex. Left (Right)
See Submittal Drawing for additional details

Segments Listed Starting At Air Inlet



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Oty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

FR - Return Fan Segment

Segment Details	Fan Segment Options
Segment Air Pressure Drop (in. w.g.):	0.08
Air Flow (CFM):	11400
Altitude (ft.):	348
TSP/ESP (in. w.g.):	1.65/ 1.25
Air Inlet:	Top
Fan Discharge:	Rear Inverted(Rear)
	1" Spring Isolator Interior Galvanized Liner Insulation: R-13 Foam Insulation Galvanized Floor Liner STD Gauge Exterior Galvanized Liner Access Doors on Both Sides 63H x 24W Standard Door Latch, No Lock, Outward Opening

Fan Detail

Type:	AF
Size:	25-25
Construction:	S
Bearing Options:	None
Fan RPM:	974
BHP:	4.46
Fan BHP w/ Belt Loss:	4.77
Outlet Velocity (ft/min):	1550

Motor Detail

Motor Type:	ODP Premium Efficiency
HP	15.0
Voltage/Phase/Frequency:	460/3/60 Hz
Motor RPM:	1800
Frame Size:	254
Location:	Left(Left)
Drive Type:	Belt Drive
Belt Drive Type:	Fixed
Drive Options:	Multiple Belt
Full Load Amps (FLA):	17.7
Efficiency:	93.0%



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Motor Control – Return Fan

Motor Control Details

Motor Control Type: Variable Frequency Drive
Motor HP: 15.0

Motor Control Electrical Details

Full Load Amps (FLA): 23.0

Motor Control Options

Non Fused Disconnect
Manual Bypass
Field Terminated Wiring

RFI/EMI EMC Filter
Swinging DC Line Choke (equivalent to 5% Input Line Reactor)
Modbus RTU, Johnson N2, Siemens FLN, BACnet

Environmental

Ambient Temperature (°F): 5 to 104
Storage Temperature (°F): -40 to 158
Humidity: MAX 95% RH non-condensing
Altitude: 3,300 ft. without derate (1% derate for each additional 330 ft.)
Enclosure: NEMA 1

Input

Rated Input Voltage: 380/400/415/440/460/480 +10% -15% VAC 3 phase
Rated Input Current Amps: 23.00
Heat Loss in Watts 100% Load: 337.00
Efficiency (%): 98.00

Output

Output Current Amps: 23.0
Overload Current Rating: 110% for 1 minute every 10 minutes

Drives are rated for use below 3,300 ft and 104°F. Use Derating Charts in Air-Mod Engineering Guide Form 100.41-EG1 (704) for use above these limits.

Copper Conductors Only



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

EE – Economizer Segment

Segment Detail

Supply Air Pressure Drop (in. w.g.)	0.32
Return/Exhaust Air Pressure Drop (in. w.g.)	0.32

	Outside Air (OA)	Mixed Air (MA)	Exhaust Air (EA)	Return Air (RA)
AirFlow (CFM)	16000	16000	16000	16000
Opening (QTY) Size	26.75Hx66.00W	26.75Hx66.00W	26.75Hx66.00W	N/A
Area per Opening (ft ²)	12.26	12.26	12.26	N/A
Location	Top	Middle-Vertical	Top	None
Damper (QTY) Size	(1)26.75x66	(1)26.75x66	(1)26.75x66	None
Damper Type	Control	Control	Control	None
Configuration	100%	100%	100%	None
Damper Model	CD60	CD60	CD60	None
Damper Material	Galvanized	Galvanized	Galvanized	None
Blade Orientation	Parallel	Parallel	Parallel	None
Min. Allowed CFM	N/A	N/A	N/A	N/A

Economizer Segment Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner

Exhaust Air Doors:

Access Doors on Both Sides 63H x 24W
Multi-Point Door Latch, No Lock, Outward Opening
Outside Air Doors:
Access Doors on Both Sides 63H x 24W
Standard Door Latch, No Lock, Outward Opening

Dampers Selected are ASHRAE 90.1 Compliant

AF – Angle Filter Segment

Filter Media Detail

(Quantity) Filter Sizes:	(24)20x16
Filter Loading:	Side
Filter Depth:	2"
Filter Media Type:	Pleated 30% (MERV 8)
Filter Area (ft ²):	53.3
Filter Air Pressure Drop (in. w.g.):	0.16
Dirty Filter Allowance (in. w.g.):	0.20

Filter Segment Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner
Access Doors on Both Sides 63H x 17W
Standard Door Latch, No Lock, Outward Opening



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

HC - Heating Coil Segment

Coil Segment Details

Coil Space:

7"

Coil Segment Options

- Interior Galvanized Liner
- Insulation: R-13 Foam Insulation
- Galvanized Floor Liner STD Gauge
- Exterior Galvanized Liner
- Bulkhead Material Galvanized
- Coil Supports Galvanized

XA Access Segment

Access Segment Details

Segment Length:

27 "

Access Segment Options

- Interior Galvanized Liner
- Insulation: R-13 Foam Insulation
- Galvanized Floor Liner STD Gauge
- Exterior Galvanized Liner
- Access Doors on Both Sides 63H x 24W
- Standard Door Latch, No Lock, Outward Opening
- 22" Additional Core Growth

CC - Cooling Coil Segment

Coil Segment Details

Coil Space:

10"

Coil Segment Options

- Interior Galvanized Liner
- Insulation: R-13 Foam Insulation
- Galvanized Floor Liner STD Gauge
- Exterior Galvanized Liner
- 19" IAQ Coil Drain Pan Left (Left)
- Stainless Steel
- Bulkhead Material Galvanized
- Coil Supports Galvanized

UV Surface Decontamination Detail

None



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

FS - Supply Fan Segment

Segment Details		Fan Segment Options
Segment Air Pressure Drop (in. w.g.):	0.00	1" Spring Isolator
Air Flow (CFM):	16000	Interior Galvanized Liner
Altitude (ft.):	348	Insulation: R-13 Foam Insulation
TSP/ESP (in. w.g.):	3.29/ 2.00	Galvanized Floor Liner STD Gauge
Air Inlet:	Front(Front)	Exterior Galvanized Liner
Fan Discharge:	Rear(Rear)	Access Doors on Both Sides 63H x 24W
		Standard Door Latch, No Lock, Outward Opening

Fan Detail

Type:	AF
Size:	25-25
Construction:	S
Bearing Options:	None
Fan RPM:	1340
BHP:	11.94
Fan BHP w/ Belt Loss:	12.59
Outlet Velocity (ft/min):	2176

Motor Detail

Motor Type:	ODP Premium Efficiency
HP	15.0
Voltage/Phase/Frequency:	460/3/60 Hz
Motor RPM:	1800
Frame Size:	254
Location:	Left(Left)
Drive Type:	Belt Drive
Belt Drive Type:	Fixed
Drive Options:	Multiple Belt
Full Load Amps (FLA):	17.7
Efficiency:	93.0%



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Motor Control – Supply Fan

Motor Control Details		Motor Control Electrical Details	
Motor Control Type:	Variable Frequency Drive	Full Load Amps (FLA):	23.0
Motor HP:	15.0		
Motor Control Options		Environmental	
Non Fused Disconnect		Ambient Temperature (°F):	5 to 104
Manual Bypass		Storage Temperature (°F):	-40 to 158
RFI/EMI EMC Filter		Humidity:	MAX 95% RH non-condensing
Swinging DC Line Choke (equivalent to 5% Input Line Reactor)		Altitude:	3,300 ft. without derate (1% derate for each additional 330 ft.)
Modbus RTU, Johnson N2, Siemens FLN, BACnet		Enclosure:	NEMA 1
Input			
Rated Input Voltage:	380/400/415/440/460/480 +10% -15% VAC 3 phase		
Rated Input Current Amps:	23.00		
Heat Loss in Watts 100% Load:	337.00		
Efficiency (%):	98.00		
Output			
Output Current Amps:	23.0		
Overload Current Rating:	110% for 1 minute every 10 minutes		
Drives are rated for use below 3,300 ft and 104°F. Use Derating Charts in Air-Mot Engineering Guide Form 100.41-EG1 (704) for use above these limits.			
Copper Conductors Only			

Coils & Spacers Listed Starting In Direction Of Air Flow

HC Coil - 01		Coil General/Physical Details		Air Side Performance		Fluid Side Performance	
Location:	0	Rows:	2	Air Flow (CFM):	16000	EWT (°F):	180.0
Tag:	AirCoil	Fins Per Inch:	11	Altitude (ft.):	348	LWT (°F):	160.0
Application:	Heating	Tubes Per Circuit:	2	EAT-DB (°F):	10.0	GPM:	155.2
Coil Type:	Water	Finned Height (in.):	57.50	LAT-DB (°F):	88.4	WPD (ft.):	10.1
Face Type:	Full	Finned Length (in.):	81	FV (ft/min):	495	FPS:	5.8
Tube Diameter:	1/2" BDW	Coil Face Area (ft ²):	32.3	TMBH:	1509.2	Fluid Type:	Water
Tube Material:	Copper	Coil Conn. Loc.:	Left(Left)	APD (in. w.g.):	0.17	Fluid Weight(lb):	82.6
Tube Wall Thickness:	.016"	Supp Conn Size:	3"			Fluid Volume(ft ³):	1.4
		Rtn Conn Size:	3"				
		# of Supply	1				

Project Name: Shippensburg Old Main
Printed: 10/25/2011 10:58:17

York Contract No.:
AHU-1Performance



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Fin Type: Corrugated Conn. (per coil):
Fin Thickness: .006"
Fin Material: Aluminum
Casing Material: Galvanized
Connection Material: Steel*
Connection Type: MPT
Coating: None

*York suggests using red brass or copper connectors when the coil is to be attached to a copper or brass piping system.

ARI Messages:

Coil is certified in accordance with the AHRI Forced-Circulation Air-Cooling and Air-Heating Coils Certification program which is based on AHRI Standard 410. Certified units may be found in the AHRI Directory at www.ahridirectory.org.

CC Coil - 01

Coil General/Physical Details		Air Side Performance		Fluid Side Performance	
Location:	0 Rows:	5	Air Flow (CFM):	16000	EWT (°F): 45.0
Tag:	AirCoil Fins Per Inch:	10	Altitude (ft.):	348	LWT (°F): 55.0
Application:	Cooling Tubes Per Circuit:	4	EAT-DB (°F):	80.0	GPM: 115.8
Coil Type:	Water Finned Height (in.):	57.50	EAT-WB (°F):	67.0	WPD (ft.): 7.3
Face Type:	Full Finned Length (in.):	81	LAT-DB (°F):	56.2	FPS: 3.5
Tube Diameter:	1/2" BDW Coil Face Area (ft ²):	32.3	LAT-WB (°F):	54.9	Fluid Type: Water
Tube Material:	Copper Coil Conn. Loc.: Left(Left)		FV (ft/min):	495	Fluid Weight(lb): 161.9
Tube Wall Thickness:	.016" Supp Conn Size:	3"	SMBH:	407.3	Fluid Volume(ft ³): 2.6
Fin Type:	Corrugated Rtn Conn Size:	3"	TMBH:	584.1	
Fin Thickness:	.006" # of Supply	1	APD (in. w.g.):	0.44	
Fin Material:	Aluminum Conn. (per coil):				
Casing Material:	Stainless Steel				
Connection Material:	Red Brass				
Connection Type:	MPT				
Coating:	None				

ARI Messages:

Coil is certified in accordance with the AHRI Forced-Circulation Air-Cooling and Air-Heating Coils Certification program which is based on AHRI Standard 410. Certified units may be found in the AHRI Directory at www.ahridirectory.org.



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Electrical Circuit Summary

Short-Circuit Summary	
5 kA rms Symmetrical	480 V Maximum

Circuit 1	Circuit 1 Electrical Details
Supply Fan Motor Control	Full Load Amps (FLA): 23.0 Minimum Circuit Ampacity (MCA): 28.8 Maximum Fuse Size: 50.00
Circuit 2	Circuit 2 Electrical Details
Return Fan Motor Control	Full Load Amps (FLA): 23.0 Minimum Circuit Ampacity (MCA): 28.8 Maximum Fuse Size: 50.00

Segment	Component	Supply (in. w.g.)	Return Fan (in. w.g.)
FR-DWDI Return Fan	Opening Pressure Drop	0.08	
EE Economizer	External Static Pressure - User Entered Pressure Drop	1.25	
	Opening Pressure Drop	0.29	
	Control Galvanized (CD60)	0.03	
	Opening Pressure Drop	0.29	
AF Angle Filter	Control Galvanized (CD60)	0.03	
	2" Pleated 30% (MERV 8)	0.16	
	Dirty Filter Allowance	0.20	
HC Heating Coil	Heating 2 rows 11 fins	0.17	
CC Variable Length Cooling Coil	Cooling 5 rows 10 fins	0.44	
FS-DWDI Supply Fan	External Static Pressure - User Entered Pressure Drop	2.00	
Total		3.29	1.65

Air handling unit parameters vary depending on conditions. Parameters such as airflows, air pressure drops, and coil capacities are shown for design conditions.



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Dimension & Weights Summary

Section	Length*	Width**	Height	Weight
	(in.)	(in.)	(in.)	(lbs.)
FR-DWDI Return Fan Segment	49	93	69	1983
EE Economizer Segment	65	93	69	819
AF Angle Filter Segment	17	93	69	416
HC Heating Coil Segment	10	93	69	607
XA Variable Length Access Segment	27	93	69	320
CC Variable Length Cooling Coil Segment	20	93	69	1214
FS-DWDI Supply Fan Segment	49	93	69	1983
Overall:	237	93	69	7342

*The length includes bottom tier segments only.

**The width does not include coil connection extensions or door latches that extend beyond the unit casing.
The width does not include the depth of any pipe chases.

Shipping Skid Summary

Shipping Skid	Length*	Width**	Height***	Weight
	(in.)	(in.)	(in.)	(lbs.)
(FS-DWDI CC)	70	114	79	3197
(XA HC)	37	102	79	927
(AF EE)	50	99	79	858
(EE)	33	99	79	377
(FR-DWDI)	50	114	79	1983
Ship Loose:				
None				
*The length includes any mounted rain-hoods, discharge flanges, tie-down brackets, shipping wood-blocks, front dampers, split connectors, electrical/control components, out rigging HW supports, isolation dampers				
**The width includes any door handles, coil connections, drain connections, lifting lugs, mounted pipe-chases, electrical/control components, tie-down brackets, side dampers				
***The height includes any base-rails, shipping wood-blocks, roof peak, discharge flanges, mounted gas-furnace flue pipes				
Shipping Skid Sequence				
Tier 1	(FS < CC) < (XA < HC) < (AF < EE) < (EE) < (FR)			



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
AHU-1	1	Solution Indoor Air Handler 69 x 93	16000

Sound Summary

Octave Band Sound Power Levels (dB Re. 1 picowatt)

	63	125	250	500	1000	2000	4000	8000	dBA
Ducted Discharge Rear-1, FS	98	95	96	91	88	80	75	70	
Return Air Top-1, FR	90	83	82	80	74	72	70	67	
Outside Air Top-1, EE	86	84	83	76	73	68	63	58	80
Exhaust Air Top-1, EE	87	85	83	76	73	68	64	58	

Sound data tested in accordance with ARI-260 (2000), Standard for Sound Rating of Ducted Air Moving and Conditioning Equipment.

Notes:

1. The overall A-weighted sound power level is only applicable to sound radiation outdoors and casing radiated sound. This metric does not apply to ducted components
2. Return air sound powers are estimated using 100% of unit flow. Outside air sound powers are estimated using 15% of unit flow. Exhaust air sound powers are estimated using 15% of unit flow.

UNIT CONSTRUCTION

Model: Solaire-XTI-260
Unit Location: L1E
Unit Weight: Pcs. 182.

Construction: Indoor
Flight:

NOTES

Unit with a plenum and a bottom operating duct connection, back to the bottom of unit, and back with bottom of unit.

Filter & Airflow Model: Solaire-XTI-260

After sufficient space around the unit for removing the access panel and various parts of the unit. A minimum space need to be available at the unit base and on one side of the unit for removing the filter or the access panel.

Consideration must be given to the orientation and placement of all exhaust fans and return air connections.

Overall dimensions account for: ceiling and wall, and everything, including ducting, piping, lighting fixtures, and other equipment.

Access holes, and openings, will be required for cleaning, maintenance, and repair.

Access panel to remove the filter and access to the interior of the unit.

Check local fire codes before installing, connecting, and operating. Refer to the manufacturer's instructions.

Check local building codes for zoning, permits, electrical, HVAC, HVAC, gas and plumbing, etc.

Unit Dimensions: Unit L1E - Unit ID: U1

(S) Dimensional Sketch (See 3.3 Table)

PIPE CONNECTIONS

In order to prevent water damage, please follow these guidelines:

SECTION LINE	Head	Supply	Return	Plenum
SC	Left	Left	Right	3"
CC	Left	Right	Left	3"

Length from centerline of 1 1/2" (38.1mm) (Dimensions include end channels).

SECTION LINE	DESCRIPTION
FR	Branch Pn. 21.50 Length = 5.90 IP
CR	Coil Pn. 21.50 Length = 5.90 IP
AR	Variable Length Access
AC	Access Case
AE	Access Hole
EE	Expansion Hole
PR	Branch Pn. 25.20 Length = 5.90 IP

PLAN VIEW TIER 1

ELEVATION VIEW

REAR (OUTLET) END VIEW

FRONT (INLET) END VIEW

PRODUCT DRAWING

Project Name: Shippensburg Old Main
Location:
Engineer:
Contractor:
For:
TAG: AHU-1
TAG: NTS

Date: 10/25/2011 10:56:13
Version: 1.1.0.5370
Form No.: 100-08-ER1
Dwg. Loc.: 503
Dwg. Serial: NTS

SOLAR AIR HANDLING UNIT DETAIL

SOLAIRE SOLAIRE-XTI-260

NOT FOR CONSTRUCTION

Johnson Controls



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Unit Sequence

Tier 2

IP >>> AF >>> XA >>> HW2 >>> XA >>> FE

Tier 1

FS <<< XA <<< HW1 <<< XA <<< AF <<< MB

Basic Unit Options

Insulation Type: (Refer to Each Segment)
Base Rail Height: 6"
Performance: High Performance

Unit Special Quotes

None

*Note: Component locations are listed as Segment Hand (Unit Hand) : ex. Left (Right)
See Submittal Drawing for additional details

Segments Listed Starting At Air Inlet

IP – Inlet Plenum

Inlet Plenum Details

Opening: Front(Rear)
Segment Air Pressure Drop (in. w.g.) 0.07

Inlet Plenum Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner
Access Doors on Both Sides 45H x 18W
Multi-Point Door Latch, No Lock, Outward Opening



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

AF – Angle Filter Segment

Filter Media Detail

(Quantity) Filter Sizes:	(16)20x16
Filter Loading:	Side
Filter Depth:	2"
Filter Media Type:	Pleated 30% (MERV 7)
Filter Area (ft ²):	35.6
Filter Air Pressure Drop (in. w.g.):	0.05
Dirty Filter Allowance (in. w.g.):	0.10

Filter Segment Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner
Access Door on Right Side(Left) 45H x 17W
Multi-Point Door Latch, No Lock, Outward Opening

XA Access Segment

Access Segment Details

Segment Length:	23 "
-----------------	------

Access Segment Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner
Access Door on Right Side(Left) 45H x 18W
Multi-Point Door Latch, No Lock, Outward Opening
2" Additional Core Growth

XA Access Segment

Access Segment Details

Segment Length:	26 "
-----------------	------

Access Segment Options

Interior Galvanized Liner
Insulation: R-13 Foam Insulation
Galvanized Floor Liner STD Gauge
Exterior Galvanized Liner
21" Additional Core Growth



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

FE - Exhaust Fan Segment

Segment Details	Fan Segment Options
Segment Air Pressure Drop (in. w.g.):	0.00
Air Flow (CFM):	4600
Altitude (ft.):	348
TSP/ESP (in. w.g.):	1.97/ 1.25
Air Inlet:	Front(Rear)
Fan Discharge:	Rear(Front)
	1" Spring Isolator
	Interior Galvanized Liner
	Insulation: R-13 Foam Insulation
	Galvanized Floor Liner STD Gauge
	Exterior Galvanized Liner
	Access Doors on Both Sides 45H x 18W
	Multi-Point Door Latch, No Lock, Outward Opening

Fan Detail

Type:	AF
Size:	18-18
Construction:	S
Bearing Options:	None
Fan RPM:	1351
BHP:	2.01
Fan BHP w/ Belt Loss:	2.15
Outlet Velocity (ft/min):	1460

Motor Detail

Motor Type:	ODP Premium Efficiency
HP	3.0
Voltage/Phase/Frequency:	460/3/60 Hz
Motor RPM:	1800
Frame Size:	182
Location:	Right(Left)
Drive Type:	Belt Drive
Belt Drive Type:	Fixed
Full Load Amps (FLA):	4.1
Efficiency:	89.5%



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Motor Control – Exhaust Fan

Motor Control Details		Motor Control Electrical Details	
Motor Control Type:	EM Starter	Full Load Amps (FLA):	4.1
Motor HP:	3		
Motor Control Options			
Fused Disconnect			
Field Terminated Wiring			
Extra Auxiliary Contacts: (1) Normally Open			
Enclosure Location: Primary Access Side of FE/FR			
The customer must provide a platform or catwalk for accessing the power-disconnect.			
Copper Conductors Only			

MB – Mixing Box Segment

Segment Detail		
Segment Air Pressure Drop (in. w.g.):		0.04
	Outside Air (OA)	Return Air (RA)
AirFlow (CFM)	4600	4600
Opening (QTY) Size	21.00Hx66.00W	N/A
Area per Opening (ft ²)	9.63	N/A
Location	Front-High(Front)	None
Damper (QTY) Size	(1)21.00x66	None
Damper Type	Control	None
Configuration	100%	None
Damper Model	CD60	None
Damper Material	Galvanized	None
Blade Orientation	Parallel	None
Min. Allowed CFM	N/A	N/A
Damper Linkage	Unlinked	Unlinked
Mixing Box Segment Options		
Interior Galvanized Liner		
Insulation: R-13 Foam Insulation		
Galvanized Floor Liner STD Gauge		
Exterior Galvanized Liner		
Access Doors on Both Sides 45H x 18W		
Standard Door Latch, No Lock, Outward Opening		
Dampers Selected are ASHRAE 90.1 Compliant		



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

AF - Angle Filter Segment

Filter Media Detail		Filter Segment Options
(Quantity) Filter Sizes:	(16)20x16	Interior Galvanized Liner
Filter Loading:	Side	Insulation: R-13 Foam Insulation
Filter Depth:	2"	Galvanized Floor Liner STD Gauge
Filter Media Type:	Pleated 30% (MERV 7)	Exterior Galvanized Liner
Filter Area (ft ²):	35.6	Access Door on Left Side(Left) 45H x 17W
Filter Air Pressure Drop (in. w.g.):	0.05	Standard Door Latch, No Lock, Outward Opening
Dirty Filter Allowance (in. w.g.):	0.10	

XA Access Segment

Access Segment Details		Access Segment Options
Segment Length:	21 "	Interior Galvanized Liner Insulation: R-13 Foam Insulation Galvanized Floor Liner STD Gauge Exterior Galvanized Liner



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

HW – Heat Wheel Segment

Segment Details		Heat Wheel Segment Options
Supply Air Pressure Drop (in. w.g.):	0.50	Interior Galvanized Liner
Exhaust Air Pressure Drop (in. w.g.):	0.50	Insulation: R-13 Foam Insulation
Outdoor Air Flow (CFM):	4600	Galvanized Floor Liner STD Gauge
Exhaust Air Flow (CFM):	4600	Exterior Galvanized Liner
Segment Length (in.):	28	Inverter Rated Motor
Heat Wheel Type:	Enthalpy	
Heat Wheel Vendor:	AirXchange	
Heat Wheel Model Number:	ERC-7490C	
Heat Wheel Media:	Composite	
Heat Wheel Coating:		
Arrangement:	Vertical	

Design Conditions		Option Notes	
	Dry Bulb, °F	Wet Bulb, °F	
Summer, Outdoor:	92.00	74.00	
Summer, Indoor:	75.00	63.00	
Winter, Outdoor:	9.00	8.00	
Winter, Indoor:	72.00	54.00	

Heat Wheel Performance		
	Summer	Winter
Net Effectiveness (%)	81.68	83.34
Sensible Effectiveness (%):	84.36	84.61
Latent Effectiveness	79.32	79.57
Supply Air Conditions (db, °F)	77.57	61.56
Supply Air Conditions (wb, °F)	65.20	47.95
Relative Humidity (%)	52.05	34.89
Total Recovered Load (BTU/Hr)	147858	328241

HEAT WHEEL IS ARI – 1060 CERTIFIED

Motor Performance		
Motor HP	0.250	
Volts/Phase/Hertz	230 / 240/ 3/ 60 Hz	

Project Name: Shippensburg Old Main
Printed: 10/25/2011 10:58:34

York Contract No.:
ERV-1Performance



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600
RPM	850		
FLA (Full Load Amps)	2.50		
Field Terminated Wiring			

Heat Wheel Segment Dampers

	Exhaust Air Bypass	Outside Air Bypass
Opening Size:	N/A	N/A
Area of Opening:	N/A	N/A
Damper (QTY)Size:	None	None
Damper Type:	N/A	N/A
Damper Configuration:	N/A	N/A
Damper Model:	N/A	N/A
Damper Material:	N/A	N/A
Blade Orientation:	N/A	N/A

XA Access Segment

Access Segment Details		Access Segment Options
Segment Length:	31 "	Interior Galvanized Liner Insulation: R-13 Foam Insulation Galvanized Floor Liner STD Gauge Exterior Galvanized Liner Access Door on Left Side(Left) 45H x 24W Standard Door Latch, No Lock, Outward Opening 10" Additional Core Growth

Project Name: Shippensburg Old Main
Printed: 10/25/2011 10:58:34

York Contract No.:
ERV-1Performance



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

FS - Supply Fan Segment

Segment Details		Fan Segment Options
Segment Air Pressure Drop (in. w.g.):	0.00	1" Spring Isolator
Air Flow (CFM):	4600	Interior Galvanized Liner
Altitude (ft.):	348	Insulation: R-13 Foam Insulation
TSP/ESP (in. w.g.):	2.19/ 1.50	Galvanized Floor Liner STD Gauge
Air Inlet:	Front(Front)	Exterior Galvanized Liner
Fan Discharge:	Rear(Rear)	Access Doors on Both Sides 45H x 18W
		Standard Door Latch, No Lock, Outward Opening

Fan Detail

Type:	AF
Size:	18-18
Construction:	S
Bearing Options:	None
Fan RPM:	1402
BHP:	2.22
Fan BHP w/ Belt Loss:	2.37
Outlet Velocity (ft/min):	1460

Motor Detail

Motor Type:	ODP Premium Efficiency
HP	3.0
Voltage/Phase/Frequency:	460/3/60 Hz
Motor RPM:	1800
Frame Size:	182
Location:	Left(Left)
Drive Type:	Belt Drive
Belt Drive Type:	Fixed
Full Load Amps (FLA):	4.1
Efficiency:	89.5%



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Motor Control – Supply Fan

Motor Control Details		Motor Control Electrical Details	
Motor Control Type:	EM Starter	Full Load Amps (FLA):	4.1
Motor HP:	3		

Motor Control Options

Fused Disconnect
Extra Auxiliary Contacts: (1) Normally Open
Enclosure Location: Primary Access Side of FS

Copper Conductors Only

Electrical Circuit Summary

Short-Circuit Summary	
5 kA rms Symmetrical	480 V Maximum

Circuit 1

Supply Fan Motor Control

Circuit 1 Electrical Details

Full Load Amps (FLA):	4.1
Minimum Circuit Ampacity (MCA):	5.1
Maximum Fuse Size:	9.00

Circuit 2

Exhaust Fan Motor Control

Circuit 2 Electrical Details

Full Load Amps (FLA):	4.1
Minimum Circuit Ampacity (MCA):	5.1
Maximum Fuse Size:	9.00

Circuit 3

Heat Wheel Motor

Circuit 3 Electrical Details

Full Load Amps (FLA):	2.5
Minimum Circuit Ampacity (MCA):	3.1
Maximum Fuse Size:	5.00



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Static Pressure Summary

Segment	Component	Supply (in. w.g.)	Exhaust Fan (in. w.g.)
IP Inlet Plenum	Opening Pressure Drop	0.07	
AF Angle Filter	2" Pleated 30% (MERV 7)	0.05	
	Dirty Filter Allowance	0.10	
HW2 Heat Wheel - Vertical - Top Tier	Energy Wheel Exhaust Pressure Drop	0.50	
FE-DWDI Exhaust Fan	External Static Pressure - User Entered Pressure Drop	1.25	
MB Mixing Box	Opening Pressure Drop	0.04	
AF Angle Filter	2" Pleated 30% (MERV 7)	0.05	
	Dirty Filter Allowance	0.10	
HW1 Heat Wheel - Vertical - Bottom Tier	Energy Wheel Supply Pressure Drop	0.50	
FS-DWDI Supply Fan	External Static Pressure - User Entered Pressure Drop	1.50	
Total		2.19	1.97

Air handling unit parameters vary depending on conditions. Parameters such as airflows, air pressure drops, and coil capacities are shown for design conditions.

Dimension & Weights Summary

Section	Length*	Width**	Height	Weight (lbs.)
IP Inlet Plenum Segment	-	87	51	460
AF Angle Filter Segment	-	87	51	337
XA Variable Length Access Segment	-	87	51	228
HW2 Heat Wheel - Vertical - Top Tier Segment	-	87	51	622
XA Variable Length Access Segment	-	87	51	258
FE-DWDI Exhaust Fan Segment	-	87	51	995
MB Mixing Box Segment	29	87	51	473
AF Angle Filter Segment	17	87	51	315
XA Variable Length Access Segment	21	87	51	217
HW1 Heat Wheel - Vertical - Bottom Tier Segment	28	87	51	1089
XA Variable Length Access Segment	31	87	51	321
FS-DWDI Supply Fan Segment	41	87	51	1014
Overall:		167	87	102
				6329

*The length includes bottom tier segments only.

**The width does not include coil connection extensions or door latches that extend beyond the unit casing.

The width does not include the depth of any pipe chases.



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Shipping Skid Summary

Shipping Skid	Length* (in.)	Width** (in.)	Height*** (in.)	Weight (lbs.)
(HW1 HW2)	28	90	112	1711
(FS-DWDI XA)	74	99	61	1335
(XA AF MB)	67	93	61	1005
(IP AF XA)	72	93	55	1025
(XA FE-DWDI)	68	99	55	1253

Ship Loose:

None

*The length includes any mounted rain-hoods, discharge flanges, tie-down brackets, shipping wood-blocks, front dampers, split connectors, electrical/control components, out rigging HW supports, isolation dampers

****The width includes any door handles, coil connections, drain connections, lifting lugs, mounted pipe-chases, electrical/control components, tie-down brackets, side dampers**

***The height includes any base-rails, shipping wood-blocks, roof peak, discharge flanges, mounted gas-furnace flue pipes, components, etc., shown attached, save dampers

Shipping Skid Sequence

Tier 2

(IP > AF > XA) > (HW > XA > FE)

Tier 1

(FS < XA) < (HW < XA < AF < MB)



SOLUTION AIR HANDLING UNIT PERFORMANCE SPECIFICATION

Unit Tag	Qty	Model	Air Flow (CFM)
ERV-1	1	Solution Indoor Air Handler 51 x 87	4600

Sound Summary

Octave Band Sound Power Levels (dB Re. 1 picowatt)


63 125 250 500 1000 2000 4000 8000 dBA

Contact the Solution Application Group for Heat Wheel Sound Data

Sound data tested in accordance with ARI-260 (2000), Standard for Sound Rating of Ducted Air Moving and Conditioning Equipment.

Notes:

1. The overall A-weighted sound power level is only applicable to sound radiation outdoors and casing radiated sound. This metric does not apply to ducted components






Project Name: Shippensburg Old Main
 Location:
 Consultant/Engineer:
 Contractor:
 Sold To:
 P.O. No: PO

JCI Contract No: Contract #
 Coll Version: 4.28a
 Printed Date: 10/25/2011 11:11:17 AM
 Selection Date: 10/25/2011 11:08:11 AM
 Last Revision Date: 10/25/2011 11:10:03 AM

Performance Data Sheet

Unit Tag	Qty	Model	Air Flow	Total Duty	Sensible Duty			
FCU-1	1	FWI-C12	703 cfm	23,340 Btuh	17,410 Btuh			
Unit Data								
Model Size	: 12	Filter	: 1" Pleated (MERV 8)	Coil Tube Diameter	[in.] 1/2			
Type	: Vertical Floor - Series C	Filter (Qty) Size	: (3) 9.25 X 21.75 X 1	Tube Wall	[in.] 0.016			
Fans/Motors	: 4 / 2	Filter Face Area	[in.] 4.19	Coil Face Area	[in.] 4.03			
Capacity	: Standard Capacity			Weight*	: 261.00 lb			
Output Data								
Altitude	[ft.]	0		Options				
Air Flow Rate	[cfm]	703		1" Pleated Spare Filter (MERV 8) (1)				
ESP	[in.wg]	0.05		16 Gauge Front Panel				
Cooling Data								
EAT DB/WB	[°F]	76.0/63.0		Auxiliary Drip Pan- Plastic, Double Wall				
LAT DB/WB	[°F]	52.0/51.5		BC006 24V, Unit S/S & Fan Op. Relay, 3-Spd Fan Relay & Transformer				
Total Capacity	[Btuh]	23,340		Coil Casing- Galvanized Casing				
Sensible Capacity	[Btuh]	17,410		OC011 Drain Pan Float Switch				
EWT/LWT	[°F]	45.0/55.0		OC012 Toggle Disconnect Switch - 15 amps				
Fluid Flow	[gpm]	4.60		OC015 Main Fusing (Up to 32 AMPS)				
Fluid P.D.	[ft.wg]	13.98		Paint Options- Pearl White Satin				
Fluid Velocity	[fps]	4.00		Remote Mounted Thermostat				
Rows / FPI / Circuits	:	3 Rows / 10 FPI / 2 Ckt		Return Air Options- Return: Stamped Louver Grille				
Heating Data								
EAT DB	[°F]	70.0		Stainless Steel Unit Drain Pan				
LAT DB	[°F]	111.1		Standard Height				
Sensible Capacity	[Btuh]	31,420		Standard Width				
EWT/LWT	[°F]	160.0/180.0		Supply Air Options- Supply: Stamped Louver Grille				
Fluid Flow	[gpm]	3.20		Tamper Proof Fasteners				
Fluid P.D.	[ft.wg]	15.03		Cooling Coil: Field Provided Piping Package Size - 1/2"				
Fluid Velocity	[fps]	5.60		Cooling Coil: Field Provided by others (2-Position Close-Off)				
Rows / FPI / Circuits	:	1 Row / 10 FPI / 1 Ckt		Cooling Coil: Left Hand Connection				
Special Quote (SQ) #								
Electrical Data				Cooling Coil: Manual Air Vent				
WPH/HZ	:	208/160		Heating Coil: Field Provided Piping Package Size - 1/2"				
Fan Power Input	[Watts]	147		Heating Coil: Field Provided by others (2-Position Close-Off)				
Sound power By Octave Band (dB Re 10¹² Watts)								
Speed	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
High	62	64	65	58	50	44	35	





VAV Box Schedule Printout

Job Name				JCI Order Number	
Engineers Firm				Date	
No	Tag	Qty	Model Desc	Size	Max Primary CFM
1	VAV1	1	TSS & TSL - Single Duct.	.08	450
			Code Compliant		
				Total SPD In wg	Min Primary CFM
				0.20	150
				Circuits	EAT
				2	2
				Flow Rate GPM	EWT LWT °F °F
				55.0	180.7
				1.8	180.0 160.0

JCI Selection Program Version V2.00a Date 15 Oct 2010 DB 372 Date 15 Oct 2010

Page 1